

# 20.11.41 NMAC "AUTHORITY-TO-CONSTRUCT" PERMIT #0273-M3-1TR MODIFICATION APPLICATION FOR PRESBYTERIAN HEALTHCARE SERVICES' ENERGY CENTER

Albuquerque, New Mexico

PREPARED FOR PRESBYTERIAN HEALTHCARE SERVICES

**JANUARY 2022** 

Prepared by

Montrose Air Quality Services, LLC



# Introduction

This 20.11.41.2 permit application is for a significant modification of Presbyterian Healthcare Services (PHS) Permit #0273-M3-1TR to include installation of a new Caterpillar Model G3516H Natural Gas Cogeneration (CoGen) Package (Unit 8) and installation of new burners for Boilers 1 and 2 (Permit Units 3 and 4). The CoGen will produce electricity and steam (heat) for the new hospital building under construction. PHS has retained Montrose Air Quality Services, LLC (Montrose) to assist with the 20.11.41 NMAC "Authority to Construct" significant permit modification application. The location for the new CoGen will be in the expanded energy center at 1002 Silver Ave SE. The UTM coordinates of the energy center is; 350,835 meters E, 3,883,175 meters N, Zone 13, NAD 83.

Presently, Air Quality Permit #0273-M3-1TR for the energy center includes four (4) steam boilers and three (3) emergency generators. In the existing permit, the boilers are allowed to operate 8,760 hours each which includes 48 hours burning diesel for Units 3, 4, and 6. For this permit modification, PHS will restrict the use of the boilers to only three boilers operating under maximum conditions at any one time for 8,760 hours per year. This requested permit change will add additional permit conditions to the present operation of the boilers, including recordkeeping and reporting requirements.

No startup/shutdown emission rates are expected to be greater than what is proposed for normal operations of the regulated equipment.

## **Operational Plan to Mitigate Emissions and Plan of Work Practices**

## <u>Startup</u>

<u>CoGen</u> - the engine is preheated before starting the warm up period to full loading, which is a very short period. The oxidation catalyst is the only pollution control equipment and it will be preheated and will be functioning almost immediately upon engine startup, so there is no startup emissions calculated. CAT does not publish emission numbers for startup and shutdown for the G3516H engine.

<u>Boilers</u> – The startup of the boilers takes a slow start and my last an hour to complete. During this time, the emission rates of all pollutants will not exceed the allowable emission rate. Most emission rates are based on fuel consumption, Btu input, or exhaust flowrate which will increase until maximum operation. No excess emissions beyond the allowable emissions will be generated during startup.

#### **PHS Energy Center – Introduction**

#### Shutdown

No excess emissions beyond the allowable emissions will be generated during shutdown. The oxidation catalyst will operate during shutdown of the CoGen.

#### Maintenance

All permitted equipment will be maintained to prevent excess emissions during startup or shutdown. This facility will not have excess emissions during any maintenance procedures. The Operations and Maintenance schedules are found in Section C and in files submitted with the application.

#### Malfunction

No predicted malfunctions are expected since each unit will have a rigorous maintenance schedule. Each unit is computer controlled where malfunctions will be identified and the unit shutdown. The malfunctioning equipment will cease until repairs are made. If excess emissions occur they will be reported per 20.11.49 NMAC– Excess Emissions.

If you have any questions regarding this permit application please call Paul Wade of Montrose at (505) 830-9680 x6 or Keith Long of PHS at (505) 563-6221.

#### The contents of this application packet include:

20.11.41 NMAC Permit Fee Review 20.11.41 NMAC Permit Application Checklist 20.11.41 NMAC Permit Application Forms Attachment A: Figure A-1: PHS Energy Center Facility Layout Attachment B: Emission Calculations Attachment C: Emission Calculations Support Documents Attachment D: Figure D-1: Aerial Map Attachment E: Facility Description Attachment F: Regulatory Applicability Determination Attachment G: Dispersion Modeling Summary and Report Attachment H: Public Notice Documents



# **City of Albuquerque**

Environmental Health Department Air Quality Program



# Permit Application Review Fee Checklist Effective January 1 - December 31, 2021

Please completely fill out the information in each section. Incompleteness of this checklist may result in the Albuquerque Environmental Health Department not accepting the application review fees. If you should have any questions concerning this checklist, please call 768-1972.

#### I. COMPANY INFORMATION:

Company Name	Presbyterian Healthcare Services				
Company Address	1100 Central Ave. SE, Albuquerque	, NM 87106			
Facility Name	Energy Center				
Facility Address	1002 Silver Ave. SE, Albuquerque, NM 87106				
Contact Person	Keith Long				
<b>Contact Person Phone Number</b>	hlong4@phs.org				
Are these application review fees for an	Are these application review fees for an existing permitted source located				
within the City of Albuquerque or Bernalillo County?					
If yes, what is the permit number associated with this modification? Permit #0273-M3-1TR			3-1TR		
Is this application review fee for a Qualified Small Business as defined in		Voc	No		
20.11.2 NMAC? (See Definition of Qualified Small Business on Page 4) Yes <u>No</u>					

#### II. STATIONARY SOURCE APPLICATION REVIEW FEES:

If the application is for a new stationary source facility, please check all that apply. If this application is for a modification to an existing permit please see Section III.

Check All That Apply	Stationary Sources		Program Element
	Air Quality Notifications		
	AQN New Application	\$581.00	2801
	AQN Technical Amendment	\$318.00	2802
	AQN Transfer of a Prior Authorization	\$318.00	2803
Х	Not Applicable		
	Stationary Source Review Fees (Not Based on Proposed Allowable Emission I	Rate)	
	Source Registration required by 20.11.40 NMAC	\$ 592.00	2401
	A Stationary Source that requires a permit pursuant to 20.11.41 NMAC or other board regulations and are not subject to the below proposed allowable emission rates	\$ 1,185.00	2301
Х	Not Applicable		
Stationa	ry Source Review Fees (Based on the Proposed Allowable Emission Rate for the single	highest fee pol	lutant)
	Proposed Allowable Emission Rate Equal to or greater than 1 tpy and less than 5 tpy	\$ 889.00	2302
	Proposed Allowable Emission Rate Equal to or greater than 5 tpy and less than 25 tpy	\$1,777.00	2303
	Proposed Allowable Emission Rate Equal to or greater than 25 tpy and less than 50 tpy	\$3,554.00	2304
	Proposed Allowable Emission Rate Equal to or greater than 50 tpy and less than 75 tpy	\$5,331.00	2305
	Proposed Allowable Emission Rate Equal to or greater than 75 tpy and less than 100 tpy	\$7,108.00	2306
	Proposed Allowable Emission Rate Equal to or greater than 100 tpy	\$8,885.00	2307
Х	Not Applicable		

Federal Program Review Fees (In addition to the Stationary Source Application Review Fees above)						
	40 CFR 60 - "New Source Performance Standards" (NSPS) \$1,185.00					
	40 CFR 61 - "Emission Standards for Hazardous Air Pollutants (NESHAPs)	\$1,185.00	2309			
	40 CFR 63 - (NESHAPs) Promulgated Standards	\$1,185.00	2310			
	40 CFR 63 - (NESHAPs) Case-by-Case MACT Review	\$11,847.00	2311			
	20.11.61 NMAC, Prevention of Significant Deterioration (PSD) Permit		2312			
	20.11.60 NMAC, Non-Attainment Area Permit	\$5,924.00	2313			
Х	Not Applicable	Not Applicable				

### III. MODIFICATION TO EXISTING PERMIT APPLICATION REVIEW FEES:

If the permit application is for a modification to an existing permit, please check all that apply. If this application is for a new stationary source facility, please see Section II.

Check All That Apply	Modifications	Review Fee	Program Element		
	Modification Application Review Fees (Not Based on Proposed Allowable Emissio	n Rate)			
	Proposed modification to an existing stationary source that requires a permit pursuant to 20.11.41 NMAC or other board regulations and are not subject to the below proposed allowable emission rates	\$ 1,185.00	2321		
Х	Not Applicable	See Sections Below			
	Modification Application Review Fees				
	(Based on the Proposed Allowable Emission Rate for the single highest fee pollu	tant)	2222		
	Proposed Allowable Emission Rate Equal to or greater than 1 tpy and less than 5 tpy	\$889.00	2322		
	and less than 25 tpy	\$1,777.00	2323		
	Proposed Allowable Emission Rate Equal to or greater than 25 tpy and less than 50 tpy	\$3,554.00	2324		
Х	Proposed Allowable Emission Rate Equal to or greater than 50 tpy and less than 75 tpy	\$5,331.00	2325		
	Proposed Allowable Emission Rate Equal to or greater than 75 tpy and less than 100 tpy	\$7,108.00	2326		
	Proposed Allowable Emission Rate Equal to or greater than 100 tpy		2327		
	Not Applicable	See Section Above			
	Major Modifications Review Fees (In addition to the Modification Application Review	Fees above)			
	20.11.60 NMAC, Permitting in Non-Attainment Areas	\$5,924.00	2333		
	20.11.61 NMAC, Prevention of Significant Deterioration	\$5,924.00	2334		
Х	Not Applicable	Not Applicable			
(This se	Federal Program Review Fees (This section applies only if a Federal Program Review is triggered by the proposed modification) (These fees are in addition to the Modification and Maior Modification Application Review Fees above)				
Х	40 CFR 60 - "New Source Performance Standards" (NSPS)	\$1,185.00	2328		
	40 CFR 61 - "Emission Standards for Hazardous Air Pollutants (NESHAPs)	\$1,185.00	2329		
	40 CFR 63 - (NESHAPs) Promulgated Standards	\$1,185.00	2330		
	40 CFR 63 - (NESHAPs) Case-by-Case MACT Review	\$11,847.00	2331		
	20.11.61 NMAC, Prevention of Significant Deterioration (PSD) Permit	\$5,924.00	2332		
	20.11.60 NMAC, Non-Attainment Area Permit	\$5,924.00	2333		
	Not Applicable	Not Applicable			

#### IV. ADMINISTRATIVE AND TECHNICAL REVISION APPLICATION REVIEW FEES:

If the permit application is for an administrative or technical revision of an existing permit issued 20.11.41 NMAC, please check one that applies.

pursuant to

Check One	Revision Type	Review Fee	Program Element
	Administrative Revisions	\$ 250.00	2340
	Technical Revisions	\$ 500.00	2341
X	Not Applicable	See Sections II, III or V	

#### V. PORTABLE STATIONARY SOURCE RELOCATION FEES:

#### If the permit application is for a portable stationary source relocation of an existing permit, please check one that applies.

Check One	Portable Stationary Source Relocation Type	Review Fee	Program Element
	No New Air Dispersion Modeling Required	\$ 500.00	2501
	New Air Dispersion Modeling Required	\$ 750.00	2502
X	Not Applicable	See Sections II, III or V	

#### VI. Please submit a check or money order in the amount shown for the total application review fee.

Section Totals	Review Fee Amount
Section II Total	\$0
Section III Total	\$6,516.00
Section IV Total	\$0
Section V Total	\$0
Total Application Review Fee	\$6,516.00

I, the undersigned, a responsible official of the applicant company, certify that to the best of my knowledge, the information stated on this checklist, give a true and complete representation of the permit application review fees which are being submitted. I also understand that an incorrect submittal of permit application reviews may cause an incompleteness determination of the submitted permit application and that the balance of the appropriate permit application review fees shall be paid in full prior to further processing of the application.

Signed this 17 day of December 2021 Director, Engineering H. Keith Long Print Title **Print Name** 

#### **Definition of Qualified Small Business** as defined in 20.11.2 NMAC:

"Qualified small business" means a business that meets all of the following requirements:

- (1) a business that has 100 or fewer employees;
- (2) a small business concern as defined by the federal Small Business Act;
- (3) a source that emits less than 50 tons per year of any individual regulated air pollutant, or less than 75 tons per year of all regulated air pollutants combined; and
- (4) a source that is not a major source or major stationary source.

**Note:** Beginning January 1, 2011, and every January 1 thereafter, an increase based on the consumer price index shall be added to the application review fees. The application review fees established in Subsection A through D of 20.11.2.18 NMAC shall be adjusted by an amount equal to the increase in the consumer price index for the immediately-preceding year. Application review fee adjustments equal to or greater than fifty cents (\$0.50) shall be rounded up to the next highest whole dollar. Application review fee adjustments totaling less than fifty cents (\$0.50) shall be rounded down to the next lowest whole dollar. The department shall post the application review fees on the city of Albuquerque environmental health department air quality program website.



# City of Albuquerque Environmental Health Department Air Quality Program



# **Permit Application Checklist**

Any person seeking a permit under 20.11.41 NMAC, Authority-to-Construct Permits, shall do so by filing a written application with the Department. Prior to ruling a submitted application complete each application submitted shall contain the required items listed below. This checklist must be returned with the application.

Applications that are ruled incomplete because of missing information will delay any determination or the issuance of the permit. The Department reserves the right to request additional relevant information prior to ruling the application complete in accordance with 20.11.41 NMAC.

All applicants shall:

- 1. □ Fill out and submit the *Pre-permit Application Meeting Request* form a. □ Attach a copy to this application
- 2. X Attend the pre-permit application meeting
  - a.  $\Box$  Attach a copy of the completed *Pre-permit Application Meeting Checklist* to this application
- 3. **X** Provide public notice to the appropriate parties
  - a. Attach a copy of the completed *Notice of Intent to Construct* form to this form
    - i. Neighborhood Association(s):\_\_\_\_\_
    - ii. Coalition(s):

b.□ Attach a copy of the completed *Public Sign Notice Guideline* form

- 4. Fill out and submit the *Permit Application*. All applications shall:
  - A. X be made on a form provided by the Department. Additional text, tables, calculations or clarifying information may also be attached to the form.
  - B. X at the time of application, include documentary proof that all applicable permit application review fees have been paid as required by 20 NMAC 11.02. Please refer to the attached permit application worksheet.
  - C. X contain the applicant's name, address, and the names and addresses of all other owners or operators of the emission sources.
  - D. X contain the name, address, and phone number of a person to contact regarding questions about the facility.

Application Checklist Revised November 13, 2013

- E. X indicate the date the application was completed and submitted
- F. X contain the company name, which identifies this particular site.
- G. X contain a written description of the facility and/or modification including all operations affecting air emissions.
- H. X contain the maximum and standard operating schedules for the source after completion of construction or modification in terms of hours per day, days per week, and weeks per year.
- I. X provide sufficient information to describe the quantities and nature of any regulated air contaminant (including any amount of a hazardous air pollutant) that the source will emit during:
  - Normal operation
  - Maximum operation
  - > Abnormal emissions from malfunction, start-up and shutdown
- J. X include anticipated operational needs to allow for reasonable operational scenarios to avoid delays from needing additional permitting in the future.
- K. X contain a map, such as a 7.5-minute USGS topographic quadrangle, showing the exact location of the source; and include physical address of the proposed source.
- L. X contain an aerial photograph showing the proposed location of each process equipment unit involved in the proposed construction, modification, relocation, or technical revision of the source except for federal agencies or departments involved in national defense or national security as confirmed and agreed to by the department in writing.
- M. **X** contain the UTM zone and UTM coordinates.
- N. X include the four digit Standard Industrialized Code (SIC) and the North American Industrial Classification System (NAICS).
- O. X contain the types and <u>potential emission rate</u> amounts of any regulated air contaminants the new source or modification will emit. Complete appropriate sections of the application; attachments can be used to supplement the application, but not replace it.
- P. X contain the types and <u>controlled</u> amounts of any regulated air contaminants the new source or modification will emit. Complete appropriate sections of the application; attachments can be used to supplement the application, but not replace it.
- Q. X contain the basis or source for each emission rate (include the manufacturer's specification sheets, AP-42 Section sheets, test data, or other data when used as the source).

- R. X contain all calculations used to estimate <u>potential emission rate</u> and <u>controlled</u> emissions.
- S. X contain the basis for the estimated control efficiencies and sufficient engineering data for verification of the control equipment operation, including if necessary, design drawings, test reports, and factors which affect the normal operation (e.g. limits to normal operation).
- T. X contain fuel data for each existing and/or proposed piece of fuel burning equipment.
- U. X contain the anticipated maximum production capacity of the entire facility and the requested production capacity after construction and/or modification.
- V. X contain the stack and exhaust gas parameters for all existing and proposed emission stacks.
- W. X provide an ambient impact analysis using a atmospheric dispersion model approved by the US Environmental Protection Agency (EPA), and the Department to demonstrate compliance with the ambient air quality standards for the City of Albuquerque and Bernalillo County (See 20.11.01 NMAC). If you are modifying an existing source, the modeling must include the emissions of the entire source to demonstrate the impact the new or modified source(s) will have on existing plant emissions.
- X. X contain a preliminary operational plan defining the measures to be taken to mitigate source emissions during malfunction, startup, or shutdown.
- Y.  $\Box$  contain a process flow sheet, including a material balance, of all components of the facility that would be involved in routine operations. Indicate all emission points, including fugitive points.
- Z. X contain a full description, including all calculations and the basis for all control efficiencies presented, of the equipment to be used for air pollution control. This shall include a process flow sheet or, if the Department so requires, layout and assembly drawings, design plans, test reports and factors which affect the normal equipment operation, including control and/or process equipment operating limitations.
- AA.  $\Box$  contain description of the equipment or methods proposed by the applicant to be used for emission measurement.
- BB. X be signed under oath or affirmation by a corporate officer, authorized to bind the company into legal agreements, certifying to the best of his or her knowledge the truth of all information submitted.



#### City of Albuquerque – Environmental Health Department Air Quality Program

Please mail this application to P.O. Box 1293, Albuquerque, NM 87103 or hand deliver between 8:00 am – 5:00 pm Monday-Friday to: 3rd Floor, Suite 3023 – One Civic Plaza NW, Albuquerque, NM 87102 (505) 768-1972 aqd@cabq.gov



### Application for Air Pollutant Sources in Bernalillo County Source Registration (20.11.40 NMAC) and Construction Permits (20.11.41 NMAC)

#### Submittal Date: January 28, 2022

<u>Corporate Information</u> Check here and leave this section blank if information is exactly the same as Facility Information below.

Company Name: Presbyterian Healthcare Services				
Mailing Address: PO Box 26666	City: Albuquerque	State: NM	Zip: <b>87125</b>	
Company Phone: 505-563-6221	Company Contact: Keith Long			
Company Contact Title: Director, Engineering	Phone: <b>505-563-6221</b>	E-mail: hlong4@phs.o	org	

Stationary Source (Facility) Information: Provide a plot plan (legal description/drawing of the facility property) with overlay sketch of facility processes, location of emission points, pollutant type, and distances to property boundaries.

Facility Name: Presbyterian Healthcare Services Energy Center	r				
Facility Physical Address: 1002 Silver Ave. SE	City: Albuquerque	State: NM	Zip: <b>87106</b>		
Facility Mailing Address (if different): <b>PO Box 26666</b>	City: Albuquerque	State: NM	Zip: <b>87125-</b> 6666		
Facility Contact: Keith Long	Title: Director, Engineering	Title: Director, Engineering			
Phone: <b>505-563-6221</b>	E-mail: hlong4@phs.org	E-mail: hlong4@phs.org			
Authorized Representative Name <sup>1</sup> : Keith Long	Authorized Representative	Authorized Representative Title: Director, Engineering			

#### Billing Information Check here if same contact and mailing address as corporate Check here if same as facility

Billing Company Name:			
Mailing Address:	City:	State:	Zip:
Billing Contact:	Title:		
Phone:	E-mail:		

#### Preparer/Consultant(s) Information Check here and leave section blank if no Consultant used or Preparer is same as Facility Contact.

Name: Paul Wade	Title: Principal / Senior Project Engineer		
Mailing Address: 3500 G Comanche Rd NE	City: Albuquerque State: NM Zip: 8		Zip: <b>87107</b>
Phone: <b>(505) 830-9680 x6</b>	Email: pwade@montrose-env.com		

1. See 20.11.41.13.E.(13) NMAC.

Application Received January 31, 2022 cqmd

#### General Operation Information (if any question does not pertain to your facility, type N/A on the line or in the box)

Permitting action being requested (please refer to the definitions in 20.11.40 NMAC or 20.11.41 NMAC):						
New Permit	Permit Modification Current Permit #: 0273-M3-1TR		Technical Permit Rev Current Permit #:	vision	Admir Current P	istrative Permit Revision ermit #:
UTM Coordinates or Latitude – Longitude of Facility: <b>350,835 meters E, 3,883,175 meters N, Zone 13, NAD 83</b>						
Facility Type (description of your f	acility operations): General N	Medica	and Surgical Hospital			
Standard Industrial Classification (	SIC Code #): <b>8062</b>		North American Industr 6221100	y Classific	cation Syst	em ( <u>NAICS Code #</u> ):
Is this facility currently operating i	n Bernalillo County? <b>Yes</b>		If <b>YES</b> , list date of origin If <b>NO</b> , list date of planne	al constru ed startur	uction: p:	
Is the facility permanent? Yes			If <b>NO</b> , list dates for requ From Throu	uested ter Igh	mporary o	peration:
Is the application for a physical or control equipment, etc.) to an exist	operational change, expansions of the second stress	on, or r	econstruction (altering p	rocess, or	adding, o	r replacing process or
Provide a description of the reque Package within the PHS Energy Co	sted changes: Installation of enter to supply electricity an	f a new nd stear	Caterpillar Model G3516 n heat for the new hospi	5H Natura ital tower	al Gas Cog r. Install n	eneration (CoGen) ew burners for boilers 1
Is the facility operation: Con	tinuous 🗌 Intermittent [	🗌 Bato	ch			
Estimated percent of production/operation:	Jan-Mar: <b>25</b>	Apr-Ju	n: <b>25</b> Jul-Se	ep: <b>25</b>		Oct-Dec: <b>25</b>
Requested operating times of facility:	24 hours/day	7 days,	/week <b>4.3</b> w	veeks/moi	nth	12 months/year
Will there be special or seasonal operating times other than shown above? This includes monthly- or seasonally-varying hours. No						
If YES, please explain:						
List raw materials processed:						
List saleable item(s) produced:						

## **Regulated Emission Sources Table**

(Generator-Crusher-Screen-Conveyor-Boiler-Mixer-Spray Guns-Saws-Sander-Oven-Dryer-Furnace-Incinerator-Haul Road-Storage Pile, etc.) Match the Units listed on this Table to the same numbered line if also listed on Emissions Tables & Stack Table.

U	nit Number and Description <sup>1</sup>	Manufacturer	Model #	Serial #	Manufacture Date	Installation Date	Modification Date <sup>2</sup>	Process Rate or Capacity (Hp, kW, Btu, ft <sup>3</sup> , Ibs, tons, yd <sup>3</sup> , etc.) <sup>3</sup>	Fuel Type
1	Internal Combustion/Gen erator (Diesel- Fired)	Caterpillar	3516B	1HZ02180	2002	2002		2,636 hp	Diesel
2	Internal Combustion/Gen erator (Diesel- Fired)	Caterpillar	3516B	7RN00972	1999	2000		2,628 hp	Diesel
3	Boiler (Natural Gas/Diesel-Fired)	Kewance	H3S500-G- 06	Order 606391	Unknown	1979	2022	20.9 MMBtu/hr	Natural Gas/Diesel
4	Boiler (Natural Gas/Diesel-Fired)	Kewance	H3S500-G- 06	Order 606391	Unknown	1979	2022	20.9 MMBtu/hr	Natural Gas/Diesel
5	Boiler (Natural Gas-Fired)	Superior	HPG-C5V	03971989P	1997	Unknown		8.4 MMBtu/hr	Natural Gas
6	Boiler (Natural Gas/Diesel-Fired)	Burnham Industrial	LN5P-500- 50-G0-WEB	Burner # U66158A- 1-8-02 Order # 682532	2002	2002		21 MMBtu/hr	Natural Gas/Diesel
7	Diesel-Fired Engine	Caterpillar	3516C	SBJ02005	6/2016	2016		2,937 hp	Diesel
/	Generator	Caterpillar	SR5-1645	G2T00106	6/2016	2016		2,000 kW	
8	Internal Combustion/Elec tric and Steam Generator (Natural Gas- Fired)	Caterpillar	G3516H	NWJ01131	2021	2022		2,763 bhp	Natural Gas
								/	
								/	
								/	
								/	
								/	

NOTE: To add extra rows in Word, click anywhere in the last row. A plus (+) sign should appear on the bottom right corner of the row. Click the plus (+) sign to add a row. Repeat as needed.

1. Unit numbers must correspond to unit numbers in the previous permit unless a complete cross reference table of all units in both permits is provided.

- 2. Have changes been made to the unit that impact emissions or that trigger modification as defined in 20.11.41.7.U NMAC?
- 3. Basis for Equipment Process Rate or Capacity (Manufacturer's data, Field observation/test, etc.) <u>Manufacturer's Data</u> Submit information for each unit as an attachment.

# **Emissions Control Equipment Table**

Control Equipment Units listed on this Table should either match up to the same Unit number as listed on the Regulated Emission Sources, Controlled Emissions and Stack Parameters Tables (if the control equipment is integrated with the emission unit) or should have a distinct Control Equipment Unit Number and that number should then also be listed on the Stack Parameters Table.

Contr	ol Equipment Unit Number and Description	Controlling Emissions for Unit Number(s)	Manufacturer	Model #   Serial #	Date Installed	Controlled Pollutant(s)	% Control Efficiency <sup>1</sup>	Method Used to Estimate Efficiency	Rated Process Rate or Capacity or Flow
8b	Oxidation Catalyst	8	Miratech	IQ2-30-20   RE- 41663	2022	CO, VOC, CH₂O	CO - 80% VOC - 40% CH₂O - 70%	Manufacturer Calculated Reduction	2,763 bhp
				I					
				I					
				I					
				I					
				I					
				I					
				I					
				I					
				Ι					

NOTE: To add extra rows in Word, click anywhere in the last row. A plus (+) sign should appear on the bottom right corner of the row. Click the plus (+) sign to add a row. Repeat as needed.

1. Basis for Control Equipment % Efficiency (Manufacturers data, Field Observation/Test, AP-42, etc.). <u>Manufacturer Calculated Reduction</u> Submit information for each unit as an attachment.

# **Exempted Sources and Exempted Activities Table**

				See 20.11.	41 IOI exempti	0115.			
U	nit Number and Description	Manufacturer	Model #	Serial #	Manufacture Date	Installation Date	Modification Date <sup>1</sup>	Process Rate or Capacity (Hp, kW, Btu, ft <sup>3</sup> , Ibs, tons, yd <sup>3</sup> , etc.) <sup>2</sup>	Fuel Type
	N/A							/	
								/	
								/	
								/	
								/	
								/	
								/	
								/	
								/	
								/	
								/	
								/	
								/	
								/	
								/	

See 20.11.41 for exemptions.

NOTE: To add extra rows in Word, click anywhere in the last row. A plus (+) sign should appear on the bottom right corner of the row. Click the plus (+) sign to add a row. Repeat as needed.

1. Have changes been made to the unit that impact emissions, that trigger modification as defined in 20.11.41.7.U NMAC, or that change the status from exempt to non-exempt?

2. Basis for Equipment Process Rate or Capacity (Manufacturer's data, Field observation/test, etc.) \_\_\_\_\_\_ Submit information for each unit as an attachment.

# **Uncontrolled Emissions Table**

(Process potential under physical/operational limitations during a 24 hr/day and 365 day/year = 8760 hrs)

Regulated Emission Units listed on this Table should match up to the same numbered line and Unit as listed on the Regulated Emissions and Controlled Tables. List total HAP values per Emission Unit if overall HAP total for the facility is ≥ 1 ton/yr.

Unit Number*	Nitroge (N	n Oxides O <sub>x</sub> )	Carbon N (C	Monoxide CO)	Nonm Hydrocarb Organic C (NMH	nethane oons/Volatile Compounds C/VOCs)	Sulfur (S	Dioxide O <sub>2</sub> )	Particula ≤ 10 N (PN	te Matter Aicrons M <sub>10</sub> )	Particula ≤ 2.5 N (PN	te Matter Aicrons $A_{2.5}$ )	Hazard Pollutan	lous Air ts (HAPs)	Method(s) used for Determination of Emissions (AP-42, Material Balance, Field Tests, etc.)
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	
1	31.1	7.8	4.6	1.1	1.3	0.3	5.4	1.4	1.0	0.3	1.0	0.3	0.11	0.0021	Permit #023-M3-1TR Emission Limits
2	31.1	7.8	4.6	1.1	1.3	0.3	5.4	1.4	1.0	0.3	1.0	0.3	0.11	0.0021	Permit #023-M3-1TR Emission Limits
2	<b>1.46</b> <sup>(4)</sup>	6.38 <sup>(4)</sup>	0.77 <sup>(4)</sup>	3.37 <sup>(4)</sup>	0.52 <sup>(4)</sup>	2.28 <sup>(4)</sup>	0.05 <sup>(4)</sup>	0.22 <sup>(4)</sup>	0.10 <sup>(4)</sup>	0.44 <sup>(4)</sup>	0.10 <sup>(4)</sup>	<b>0.44</b> <sup>(4)</sup>	0.042(4)	0 19(4)	Manufacturer Data – NOx, CO, VOC, PM; SO2 – Fuel Sulfur Content
3	<b>3.06</b> <sup>(5)</sup>	0.07 <sup>(5)</sup>	0.77 <sup>(5)</sup>	0.019 <sup>(5)</sup>	0.80 <sup>(5)</sup>	0.019 <sup>(5)</sup>	1.07 <sup>(5)</sup>	0.026 <sup>(5)</sup>	<b>0.3</b> <sup>(5)</sup>	0.007 <sup>(5)</sup>	<b>0.3</b> <sup>(5)</sup>	0.007 <sup>(5)</sup>	0.042\''	0.18("	Manufacturer Data – NOx, CO, VOC, PM; SO2 – Fuel Sulfur Content
	1.46 <sup>(4)</sup>	6.38 <sup>(4)</sup>	0.77 <sup>(4)</sup>	3.37 <sup>(4)</sup>	0.52 <sup>(4)</sup>	2.28 <sup>(4)</sup>	0.05 <sup>(4)</sup>	0.22 <sup>(4)</sup>	0.10 <sup>(4)</sup>	0.44 <sup>(4)</sup>	0.10 <sup>(4)</sup>	0.44 <sup>(4)</sup>	0.042(4)	0.19(4)	Manufacturer Data – NOx, CO, VOC, PM; SO2 – Fuel Sulfur Content
4	<b>3.06</b> <sup>(5)</sup>	0.07 <sup>(5)</sup>	0.77 <sup>(5)</sup>	0.019 <sup>(5)</sup>	0.80 <sup>(5)</sup>	0.019 <sup>(5)</sup>	1.07 <sup>(5)</sup>	0.026 <sup>(5)</sup>	<b>0.3</b> <sup>(5)</sup>	0.007 <sup>(5)</sup>	<b>0.3</b> <sup>(5)</sup>	0.007 <sup>(5)</sup>	0.042\*	0.18\*'	Manufacturer Data – NOx, CO, VOC, PM; SO2 – Fuel Sulfur Content
5	1.0	4.4	0.9	3.7	0.06	0.2	0.01	0.03	0.08	0.34	0.08	0.34	0.017	0.073	Permit #023-M3-1TR Emission Limits
6	<b>1.06</b> <sup>(4)</sup>	4.60 <sup>(4)</sup>	2.1 <sup>(4)</sup>	9.3 <sup>(4)</sup>	<b>0.1</b> <sup>(4)</sup>	0.6 <sup>(4)</sup>	0.02 <sup>(4)</sup>	0.07 <sup>(4)</sup>	0.2(4)	0.8(4)	0.2(4)	0.8(4)	0.042 <sup>(4)</sup>	0.18 <sup>(4)</sup>	NOx Recalulated at 30 PPM per Manufacturer; Permit #023-M3-1TR Emission Limits – CO, VOC, PM, SO2
	3.0 <sup>(5)</sup>	<b>0.8</b> <sup>(5)</sup>	<b>0.8</b> <sup>(5)</sup>	<b>0.2</b> <sup>(5)</sup>	0.05 <sup>(5)</sup>	0.01 <sup>(5)</sup>	1.1 <sup>(5)</sup>	0.3 <sup>(5)</sup>	0.3 <sup>(5)</sup>	0.08(5)	0.3 <sup>(5)</sup>	0.08(5)			Permit #023-M3-1TR Emission Limits
7	29.53	7.38	16.83	4.21	1.55	0.39	3.56	0.89	0.97	0.24	0.97	0.24	0.12	0.0024	Permit #023-M3-1TR Emission Limits
8	6.09	26.68	49.34	216.11	3.25	14.23	0.038	0.17	0.16	0.71	0.16	0.71	4.17	18.27	Manufacturer Data
Totals of	<b>102.8</b> <sup>(4)</sup>		<b>79.92</b> <sup>(4)</sup>		8.61 <sup>(4)</sup>		14.53 <sup>(4)</sup>		3.61 <sup>(4)</sup>		3.61 <sup>(4)</sup>				
Uncontrolled Emissions	107.9(5)	72.37	78.62(5)	242.50	9.10 <sup>(5)</sup>	20.62	17.65 <sup>5)</sup>	4.74	4.11 <sup>5)</sup>	3.66	4.11 <sup>5)</sup>	3.66	4.65	18.89	

NOTE: To add extra rows in Word, click anywhere in the second-to-last row. A plus (+) sign should appear on the bottom right corner of the row. Click the plus (+) sign to add a row. Repeat as needed.

\*A permit is required and this application along with the additional checklist information requested on the Permit Application checklist must be provided if:

(1) any one of these process units or combination of units, has an uncontrolled emission rate greater than or equal to (≥) 10 lbs/hr or 25 tons/yr for any of the above pollutants, excluding HAPs, based on 8,760 hrs of operation; or

(2) any one of these process units <u>or</u> combination of units, has an uncontrolled emission rate  $\geq$  2 tons/yr for any single HAP or  $\geq$  5 tons/yr for any combination of HAPs based on 8,760 hours of operation; or (3) any one of the process units <u>or</u> combination of units is subject to an Air Board or federal emission limit or standard.

\* If all of these process units, individually <u>and</u> in combination, have an uncontrolled emission rate less than (<) 10 lbs/hr or 25 tons/yr for all of the above pollutants (based on 8,760 hrs of operation), but > 1 ton/yr for any of the above pollutants, then a source registration is required. <u>A Registration is required, at minimum</u>, for any amount of HAP emissions. Please complete the remainder of this form. (4) Pound per hour and ton per year when unit is operating with natural gas only

(5) Pound per hour and ton per year when unit is operating with diesel fuel for emergency, maintenance, and testing purposes only

cgmd v. November 2020

# **Controlled Emissions Table**

(Based on current operations with emission controls OR requested operations with emission controls)

Regulated Emission Units listed on this Table should match up to the same numbered line and Unit as listed on the Regulated Emissions and Uncontrolled Tables. List total HAP values per Emission Unit if overall HAP total for the facility is ≥ 1 ton/yr.

Unit Number	Nitroge (N	n Oxides O <sub>x</sub> )	Carbon I (C	Monoxide CO)	Nonm Hydrocarb Organic C (NMH	nethane ons/Volatile Compounds C/VOCs)	Sulfur (S	Dioxide O <sub>2</sub> )	Particula ≤ 10 № (PN	te Matter 1icrons N <sub>10</sub> )	Particulate 2.5 Micro	e Matter ≤ ns (PM <sub>2.5</sub> )	Hazard Pollutan	lous Air ts (HAPs)	Control Method	% Efficiency <sup>1</sup>
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr		
1	31.1	7.8	4.6	1.1	1.3	0.3	5.4	1.4	1.0	0.3	1.0	0.3	0.11	0.0021	NA	NA
2	31.1	7.8	4.6	1.1	1.3	0.3	5.4	1.4	1.0	0.3	1.0	0.3	0.11	0.0021	NA	NA
2	1.46 <sup>(2)</sup>	6.38 <sup>(2)</sup>	<b>0.77</b> <sup>(2)</sup>	<b>3.37</b> <sup>(2)</sup>	0.52 <sup>(2)</sup>	<b>2.28</b> <sup>(2)</sup>	0.05 <sup>(2)</sup>	0.22 <sup>(2)</sup>	0.10 <sup>(2)</sup>	0.44 <sup>(2)</sup>	0.10 <sup>(2)</sup>	0.44 <sup>(2)</sup>	0.042(2)	0 18(2)	NA	
5	<b>3.06</b> <sup>(3)</sup>	0.07 <sup>(3)</sup>	0.77 <sup>(3)</sup>	0.019 <sup>(3)</sup>	0.80 <sup>3)</sup>	0.019 <sup>(3)</sup>	1.07 <sup>(3)</sup>	0.026 <sup>(3)</sup>	0.30 <sup>(3)</sup>	0.007 <sup>(3)</sup>	0.30 <sup>(3)</sup>	0.007 <sup>(3)</sup>	0.042(-/	0.18(-)	NA	NA
	1.46 <sup>(2)</sup>	6.38 <sup>(2)</sup>	0.77 <sup>(2)</sup>	<b>3.37</b> <sup>(2)</sup>	0.52 <sup>(2)</sup>	<b>2.28</b> <sup>(2)</sup>	0.05 <sup>(2)</sup>	0.22 <sup>(2)</sup>	0.10 <sup>(2)</sup>	0.44 <sup>(2)</sup>	0.10 <sup>(2)</sup>	0.44 <sup>(2)</sup>	0.042(3)	0 1 8(2)	NA	
4	<b>3.06</b> <sup>(3)</sup>	0.07 <sup>(3)</sup>	0.77 <sup>(3)</sup>	0.019 <sup>(3)</sup>	0.80 <sup>3)</sup>	0.019 <sup>(3)</sup>	1.07 <sup>(3)</sup>	0.026 <sup>(3)</sup>	0.30 <sup>(3)</sup>	0.007 <sup>(3)</sup>	0.30 <sup>(3)</sup>	0.007 <sup>(3)</sup>	0.042(-)	0.18(-)	NA	NA
5	1.0	4.4	0.9	3.7	0.06	0.2	0.01	0.03	0.08	0.34	0.08	0.34	0.017	0.073	NA	NA
6	<b>1.06</b> <sup>(2)</sup>	4.60 <sup>(2)</sup>	<b>2.1</b> <sup>(2)</sup>	9.3 <sup>(2)</sup>	<b>0.1</b> <sup>(2)</sup>	0.6 <sup>(2)</sup>	0.02(2)	0.07 <sup>(2)</sup>	<b>0.2</b> <sup>(2)</sup>	<b>0.8</b> <sup>(2)</sup>	<b>0.2</b> <sup>(2)</sup>	0.8 <sup>(2)</sup>	0.042(2)	0 18(2)	NA	
0	<b>3.0</b> <sup>(3)</sup>	0.8 <sup>(3)</sup>	0.8 <sup>(3)</sup>	0.2 <sup>(3)</sup>	0.05 <sup>(3)</sup>	0.01 <sup>(3)</sup>	1.1 <sup>(3)</sup>	<b>0.3</b> <sup>(3)</sup>	0.3 <sup>(3)</sup>	0.08 <sup>(3)</sup>	0.3 <sup>(3)</sup>	0.08 <sup>(3)</sup>	0.042(-/	0.18(-)	NA	NA
7	29.53	7.38	16.83	4.21	1.55	0.39	3.56	0.89	0.97	0.24	0.97	0.24	0.12	0.0024	NA	NA
8	6.09	26.68	9.87	43.22	1.95	8.54	0.038	0.17	0.16	0.71	0.16	0.71	1.47	6.44	CO, VOC, Formaldehyde	80%, 40%, 70%
Totals of Controlled	101.8(2)	67.07	39.67 <sup>(2)</sup>	(( ))	7.25 <sup>(2)</sup>	14 72	14.52 <sup>(2)</sup>	4 71	3.53 <sup>(2)</sup>	2.22	<b>3.53</b> <sup>(2)</sup>	2.22	1.04	6.00		
Emissions (4)	106.9 <sup>(3)</sup>	67.97	38.37 <sup>(3)</sup>	66.22	7.74 <sup>(3)</sup>	14.73	17.64 <sup>(3)</sup>	4.71	4.03 <sup>(3)</sup>	3.32	<b>4.03</b> <sup>(3)</sup>	3.32	1.94	6.99		

NOTE: To add extra rows in Word, click anywhere in the second-to-last row. A plus (+) sign should appear on the bottom right corner of the row. Click the plus (+) sign to add a row. Repeat as needed.

1. Basis for Control Equipment % Efficiency (Manufacturers data, Field Observation/Test, AP-42, etc.). <u>Manufacturers Data</u> Submit information for each unit as an attachment.

(2) Pound per hour and ton per year when unit is operating with natural gas only

cgmd

(3) Pound per hour and ton per year when unit is operating with diesel fuel for emergency, maintenance, and testing purposes only

(4) Totals based on the highest maximum emission rates for three of the four boilers operating at the same time.



## Hazardous Air Pollutants (HAPs) Emissions Table

Report the Potential Emission Rate for each HAP from each source on the Regulated Emission Sources Table that emits a given HAP. Report individual HAPs with ≥ 1 ton/yr total emissions for the facility on this table. Otherwise, report total HAP emissions for each source that emits HAPs and report individual HAPs in the accompanying application package in association with emission calculations. If this application is for a Registration solely due to HAP emissions, report the largest HAP emissions on this table and the rest, if any, in the accompanying application package.

Linit Number	Tota	l HAPs	Formal	dehyde												
Unit Number	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
1	<mark>0.11</mark>	<mark>0.0021</mark>														
2	<mark>0.11</mark>	<mark>0.0021</mark>														
3	<mark>0.042</mark>	<mark>0.18</mark>														
4	<mark>0.042</mark>	<mark>0.18</mark>			HAPs Emi	ssion Rates	s were calcu	lated for								
5	0.017	0.073			gas is t	he prevaler	nt fuel comb	ousted.								
6	<mark>0.042</mark>	<mark>0.18</mark>														
7	<mark>0.12</mark>	<mark>0.0024</mark>														
8	<mark>1.47</mark>	<mark>6.44</mark>	1.16	5.07												
Totals of HAPs for all units: <sup>(1)</sup>	1.94	6.99	1.16	5.07												

NOTE: To add extra rows in Word, click anywhere in the second-to-last row. A plus (+) sign should appear on the bottom right corner of the row. Click the plus (+) sign to add a row. Repeat as needed.

Copy and paste the HAPs table here if need to list more individual HAPs.

(1) Totals based on the highest maximum emission rates for three (yellow highlighted) of the four boilers operating at the same time.

Product Categories (Coatings, Solvents, Thinners, etc.)	Hazardous Air Pollutant (HAP), or Volatile Hazardous Air Pollutant (VHAP) Primary To The Representative As Purchased Product	Chemical Abstract Service Number (CAS) of HAP or VHAP from Representative As Purchased Product	HAP or VHAP Concentration of Representative As Purchased Product (pounds/gallon, or %)	Concentration Determination (CPDS, MSDS, etc.) <sup>1</sup>	Total Product Purchases For Category	(-)	Quantity of Product Recovered & Disposed For Category	(=)	Total Product Usage For Category
1. N/A					lbs/yr	(-)	lbs/yr	(=)	lbs/yr
•					gal/yr	( )	gal/yr	. ,	gal/yr
2.					lbs/yr	(-)	lbs/yr	(=)	lbs/yr
					gal/yr	( )	gal/yr	. ,	gal/yr
3.					lbs/yr	(-)	lbs/yr	(=)	lbs/yr
					gal/yr	( )	gal/yr	. ,	gal/yr
4.					lbs/yr	(-)	lbs/yr	(=)	lbs/yr
					gal/yr	.,	gal/yr	. ,	gal/yr
5.					lbs/yr	(-)	lbs/yr	(=)	lbs/yr
					gal/yr	( )	gal/yr	. ,	gal/yr
6.					lbs/yr	(-)	lbs/yr	(=)	lbs/yr
					gal/yr	.,	gal/yr	. ,	gal/yr
7.					lbs/yr	(-)	lbs/yr	(=)	lbs/yr
					gal/yr	.,	gal/yr	. ,	gal/yr
8.					lbs/yr	(-)	lbs/yr	(=)	lbs/yr
					gal/yr	.,	gal/yr	. ,	gal/yr
9.					lbs/yr	(-)	lbs/yr	(=)	lbs/yr
					gal/yr	.,	gal/yr	. ,	gal/yr
					lbs/yr	(-)	lbs/yr	(=)	lbs/yr
					gal/yr		gal/yr		gal/yr
		TOTALS			lbs/yr	(-)	lbs/yr	(=)	lbs/yr
		-			gal/yr	( )	gal/yr	. ,	gal/yr

# Purchased Hazardous Air Pollutant Table\*

NOTE: To add extra rows in Word, click anywhere in the second-to-last row. A plus (+) sign should appear on the bottom right corner of the row. Click the plus (+) sign to add a row. Repeat as needed.

1. Submit, as an attachment, information on one (1) product from each Category listed above which best represents the average of all the products purchased in that Category.

\*NOTE: A Registration is required, at minimum, for any amount of HAP or VHAP emission. Emissions from purchased HAP usage should be accounted for on previous tables as appropriate. A permit may be required for these emissions if the source meets the requirements of 20.11.41.

# **Material and Fuel Storage Table**

					(Tanks, barrels, s	ilos, stockpiles	s, etc.)					
Storag	e Equipment	Product Stored	Capacity (bbls, tons, gals, acres, etc.)	Above or Below Ground	Construction (Welded, riveted) & Color	Installation Date	Loading Rate <sup>1</sup>	Offloading Rate <sup>1</sup>	True Vapor Pressure	Control Equipment	Seal Type	% Eff.²
UST1	Tank #1, UL A74663	#2 Diesel	30,000 Gal	Below	Dbl wall Fiberglas	12/2009	5000	Various	<15 kPa	NA	NA	NA
UST2	Tank #2, UL A74667	#2 Diesel	30,000 Gal	Below	Dbl wall fiberglas	12/2009	5000	Various	<15 kPa	NA	NA	NA

NOTE: To add extra rows in Word, click anywhere in the last row. A plus (+) sign should appear on the bottom right corner of the row. Click the plus (+) sign to add a row. Repeat as needed.

- Basis for Loading/Offloading Rate (Manufacturer's data, Field Observation/Test, etc.). Loading rate equal to delivery truck capacity; Unloading rate is various depending on demand from diesel-fired boilers and emergency generators operation Submit information for each unit as an attachment.
- 2. Basis for Control Equipment % Efficiency (Manufacturer's data, Field Observation/Test, AP-42, etc.). <u>NA</u> Submit information for each unit as an attachment.

# **Stack Parameters Table**

If any equipment from the Regulated Emission Sources Table Is also listed in this Stack Table, use the same numbered line for the emission unit on both tables to show the association between the Process Equipment and its stack.

Un	it Number and Description	Pollutant (CO, NOx, PM10, etc.)	UTM Easting (m)	UTM Northing (m)	Stack Height (ft)	Stack Exit Temp <b>.</b> (°F)	Stack Velocity (fps)	Stack Flow Rate (ACFM)	Stack Inside Diameter (ft)	Stack Type
3	Internal Combustion/ Generator (Diesel-Fired)	<b>NOx, CO, S02,</b> PMio, PM <sub>2.</sub> s	350833.1	3883177.0	37.0	400.0	27.57	7,073	2.33	Rain Cap
4	Boiler (Natural Gas/Diesel- Fired)	<b>NOx, CO, S02,</b> PM <sub>io</sub> , PM <sub>2,S</sub>	350835.9	3883176.6	37.0	400.0	27.57	7,073	2.33	Rain Cap
5	Boiler (Natural Gas/Diesel- Fired)	NOx, CO, S02, PM <sub>io</sub> , PM <sub>2.5</sub>	350837.9	3883176.2	37.0	400.0	21.66	2,835	1.67	Rain Cap
6	Boiler (Natural Gas- Fired)	<b>NOx, CO, S02,</b> PMio <b>,</b> PM <sub>2.5</sub>	350849.2	3883175.4	37.0	400.0	43.85	8,265	2.00	Rain Cap
8	Internal Combustion/ Electric and Steam Generator (Natural- Fired)	NOx, CO, 802, PMio, PM <sub>2.5</sub>	350838.3	3883182.2	49.0	375.0	64.54	8,448	1.67	Vertical

NOTE: To add extra rows in Word, click anywhere in the last row. A plus (+) sign should appear on the bottom right corner of the row. Click the plus (+) sign to add a row. Repeat as needed.

I, the undersigned, an authorized representative of the applicant company, certify that to the best of my knowledge, the information stated on this application, together with associated drawings, specifications, and other data, give a true and complete representation of the existing, modified existing, or planned new stationary source with respect to air pollution sources and control equipment. I also understand that any significant omissions, errors, or misrepresentations in these data will be cause for revocation of part or all of the resulting registration or permit.

day of Jak War Signed this , 20

Keith Long Print Name

Director, Engineering Print Title

Signature

Attachment A Facility Process Flow Diagram and Plot Plan



FIGURE A-1: PHS Energy Center Facility Layout

Attachment B Emissions Calculations There will be no emission change in existing Permitted Units 1, 2, 5 and 7 steam boilers and emergency generators emission rates with the exception of CO annual emission rates for Units 1 and 2. For these identical units all emissions are the same. In the present permit, CO annual emission rates are different and PHS has corrected the CO annual emission rate so they are the same for each unit.

For this significant permit application, PHS will add a new CoGen plant at the existing PHS Energy Center, and replacing the burners for steam boilers 1 and 2 (Units 3 and 4) with revised emission rate calculation based on manufacturers specifications. Additionally, for steam boiler 4 (Unit 6) the NOx emission rate will be recalculated per the original burner manufacturers emission rate guarantee (see Attachment C) of 30 PPM.

# CoGen (Permit Unit 8) Emission Rates

The CoGen will be permitted to operating at maximum emissions rates as supplied by the manufacturer, mass balance, or AP-42 emission factors, and operating for 8,760 hours per year. An oxidation catalyst is proposed for the CoGen engine. The oxidation catalyst will control emission of CO, VOC, and Formaldehyde potentially resulting from natural gas fuel combustion by the CoGen engine. Based on information provided by the oxidation catalyst manufacturer (Miratech), CO control efficiency is 80%, VOC is 40%, and Formaldehyde is 70%. To estimate the uncontrolled emission rate for CO, VOC, and Formaldehyde, the CAT allowable emission factors were adjusted by the pollutant control efficiency.

NO<sub>X</sub>, CO, VOC, formaldehyde, and CO<sub>2</sub> emission factors are extracted from the Caterpillar emission document found in Attachment C. Particulate emission factor for natural gas combustion for RICE engines is found in AP-42 Section 3.2 "Natural Gas-fired Reciprocating Engines".

Sulfur dioxide (SO<sub>2</sub>) emission rates were determined by mass balance based on the sulfur content in New Mexico natural gas and the amount of natural gas combusted. Based on Public Regulatory Commission documents (see Attachment C), the maximum sulfur content in New Mexico natural gas is 0.75 grains per 100 standard cubic feet (scf). The amount of Btu per hour combusted in the CoGen engine was extracted from Caterpillar emission document found in Attachment C and a lower heating value for natural gas of 905 Btu/scf.

The following is the emission calculations for the CoGen engine.

Engine BHP =	2,763	Manufactu	rer Data		
Hours/Yr =	8,760				
Fuel Consumption =	5,843	Btu/BHP-H	Ir, Manufacturer Data		
Fuel Consumption =	16,144,209	Btu/Hr			
Fuel Consumption =	17,700.0	scf/hr	LHV=	905	Btu/scf
Sulfur Content	0.75	grains/100	scf (NM regulatory limi	t)	

Catalyst Control Efficie	ncy	(see Section C)				
CO =	80	%				
VOC =	40	%				
Formaldehyde =	70	%				
Manufacturer Emission	Rates	(see Section C)				
	Uncontrolled	Manufacturer	Uncon	trolled	Cont	rolled
	g/BHP-hr	g/BHP-hr	lbs/hr	tpy	lbs/hr	tpy
NOx =	1.00	1.00	6.09	26.68	6.09	26.68
CO =	8.10	1.62	49.34	216.11	9.87	43.22
VOC =	0.53	0.32	3.25	14.23	1.95	8.54
Formaldehyde =	0.63	0.19	3.86	16.90	1.16	5.07
CO2 =	412	412	2,510	10,992	2,510	10,992
$SO_2 = 0.75$ grains/100 s	cf * 17,700.0 sci	f/hr/100 / 7,000 g	rains/pound <sup>•</sup>	* 2 S/SO <sub>2</sub>		
-		lbs/hr	tpy			
$SO_2 =$		0.038	0.17			
AP-42 Section 3.2 "Nat	ural Gas-fired R	eciprocating Engi	ines", Table	3.2-2		
	lb/MMBtu	lbs/hr	tpy			
PM Filterable =	7.71E-05	0.0012	0.0055			
PM Condensable =	9.91E-03	0.16	0.70			
PM Total =		0.16	0.71			

## Boilers 1 and 2 (Permit Units 3 and 4) Emission Rates

As part of this permit application, PHS will be installing new Power Flame Burners on Boilers 1 and 2 (Permit Units 3 and 4). The manufacturer's data sheet is found in Section C. These two boilers are permitted to combust both natural gas and diesel with manufacturer's emission rate represented in the manufacturer's data. For SO<sub>2</sub>, the emissions are based on the sulfur content of the fuel combusted, 0.75 grains/100 scf for natural gas and 500 PPM (0.05%) for diesel.

Emission Factor	0.070	lb/NOx per MMBTU Input		Manufacturer
Emission Factor	0.037	lb/CO per MMBTU Input		Manufacturer
Emission Factor	0.0048	lb/PM per MMBTU Input		Manufacturer
Emission Factor	0.025	lb/VOC per MMBTU Input		Manufacturer
MBH	20925			Manufacturer
MMBTU/Hr	20.925			Manufacturer
BTU/Hr	20925000			Manufacturer
scf/hr	23121.55	LHV=	905	Btu/scf

#### Emission Units 3 and 4 (Boiler 1 and 2) NG

Prepared by Montrose Air Quality Services, LLC

Hours per year	8712		
lbs/hr = lb/MMBTU * tpy = lbs/hr * hr/yr / 20	MMBTU/Hr 000 lbs/ton		
	lbs/hr	tpy	
NOx	1.46	6.38	Based on Emission Factor
CO	0.77	3.37	Based on Emission Factor
PM	0.10	0.44	Based on Emission Factor
VOC	0.52	2.28	Based on Emission Factor
Sulfur Content	0.75	grai	ins/100 scf (NM regulatory limit)
SO2 = grains/100 scf * so	cf/hr/100 / 7000 grain	s/lb * 2S/SO2	
		lbs/hr	tpy
SO2 =		0.050	0.22

## Emission Units 3 and 4 (Boiler 1 and 2) Diesel

0.146	lb/NOx per MMBTU	Input	Manufacturer
0.037	lb/CO per MMBTU l	Input	Manufacturer
0.0143	lb/PM per MMBTU	Input	Manufacturer
0.038	lb/VOC per MMBTU	J Input	Manufacturer
20925			Manufacturer
20.925			Manufacturer
20925000			Manufacturer
152.74	LHV=	137000	Btu/gallon
48			
	0.146 0.037 0.0143 0.038 20925 20.925 20925000 152.74 48	0.146 lb/NOx per MMBTU 0.037 lb/CO per MMBTU 0.0143 lb/PM per MMBTU 0.038 lb/VOC per MMBTU 20925 20.925 20925000 152.74 LHV= 48	0.146       lb/NOx per MMBTU Input         0.037       lb/CO per MMBTU Input         0.0143       lb/PM per MMBTU Input         0.038       lb/VOC per MMBTU Input         20925       20.925         20925000       152.74         48       137000

lbs/hr = lb/MMBTU * tpy = lbs/hr * hr/yr / 20 Manufacture Spec	MMBTU/Hr 00 lbs/ton		
	lbs/hr	tpy	
NOx	3.06	0.073	Based on Emission Factor
CO	0.77	0.019	Based on Emission Factor
PM	0.30	0.0072	Based on Emission Factor
VOC	0.80	0.019	Based on Emission Factor
Sulfur Content	500	PPM	
SO2 = gal/hr * 7 lbs/gal *	<sup>5</sup> PPM/1000000 * 25	S/SO2	
		lbs/hr	tpy
SO2 =		1.069	0.026

## **Boiler 4 (Permit Unit 6) Emission Rates**

For this application, PHS will be recalculate the NOx emission rate for Permit Unit 6 combusting natural gas. The new NOx emission rate for natural gas will be calculated using a parts per million (PPM) of 30 of the exhaust in standard cubic feet per minute (SCFM). The manufacturer's data sheet is found in Section C. NOx emission rate was calculated by converting PPM to pounds per hour.

**Emission Unit 6 (Boiler 4) Natural Gas** 

Boiler	Stack Flowrate (ACFM)					
Unit 6	8265					
Hours/Year on Natural Gas	8712					
NOx PPM	30	Manufacturer l	Data			
SCFM = ACFM * Standard '	Temperature (R	) / High Temper	ature (R)			
ACFM	Boiler High Temperature F	Standard Temperature F	Boiler High Temperature R	Standard Temperature R	SCFM	
8265	400	70	860	530	5094	
NOx lbs/hr = PPM/1000000	*Air Density (II	os/ft3) * SCFM Air Density	* min/hr * Mole	ecular Weight (1	mw) / mw air	
NOx lbs/hr	PPM	lbs/ft3	SCFM	min/hr	mw NOx	mw air
1.06	30	0.0749	5094	60	46.1	29.95
Tons per Year (tpy) = lbs/hr	* hr/yr / 2000 lt	os/ton				
NOx tpy	NOx lbs/hr	hr/yr	lbs/ton			
4.60	1.06	8712	2000			

	Uncontrolled Emission Totals														
	Decorintion	NC	) <sub>X</sub>	NO <sub>X</sub> +	NMHC	C	0	SC	$\mathbf{D}_2$	V	OC	P	M <sub>10</sub>	PN	<b>A</b> <sub>2.5</sub>
Unit #	Description	lbs/hr	tons/yr	lbs/hr	tons/yr	lbs/hr	tons/yr	lbs/hr	tons/yr	lbs/hr	lbs/hr	lbs/hr	tons/yr	lbs/hr	tons/yr
1	Internal Combustion/Emergency Generator (Diesel-Fired)	31.1	7.8			4.6	1.1	5.4	1.4	1.3	0.3	1.0	0.3	1.0	0.3
2	Internal Combustion/Emergency Generator (Diesel-Fired)	31.1	7.8			4.6	1.1	5.4	1.4	1.3	0.3	1.0	0.3	1.0	0.3
3	Boiler (Natural	1.46 <sup>(1)</sup>	6.38(1)			0.77 <sup>(1)</sup>	3.37 <sup>(1)</sup>	0.050 <sup>(1)</sup>	0.22 <sup>(1)</sup>	0.52 <sup>(1)</sup>	2.28(1)	0.10 <sup>(1)</sup>	0.44 <sup>(1)</sup>	0.10 <sup>(1)</sup>	0.44 <sup>(1)</sup>
J	Gas/Diesel-Fired)	3.06 <sup>(2)</sup>	0.073(2)			0.77 <sup>(2)</sup>	0.0.19 <sup>(2)</sup>	1.07 <sup>(2)</sup>	0.026 <sup>(2)</sup>	0.80 <sup>(2)</sup>	0.019(2)	0.30(2)	0.0072 <sup>(2)</sup>	0.30 <sup>(2)</sup>	0.0072 <sup>(2)</sup>
4 Boiler (Natural Gas/Diesel-Fired)	Boiler (Natural	1.46 <sup>(1)</sup>	6.38(1)			0.77 <sup>(1)</sup>	3.37 <sup>(1)</sup>	0.050 <sup>(1)</sup>	0.22 <sup>(1)</sup>	0.52(1)	2.28(1)	0.10 <sup>(1)</sup>	0.44 <sup>(1)</sup>	0.10 <sup>(1)</sup>	0.44 <sup>(1)</sup>
	Gas/Diesel-Fired)	3.06 <sup>(2)</sup>	0.073(2)			0.77 <sup>(2)</sup>	0.0.19 <sup>(2)</sup>	1.07 <sup>(2)</sup>	0.026 <sup>(2)</sup>	0.80 <sup>(2)</sup>	0.019(2)	0.30(2)	0.0072 <sup>(2)</sup>	0.30 <sup>(2)</sup>	0.0072 <sup>(2)</sup>
5	Boiler (Natural Gas- Fired)	1.0	4.4			0.9	3.7	0.01	0.03	0.06	0.2	0.08	0.34	0.08	0.34
6	Boiler (Natural	1.06 <sup>(1)</sup>	4.60 <sup>(1)</sup>			2.1(1)	9.3(1)	0.02 <sup>(1)</sup>	0.07 <sup>(1)</sup>	0.1(1)	0.6 <sup>(1)</sup>	0.2(1)	0.8(1)	0.2(1)	0.8(1)
0	Gas/Diesel-Fired)	3.0(2)	0.8(2)			0.8(2)	0.2(2)	1.1 <sup>(2)</sup>	0.3(2)	0.05(2)	0.01 <sup>(2)</sup>	0.3(2)	0.08(2)	0.3(2)	0.08(2)
7	Internal Combustion/Emergency Generator (Diesel-Fired)	29.53	7.38	31.08	7.77	16.83	4.21	3.56	0.89	1.55	0.39	0.97	0.24	0.97	0.24
8	Internal Combustion/Electric and Steam Generator (Natural Gas-Fired)	6.09	26.68			49.34	216.1	0.038	0.17	3.25	14.2	0.16	0.71	0.16	0.71
	Total	<b>102.8</b> <sup>(1)</sup>	72 27			<b>79.92</b> <sup>(1)</sup>	242 5	<b>14.53</b> <sup>(1)</sup>	4 74	<b>8.61</b> <sup>(1)</sup>	20.62	3.61 <sup>(1)</sup>	3.66	<b>3.61</b> <sup>(1)</sup>	3.66
	10(8)	<b>107.9</b> <sup>(2)</sup>	12.31			78.62 <sup>(2)</sup>	242.3	<b>17.65</b> <sup>(2)</sup>	4./4	<b>9.10</b> <sup>(2)</sup>	20.02	<b>4.11</b> <sup>(2)</sup>	3.00	<b>4.11</b> <sup>(2)</sup>	3.00

Table B-1 Summary of Uncontrolled NOx, CO, SO2, and PM Emission Rates

(1) Pound per hour and ton per year when unit is operating with natural gas only

(2) Pound per hour and ton per year when unit is operating with diesel fuel for emergency, maintenance, and testing purposes only

Correct information received 03/07/2022 cgmd

	Allowable Emission Totals														
	Description	NO	) <sub>X</sub>	NO <sub>X</sub> +	NMHC	C	0	SC	$\mathbf{D}_2$	V	OC	P	M <sub>10</sub>	PN	M <sub>2.5</sub>
Unit #	Description	lbs/hr	tons/yr	lbs/hr	tons/yr	lbs/hr	tons/yr	lbs/hr	tons/yr	lbs/hr	lbs/hr	lbs/hr	tons/yr	lbs/hr	tons/yr
1	Internal Combustion/Emergency Generator (Diesel-Fired)	31.1	7.8			4.6	1.1	5.4	1.4	1.3	0.3	1.0	0.3	1.0	0.3
2	Internal Combustion/Emergency Generator (Diesel-Fired)	31.1	7.8			4.6	1.1	5.4	1.4	1.3	0.3	1.0	0.3	1.0	0.3
3	Boiler (Natural	1.46 <sup>(1)</sup>	6.38 <sup>(1)</sup>			0.77 <sup>(1)</sup>	3.37 <sup>(1)</sup>	0.050 <sup>(1)</sup>	0.22 <sup>(1)</sup>	0.52 <sup>(1)</sup>	2.28 <sup>(1)</sup>	0.10 <sup>(1)</sup>	0.44 <sup>(1)</sup>	0.10 <sup>(1)</sup>	0.44 <sup>(1)</sup>
5	Gas/Diesel-Fired)	3.06 <sup>(2)</sup>	0.073(2)			0.77 <sup>(2)</sup>	0.019(2)	1.07 <sup>(2)</sup>	0.026 <sup>(2)</sup>	0.80 <sup>(2)</sup>	0.019(2)	0.30 <sup>(2)</sup>	0.0072 <sup>(2)</sup>	0.30 <sup>(2)</sup>	0.0072 <sup>(2)</sup>
4	Boiler (Natural	1.46 <sup>(1)</sup>	6.38(1)			0.77 <sup>(1)</sup>	3.37 <sup>(1)</sup>	0.050 <sup>(1)</sup>	0.22 <sup>(1)</sup>	0.52(1)	2.28(1)	0.10 <sup>(1)</sup>	0.44 <sup>(1)</sup>	0.10 <sup>(1)</sup>	0.44 <sup>(1)</sup>
4	Gas/Diesel-Fired)	3.06 <sup>(2)</sup>	0.073(2)			0.77 <sup>(2)</sup>	0.019(2)	1.07 <sup>(2)</sup>	0.026 <sup>(2)</sup>	0.80 <sup>(2)</sup>	0.019(2)	0.30 <sup>(2)</sup>	0.0072 <sup>(2)</sup>	0.30 <sup>(2)</sup>	0.0072 <sup>(2)</sup>
5	Boiler (Natural Gas- Fired)	1.0	4.4			0.9	3.7	0.01	0.03	0.06	0.2	0.08	0.34	0.08	0.34
6	Boiler (Natural	1.06 <sup>(1)</sup>	4.60 <sup>(1)</sup>			2.1(1)	9.3(1)	0.02 <sup>(1)</sup>	0.07 <sup>(1)</sup>	0.1(1)	0.6 <sup>(1)</sup>	0.2(1)	0.8(1)	0.2(1)	0.8(1)
0	Gas/Diesel-Fired)	3.0(2)	0.8(2)			0.8(2)	0.2(2)	1.1 <sup>(2)</sup>	0.3(2)	0.05(2)	0.01 <sup>(2)</sup>	0.3(2)	0.08(2)	0.3(2)	0.08(2)
7	Internal Combustion/Emergency Generator (Diesel-Fired)	29.53	7.38	31.08	7.77	16.83	4.21	3.56	0.89	1.55	0.39	0.97	0.24	0.97	0.24
8	Internal Combustion/Electric and Steam Generator (Natural Gas-Fired)	6.09	26.68			9.87	43.22	0.038	0.17	1.95	8.54	0.16	0.71	0.16	0.71
	$T_{242}(3)$	<b>101.8</b> <sup>(1)</sup>	(7.07			<b>39.67</b> <sup>(1)</sup>	(( ))	<b>14.52</b> <sup>(1)</sup>	4.71	<b>7.25</b> <sup>(1)</sup>	14 53	<b>3.53</b> <sup>(1)</sup>		<b>3.53</b> <sup>(1)</sup>	2.22
	1 otal <sup>(e)</sup>	<b>106.9</b> <sup>2)</sup>	67.97			<b>38.37</b> <sup>(2)</sup>	00.22	<b>17.64</b> <sup>(2)</sup>	4.71	<b>7.74</b> <sup>(2)</sup>	14.73	<b>4.03</b> <sup>(2)</sup>	3.32	<b>4.03</b> <sup>(2)</sup>	<u>3.32</u>

(1) Pound per hour and ton per year when unit is operating with natural gas only

(2) Pound per hour and ton per year when unit is operating with diesel fuel for emergency, maintenance, and testing purposes only

(3) Total is sum of the maximum emission of 3 of the 4 boilers operating at any one time as proposed in the permit application.

cgmd

# **Estimates for Federal Hazardous Air Pollutants (HAPs)**

The combustion Units 1 - 8, are sources of HAPs as it appears in Section 112 (b) of the 1990 CAA. Emissions of HAPs were determined with all boiler sources combusting natural gas. Emergency dieselfired generator/engine (Units 1, 2, and 7) used AP-42 Section 3.3 and 1.3 HAP emission factors. Steam boilers combusting natural gas (Units 3, 4, 5, and 6) used AP-42 Section 1.4 HAP emission factors. CoGen system combusting natural gas (Unit 8) used AP-42 Section 3.2 HAP emission factors.

The following tables summarize the HAPs emission rates from the Units 1 - 8. Total combined HAPs emissions from the PHS Energy Center is 1.95 pounds per hour or 7.06 tons per year. Total combined HAPs emissions from the PHS Energy Center with only 3 of the 4 boilers operating at a time is 1.94 pounds per hour or 6.99 tons per year.

## Table B-3: HAPs Emission Rates from the Unit 1 (Emergency Generator)

#### **EPA HAPS Emissions Diesel Fired Engines**

Horsepower Rating: Fuel Usage: MMBtu/hr: Btu x 10 <sup>^</sup> -12/hr: Yearly Operating Hours:		2,636 131.8 16.8704 1.68704E-05 500	horsepower gallons/hr Btu Btu x10^-12 hours per year	(based on 128000 Btu/gallon) (based on 128000 Btu/gallon)		
Type of Fuel:	Diesel	22 and Section 1	2			
Emission Factors	AP-42 Section	1 5.5 and Section 1				
Non-PAH HAPS	CAS#			Emission Factor (lbs/mmBtu)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Acetalehyde	75-07-0			7.67E-04	0.012940	0.003235
Acrolein	107-02-8			9.25E-05	0.001561	0.000390
Benzene	71-43-2			9.33E-04	0.015740	0.003935
1 3-Butadiene	106-99-0			3.91E-05	0.000660	0.0000165
Formaldehyde	50-00-0			1 18E-03	0.019907	0.000103
Pronvlene	115-07-1			2 58E-03	0.043526	0.010881
Toluene	108-88-3			2.50E 05 4 09E-04	0.006900	0.001725
Xvlene	1330-20-7			2.85E-04	0.004808	0.001723
ryione	1550 20 7	То	tal Non-PAH HAPS	6 29E-03	0.106041	0.026510
PAH HAPS	CAS#			Emission Factor (lbs/mmBtu)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Accornethers	92 2 <b>2</b> 0			1 42E 06	0.000024	0.000006
Acenaphthelena	03-32-9 200 06 0			1.42E-00	0.000024	0.000000
Acenaphinylene	208-90-8			J.00E-00	0.000083	0.000021
Anumacene Denzo(a)enthrocene	120-12-7 56 55 2			1.67E-00	0.000032	0.000008
Benzo(a)anunacene	50 32 8			1.08E-00	0.000028	0.000007
Benzo(b)fluoranthana	205 00 2			0.01E.08	0.000003	0.000001
Benzo(0)nuorantiene	203-99-2			9.91E-08	0.000002	0.000000
Benzo(a h Dnervlene	192-97-2			1.55E-07	0.000003	0.000001
Benzo(k)fluoranthene	207.08.9			4.89E-07	0.000003	0.000002
Dibenz(a h)anthracene	207-08-9			5.83E-07	0.000003	0.000001
Chrysene	218 01 0			3.53E-07	0.000010	0.000002
Eluoranthene	206.44.0			5.55E-07	0.000000	0.000001
Fluorene	200-44-0 86-73-7			7.01E-00 2.92E-05	0.000128	0.000032
Indeno(1 2 3.cd)nyrene	193_39_5			2.72E-05	0.000495	0.000123
Nanhthalene	91_20_3			8 48F-05	0.001/131	0.000002
Phenanthrene	85-01 8			2 9/F 05	0.001431	0.000338
Pyrene	129_00_0			2.74E-05 4 78E-06	0.000490	0.000124
			Total PAH HAPS	1.68E-04	0.002838	0.000709

HAPS Metals		Emission Factor (lbs/Btu^12)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Arsenic		4	0.000067	0.000017
Beryllium		3	0.000051	0.000013
Cadmium		3	0.000051	0.000013
Chromium		3	0.000051	0.000013
Lead		9	0.000152	0.000038
Manganese		6	0.000101	0.000025
Mercury		3	0.000051	0.000013
Nickel		3	0.000051	0.000013
Selenium		15	0.000253	0.000063
	Total Metals HAPS	49	0.000827	0.000207
	Total HAPS		0.10971	0.00212

## Table B-4: HAPs Emission Rates from the Unit 2 (Emergency Generator)

#### **EPA HAPS Emissions Diesel Fired Engines**

Horsepower Rating: Fuel Usage: MMBtu/hr: Btu x 10^-12/hr: Yearly Operating Hours:		2628 131.4 16.8192 1.68192E-05 500	horsepower gallons/hr Btu Btu x10^-12 hours per year	(based on 1280) (based on 1280)	00 Btu/gallon) 00 Btu/gallon)	
Type of Fuel:	Diesel					
Emission Factors	AP-42 Section	1 3.3 and Section 1	1.3			
Non-PAH HAPS	CAS#			Emission Factor (lbs/mmBtu)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Acetalehyde	75-07-0			7.67E-04	0.012900	0.003225
Acrolein	107-02-8			9.25E-05	0.001556	0.000389
Benzene	71-43-2			9.33E-04	0.015692	0.003923
1.3-Butadiene	106-99-0			3.91E-05	0.000658	0.000164
Formaldehvde	50-00-0			1.18E-03	0.019847	0.004962
Propylene	115-07-1			2.58E-03	0.043394	0.010848
Toluene	108-88-3			4.09E-04	0.006879	0.001720
Xvlene	1330-20-7			2.85E-04	0.004793	0.001198
-		То	tal Non-PAH HAPS	6.29E-03	0.105719	0.026430
				Emission	Emission	Emission
PAH HAPS	CAS#			Factor (lbs/mmBtu)	Rate (lbs/hr)	Rate (ton/yr)
Acenaphthene	83-32-9			1.42E-06	0.000024	0.000006
Acenaphthylene	208-96-8			5.06E-06	0.000085	0.000021
Anthracene	120-12-7			1.87E-06	0.000031	0.000008
Benzo(a)anthracene	56-55-3			1.68E-06	0.000028	0.000007
Benzo(a)pyrene	50-32-8			1.88E-07	0.000003	0.000001
Benzo(b)fluoranthene	205-99-2			9.91E-08	0.000002	0.000000
Benzo(a)pyrene	192-97-2			1.55E-07	0.000003	0.000001
Benzo(g,h,I)perylene	191-24-2			4.89E-07	0.000008	0.000002
Benzo(k)fluoranthene	207-08-9			1.55E-07	0.000003	0.000001
Dibenz(a,h)anthracene				5.83E-07	0.000010	0.000002
Chrysene	218-01-9			3.53E-07	0.000006	0.000001
Fluoranthene	206-44-0			7.61E-06	0.000128	0.000032
Fluorene	86-73-7			2.92E-05	0.000491	0.000123
Indeno(1,2,3-cd)pyrene	193-39-5			3.75E-07	0.000006	0.000002
Naphthalene	91-20-3			8.48E-05	0.001426	0.000357
Phenanthrene	85-01-8			2.94E-05	0.000494	0.000124
Pyrene	129-00-0			4.78E-06	0.000080	0.000020
			Total PAH HAPS	1.68E-04	0.002829	0.000707

HAPS Metals		Emission Factor (lbs/Btu^12)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Arsenic		4	0.000067	0.000017
Beryllium		3	0.000050	0.000013
Cadmium		3	0.000050	0.000013
Chromium		3	0.000050	0.000013
Lead		9	0.000151	0.000038
Manganese		6	0.000101	0.000025
Mercury		3	0.000050	0.000013
Nickel		3	0.000050	0.000013
Selenium		15	0.000252	0.000063
	Total Metals HAPS	49	0.000824	0.000206
	Total HAPS		0.10937	0.00211
## Table B-5: HAPs Emission Rates from the Unit 3 (Boiler)

## **EPA HAPS Emissions Natural Gas Boilers**

Btu Rating	20.9	mmBtu/hr	
Fuel Usage:	22000.0	scf/hr	(based on 950 Btu/scf)
MMscf/hr:	0.022	MMscf/hr	
Yearly Operating Hours:	8760	hours per ye	ear

Type of Fuel:	Natural Gas
Emission Factors	AP-42 Section 1.4

Organic Compounds	CAS#		Emission Factor (lbs/MM scf)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Benzene	71-43-2		2.10E-03	0.000046	0.000202
Formaldehyde	50-00-0		7.50E-02	0.001650	0.007227
Hexane	110-54-3		1.80E+00	0.039600	0.173448
Naphthalene	91-20-3		6.10E-04	0.000013	0.000059
Toluene	108-88-3		3.40E-03	0.000075	0.000328
		Total Organic Compounds	1.88E+00	0.041384	0.181264

		Emission Factor	Emission Rate	Emission Rate
HAPS Metals		(lbs/MM scf)	(lbs/hr)	(ton/yr)
Arsenic		2.00E-04	0.000004	0.000019
Beryllium		1.20E-05	0.000000	0.000001
Cadmium		1.10E-03	0.000024	0.000106
Chromium		1.40E-03	0.000031	0.000135
Cobalt		8.40E-05	0.000002	0.000008
Lead		5.00E-04	0.000011	0.000048
Manganese		3.80E-04	0.000008	0.000037
Mercury		2.60E-04	0.000006	0.000025
Nickel		2.10E-03	0.000046	0.000202
Selenium		2.40E-05	0.000001	0.000002
	Total Metals HAPS	6.06E-03	0.000133	0.000584
	<b>Total HAPS</b>		0.041518	0.181848

## Table B-6: HAPs Emission Rates from the Unit 4 (Boiler)

## **EPA HAPS Emissions Natural Gas Boilers**

Btu Rating	20.9	mmBtu/hr	
Fuel Usage:	22000.0	scf/hr	(based on 950 Btu/scf)
MMscf/hr:	0.022	MMscf/hr	
Yearly Operating Hours:	8760	hours per ye	ear

Type of Fuel:	Natural Gas
Emission Factors	AP-42 Section 1.4

Organic Compounds	CAS#		Emission Factor (lbs/MM scf)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Benzene	71-43-2		2.10E-03	0.000046	0.000202
Formaldehyde	50-00-0		7.50E-02	0.001650	0.007227
Hexane	110-54-3		1.80E+00	0.039600	0.173448
Naphthalene	91-20-3		6.10E-04	0.000013	0.000059
Toluene	108-88-3		3.40E-03	0.000075	0.000328
		Total Organic Compounds	1.88E+00	0.041384	0.181264

		Emission Factor	Emission Rate	Emission Rate
HAPS Metals		(lbs/MM scf)	(lbs/hr)	(ton/yr)
Arsenic		2.00E-04	0.000004	0.000019
Beryllium		1.20E-05	0.000000	0.000001
Cadmium		1.10E-03	0.000024	0.000106
Chromium		1.40E-03	0.000031	0.000135
Cobalt		8.40E-05	0.000002	0.000008
Lead		5.00E-04	0.000011	0.000048
Manganese		3.80E-04	0.000008	0.000037
Mercury		2.60E-04	0.000006	0.000025
Nickel		2.10E-03	0.000046	0.000202
Selenium		2.40E-05	0.000001	0.000002
	Total Metals HAPS	6.06E-03	0.000133	0.000584
	Total HAPS		0.041518	0.181848

## Table B-7: HAPs Emission Rates from the Unit 5 (Boiler)

## **EPA HAPS Emissions Natural Gas Boilers**

Btu Rating	8.4	mmBtu/hr				
Fuel Usage:	8842.1	scf/hr	(based on 950)	Btu/scf)		
MMscf/hr:	0.0088421	MMscf/hr				
Yearly Operating Hours:	8760	hours per ye	ar			
Type of Fuel:	Natural Gas					
Emission Factors	AP-42 Section	1.4				
Organic Compounds	CAS#			Emission Factor (lbs/MM scf)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Benzene	71-43-2			2.10E-03	0.000019	0.000081
Formaldehyde	50-00-0			7.50E-02	0.000663	0.002905
Hexane	110-54-3			1.80E+00	0.015916	0.069711
Naphthalene	91-20-3			6.10E-04	0.000005	0.000024
Toluene	108-88-3			3.40E-03	0.000030	0.000132
		Total Organ	ic Compounds	1.88E+00	0.016633	0.072852
HAPS Metals				Emission Factor (lbs/MM scf)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Arsenic				2.00E-04	0.000002	0.000008
Beryllium				1.20E-05	0.000000	0.000000
Cadmium				1.10E-03	0.000010	0.000043
Chromium				1.40E-03	0.000012	0.000054
Cobalt				8.40E-05	0.000001	0.000003
Lead				5.00E-04	0.000004	0.000019
Manganese				3.80E-04	0.000003	0.000015
Mercury				2.60E-04	0.000002	0.000010
Nickel				2.10E-03	0.000019	0.000081
Selenium				2.40E-05	0.000000	0.000001
		Total	Metals HAPS	6.06E-03	0.000054	0.000235

Total HAPS

0.016687 0.073087

## Table B-8: HAPs Emission Rates from the Unit 6 (Boiler)

## **EPA HAPS Emissions Natural Gas Boilers**

Btu Rating	21	mmBtu/hr				
Fuel Usage:	22105.3	scf/hr (bas	ed on 950	Btu/scf)		
MMscf/hr:	0.0221053	MMscf/hr		)		
Yearly Operating Hours:	8760	hours per year				
Type of Fuel:	Natural Gas					
Emission Factors	AP-42 Section	1.4				
Organic Compounds	CAS#			Emission Factor (lbs/MM scf)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Benzene	71-43-2			2.10E-03	0.000046	0.000203
Formaldehyde	50-00-0			7.50E-02	0.001658	0.007262
Hexane	110-54-3			1.80E+00	0.039789	0.174278
Naphthalene	91-20-3			6.10E-04	0.000013	0.000059
Toluene	108-88-3			3.40E-03	0.000075	0.000329
		Total Organic Co	mpounds	1.88E+00	0.041582	0.182131
HAPS Metals				Emission Factor (lbs/MM scf)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Arsenic				2.00E-04	0.000004	0.000019
Beryllium				1.20E-05	0.000000	0.000001
Cadmium				1.10E-03	0.000024	0.000107
Chromium				1.40E-03	0.000031	0.000136
Cobalt				8.40E-05	0.000002	0.000008
Lead				5.00E-04	0.000011	0.000048
Manganese				3.80E-04	0.000008	0.000037
Mercury				2.60E-04	0.000006	0.000025
Nickel				2.10E-03	0.000046	0.000203
Selenium				2.40E-05	0.000001	0.000002
		Total Meta	als HAPS	6.06E-03	0.000134	0.000587

Total HAPS

0.041716 0.182718

## Table B-9: HAPs Emission Rates from the Unit 7 (Emergency Generator)

## **EPA HAPS Emissions Diesel Fired Engines**

Horsepower Rating: Fuel Usage: MMBtu/hr: Btu x 10^-12/hr: Yearly Operating Hours:		2937 146.85 18.7968 1.87968E-05 500	horsepower gallons/hr Btu Btu x10^-12 hours per year	(based on 1280) (based on 1280)	00 Btu/gallon) 00 Btu/gallon)	
		500	nouis per year			
Type of Fuel: Emission Factors	Diesel AP-42 Section	3.3 and Section 1	.3			
Non-PAH HAPS	CAS#			Emission Factor (lbs/mmBtu)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Acetalehyde	75-07-0			7.67E-04	0.014417	0.003604
Acrolein	107-02-8			9.25E-05	0.001739	0.000435
Benzene	71-43-2			9.33E-04	0.017537	0.004384
1.3-Butadiene	106-99-0			3.91E-05	0.000735	0.000184
Formaldehvde	50-00-0			1.18E-03	0.022180	0.005545
Propylene	115-07-1			2.58E-03	0.048496	0.012124
Toluene	108-88-3			4.09E-04	0.007688	0.001922
Xvlene	1330-20-7			2.85E-04	0.005357	0.001339
<b>y</b> • •		То	tal Non-PAH HAPS	6.29E-03	0.118149	0.029537
				Emission	Emission	Emission
PAH HAPS	CAS#			Factor (lbs/mmBtu)	Rate (lbs/hr)	Rate (ton/yr)
Acenaphthene	83-32-9			1.42E-06	0.000027	0.000007
Acenaphthylene	208-96-8			5.06E-06	0.000095	0.000024
Anthracene	120-12-7			1.87E-06	0.000035	0.000009
Benzo(a)anthracene	56-55-3			1.68E-06	0.000032	0.000008
Benzo(a)pyrene	50-32-8			1.88E-07	0.000004	0.000001
Benzo(b)fluoranthene	205-99-2			9.91E-08	0.000002	0.000000
Benzo(a)pyrene	192-97-2			1.55E-07	0.000003	0.000001
Benzo(g,h,I)perylene	191-24-2			4.89E-07	0.000009	0.000002
Benzo(k)fluoranthene	207-08-9			1.55E-07	0.000003	0.000001
Dibenz(a,h)anthracene				5.83E-07	0.000011	0.000003
Chrysene	218-01-9			3.53E-07	0.000007	0.000002
Fluoranthene	206-44-0			7.61E-06	0.000143	0.000036
Fluorene	86-73-7			2.92E-05	0.000549	0.000137
Indeno(1,2,3-cd)pyrene	193-39-5			3.75E-07	0.000007	0.000002
Naphthalene	91-20-3			8.48E-05	0.001594	0.000398
Phenanthrene	85-01-8			2.94E-05	0.000553	0.000138
Pyrene	129-00-0			4.78E-06	0.000090	0.000022
			Total PAH HAPS	1.68E-04	0.003162	0.000790

HAPS Metals		Emission Factor (lbs/Btu^12)	Emission Rate (lbs/hr)	Emission Rate (ton/yr)
Arsenic		4	0.000075	0.000019
Beryllium		3	0.000056	0.000014
Cadmium		3	0.000056	0.000014
Chromium		3	0.000056	0.000014
Lead		9	0.000169	0.000042
Manganese		6	0.000113	0.000028
Mercury		3	0.000056	0.000014
Nickel		3	0.000056	0.000014
Selenium		15	0.000282	0.000070
	Total Organic Compounds	49	0.000921	0.000230
	Total HAPS		0.12223	0.00236

## Table B-10: HAPs Emission Rates from the Unit 8 (CoGen)

# EPA HAPS Natural Gas-fired Reciprocating Engines

Brake HP	2763	BHP			
Btu Rating	5843	Btu/bhp-hr			
Fuel Usage:	16144209.0	Btu/hr			
MMscf/hr:	16.144209	MMBtu/hr			
Yearly Operating Hours:	8760	hours per year			
Type of Fuel:	Natural Gas				
Emission Factors	AP-42 Section	3.2			
			Emission	Emission	Emission
			Factor	Rate	Rate
<b>Organic Compounds</b>	CAS#		(lbs/MMBtu)	(lbs/hr)	(ton/yr)
1,1,2,2-Tetrachloroethane	71-55-6		4.00E-05	0.000646	0.002828
1,1,2-Trichloroethane	79-00-5		3.18E-05	0.000513	0.002249
1,3-Butadiene	106-99-0		2.67E-04	0.004311	0.018880
1,3-Dichloropropene	78-87-5		2.64E-05	0.000426	0.001867
2-Methylnaphthalene	91-57-6		3.32E-05	0.000536	0.002348
2,2,4-Trimethylpentane	540-84-1		2.50E-04	0.004036	0.017678
Acenaphthene	83-32-9		1.25E-06	0.000020	0.000088
Acenaphthylene	208-96-8		5.53E-06	0.000089	0.000391
Acetaldehyde	75-07-0		8.36E-03	0.134966	0.591149
Acrolein	107-02-8		5.14E-03	0.082981	0.363458
Benzene	71-43-2		4.40E-04	0.007103	0.031113
Benzo(b)fluoranthene	205-99-2		1.66E-07	0.000003	0.000012
Benzo(e)pyrene	192-97-2		4.15E-07	0.000007	0.000029
Benzo(g,h,i)pervlene	191-24-2		4.14E-07	0.000007	0.000029
Biphenyl	92-52-4		2.12E-04	0.003423	0.014991
Carbon Tetrachloride	56-23-5		3.67E-05	0.000592	0.002595
Chlorobenzene	108-90-7		3.04E-05	0.000491	0.002150
Chloroform	67-66-3		2.85E-05	0.000460	0.002015
Chrysene	218-01-9		6.93E-07	0.000011	0.000049
Ethylbenzene	100-41-4		3.97E-05	0.000641	0.002807
Ethylene Dibromide	106-93-4		4.43E-05	0.000715	0.003133
Fluoranthene	206-44-0		1.11E-06	0.000018	0.000078
Fluorene	86-73-7		5.67E-06	0.000092	0.000401
Formaldehyde	50-00-0	Controlled CAT Emission Data		1.157340	5.069150
Methanol	67-56-1		2.50E-03	0.040361	0.176779
Methylene Chloride	75-09-2		2.00E-05	0.000323	0.001414
n-Hexane	110-54-3		1.11E-03	0.017920	0.078490
Naphthalene	91-20-3		7.44E-05	0.001201	0.005261
PAH			2.69E-05	0.000434	0.001902
Phenanthrene	85-01-8		1.04E-05	0.000168	0.000735
Phenol	108-95-2		2.40E-05	0.000387	0.001697
Pyrene	129-00-0		1.36E-06	0.000022	0.000096
Styrene	100-42-5		2.36E-05	0.000381	0.001669
Tetrachloroethane	79-34-5		2.48E-06	0.000040	0.000175
Toluene	108-88-3		4.08E-04	0.006587	0.028850
Vinyl Chloride	75-01-4		1.49E-05	0.000241	0.001054
Xylene	1330-20-7		1.84E-04	0.002971	0.013011
		Total Organic Compounds	7.18E-05	1.470462	6.440623
		Total HAPS		1.470462	6.440623

Attachment C Emission Calculations Supporting Documents AP-42 Section 1.3

## 1.3 Fuel Oil Combustion

## 1.3.1 General<sup>1-3</sup>

Two major categories of fuel oil are burned by combustion sources: distillate oils and residual oils. These oils are further distinguished by grade numbers, with Nos. 1 and 2 being distillate oils; Nos. 5 and 6 being residual oils; and No. 4 being either distillate oil or a mixture of distillate and residual oils. No. 6 fuel oil is sometimes referred to as Bunker C. Distillate oils are more volatile and less viscous than residual oils. They have negligible nitrogen and ash contents and usually contain less than 0.3 percent sulfur (by weight). Distillate oils are used mainly in domestic and small commercial applications, and include kerosene and diesel fuels. Being more viscous and less volatile than distillate proper atomization. Because residual oils are produced from the residue remaining after the lighter fractions (gasoline, kerosene, and distillate oils) have been removed from the crude oil, they contain significant quantities of ash, nitrogen, and sulfur. Residual oils are used mainly in utility, industrial, and large commercial applications.

## 1.3.2 Firing Practices<sup>4</sup>

The major boiler configurations for fuel oil-fired combustors are watertube, firetube, cast iron, and tubeless design. Boilers are classified according to design and orientation of heat transfer surfaces, burner configuration, and size. These factors can all strongly influence emissions as well as the potential for controlling emissions.

Watertube boilers are used in a variety of applications ranging from supplying large amounts of process steam to providing space heat for industrial facilities. In a watertube boiler, combustion heat is transferred to water flowing through tubes which line the furnace walls and boiler passes. The tube surfaces in the furnace (which houses the burner flame) absorb heat primarily by radiation from the flames. The tube surfaces in the boiler passes (adjacent to the primary furnace) absorb heat primarily by convective heat transfer.

Firetube boilers are used primarily for heating systems, industrial process steam generators, and portable power boilers. In firetube boilers, the hot combustion gases flow through the tubes while the water being heated circulates outside of the tubes. At high pressures and when subjected to large variations in steam demand, firetube units are more susceptible to structural failure than watertube boilers. This is because the high-pressure steam in firetube units is contained by the boiler walls rather than by multiple small-diameter watertubes, which are inherently stronger. As a consequence, firetube boilers are typically small and are used primarily where boiler loads are relatively constant. Nearly all firetube boilers are sold as packaged units because of their relatively small size.

A cast iron boiler is one in which combustion gases rise through a vertical heat exchanger and out through an exhaust duct. Water in the heat exchanger tubes is heated as it moves upward through the tubes. Cast iron boilers produce low pressure steam or hot water, and generally burn oil or natural gas. They are used primarily in the residential and commercial sectors.

Another type of heat transfer configuration used on smaller boilers is the tubeless design. This design incorporates nested pressure vessels with water in between the shells. Combustion gases are fired into the inner pressure vessel and are then sometimes recirculated outside the second vessel.

Organic Compound	Average Emission Factor <sup>b</sup> (lb/10 <sup>3</sup> Gal)	EMISSION FACTOR RATING
Benzene	2.14E-04	С
Ethylbenzene	6.36E-05 <sup>c</sup>	Е
Formaldehyde <sup>d</sup>	3.30E-02	С
Naphthalene	1.13E-03	С
1,1,1-Trichloroethane	2.36E-04 <sup>c</sup>	Е
Toluene	6.20E-03	D
o-Xylene	1.09E-04 <sup>c</sup>	Е
Acenaphthene	2.11E-05	С
Acenaphthylene	2.53E-07	D
Anthracene	1.22E-06	С
Benz(a)anthracene	4.01E-06	С
Benzo(b,k)fluoranthene	1.48E-06	С
Benzo(g,h,i)perylene	2.26E-06	С
Chrysene	2.38E-06	С
Dibenzo(a,h) anthracene	1.67E-06	D
Fluoranthene	4.84E-06	С
Fluorene	4.47E-06	С
Indo(1,2,3-cd)pyrene	2.14E-06	С
Phenanthrene	1.05E-05	С
Pyrene	4.25E-06	С
OCDD	3.10E-09 <sup>c</sup>	Е

## Table 1.3-9. EMISSION FACTORS FOR SPECIATED ORGANIC COMPOUNDS FROM FUEL OIL COMBUSTION<sup>a</sup>

<sup>a</sup> Data are for residual oil fired boilers, Source Classification Codes (SCCs) 1-01-004-01/04.
 <sup>b</sup> References 64-72. To convert from lb/10<sup>3</sup> gal to kg/10<sup>3</sup> L, multiply by 0.12.
 <sup>c</sup> Based on data from one source test (Reference 67).

<sup>d</sup> The formaldehyde number presented here is based only on data from utilities using No. 6 oil. The number presented in Table 1.3-7 is based on utility, commercial, and industrial boilers.

# Table 1.3-10. EMISSION FACTORS FOR TRACE ELEMENTS FROM DISTILLATEFUEL OIL COMBUSTION SOURCES<sup>a</sup>

## EMISSION FACTOR RATING: E

Firing Configuration					Emission	Factor (1	$b/10^{12}$ Btu)	)			
(SCC)	As	Be	Cd	Cr	Cu	Pb	Hg	Mn	Ni	Se	Zn
Distillate oil fired (1-01-005-01, 1-02-005-01, 1-03-005-01)	4	3	3	3	6	9	3	6	3	15	4

<sup>a</sup> Data are for distillate oil fired boilers, SCC codes 1-01-005-01, 1-02-005-01, and 1-03-005-01. References 29-32, 40-44 and 83. To convert from lb/10<sup>12</sup> Btu to pg/J, multiply by 0.43.

Metal	Average Emission Factor <sup>b, d</sup> (lb/10 <sup>3</sup> Gal)	EMISSION FACTOR RATING
Antimony	5.25E-03 <sup>c</sup>	E
Arsenic	1.32E-03	С
Barium	2.57E-03	D
Beryllium	2.78E-05	С
Cadmium	3.98E-04	С
Chloride	3.47E-01	D
Chromium	8.45E-04	С
Chromium VI	2.48E-04	С
Cobalt	6.02E-03	D
Copper	1.76E-03	С
Fluoride	3.73E-02	D
Lead	1.51E-03	С
Manganese	3.00E-03	С
Mercury	1.13E-04	С
Molybdenum	7.87E-04	D
Nickel	8.45E-02	С
Phosphorous	9.46E-03	D
Selenium	6.83E-04	С
Vanadium	3.18E-02	D
Zinc	2.91E-02	D

# Table 1.3-11. EMISSION FACTORS FOR METALS FROM UNCONTROLLED NO. 6FUEL OIL COMBUSTION<sup>a</sup>

<sup>a</sup> Data are for residual oil fired boilers, Source Classification Codes (SCCs) 1-01-004-01/04.

<sup>b</sup> References 64-72. 18 of 19 sources were uncontrolled and 1 source was controlled with low efficiency ESP. To convert from lb/10<sup>3</sup> gal to kg/10<sup>3</sup> L, multiply by 0.12.

<sup>c</sup> References 29-32,40-44.

<sup>d</sup> For oil/water mixture, reduce factors in proportion to water content of the fuel (due to dilution). To adjust the listed values for water content, multiply the listed value by 1-decimal fraction of water (ex: For fuel with 9 percent water by volume, multiply by 1-0.9=.91).

AP-42 Section 1.4

## 1.4 Natural Gas Combustion

### 1.4.1 General<sup>1-2</sup>

Natural gas is one of the major combustion fuels used throughout the country. It is mainly used to generate industrial and utility electric power, produce industrial process steam and heat, and heat residential and commercial space. Natural gas consists of a high percentage of methane (generally above 85 percent) and varying amounts of ethane, propane, butane, and inerts (typically nitrogen, carbon dioxide, and helium). The average gross heating value of natural gas is approximately 1,020 British thermal units per standard cubic foot (Btu/scf), usually varying from 950 to 1,050 Btu/scf.

## 1.4.2 Firing Practices<sup>3-5</sup>

There are three major types of boilers used for natural gas combustion in commercial, industrial, and utility applications: watertube, firetube, and cast iron. Watertube boilers are designed to pass water through the inside of heat transfer tubes while the outside of the tubes is heated by direct contact with the hot combustion gases and through radiant heat transfer. The watertube design is the most common in utility and large industrial boilers. Watertube boilers are used for a variety of applications, ranging from providing large amounts of process steam, to providing hot water or steam for space heating, to generating high-temperature, high-pressure steam for producing electricity. Furthermore, watertube boilers can be distinguished either as field erected units or packaged units.

Field erected boilers are boilers that are constructed on site and comprise the larger sized watertube boilers. Generally, boilers with heat input levels greater than 100 MMBtu/hr, are field erected. Field erected units usually have multiple burners and, given the customized nature of their construction, also have greater operational flexibility and  $NO_x$  control options. Field erected units can also be further categorized as wall-fired or tangential-fired. Wall-fired units are characterized by multiple individual burners located on a single wall or on opposing walls of the furnace while tangential units have several rows of air and fuel nozzles located in each of the four corners of the boiler.

Package units are constructed off-site and shipped to the location where they are needed. While the heat input levels of packaged units may range up to 250 MMBtu/hr, the physical size of these units are constrained by shipping considerations and generally have heat input levels less than 100 MMBtu/hr. Packaged units are always wall-fired units with one or more individual burners. Given the size limitations imposed on packaged boilers, they have limited operational flexibility and cannot feasibly incorporate some  $NO_x$  control options.

Firetube boilers are designed such that the hot combustion gases flow through tubes, which heat the water circulating outside of the tubes. These boilers are used primarily for space heating systems, industrial process steam, and portable power boilers. Firetube boilers are almost exclusively packaged units. The two major types of firetube units are Scotch Marine boilers and the older firebox boilers. In cast iron boilers, as in firetube boilers, the hot gases are contained inside the tubes and the water being heated circulates outside the tubes. However, the units are constructed of cast iron rather than steel. Virtually all cast iron boilers are constructed as package boilers. These boilers are used to produce either low-pressure steam or hot water, and are most commonly used in small commercial applications.

Natural gas is also combusted in residential boilers and furnaces. Residential boilers and furnaces generally resemble firetube boilers with flue gas traveling through several channels or tubes with water or air circulated outside the channels or tubes.

## 1.4.3 Emissions<sup>3-4</sup>

The emissions from natural gas-fired boilers and furnaces include nitrogen oxides  $(NO_x)$ , carbon monoxide (CO), and carbon dioxide  $(CO_2)$ , methane  $(CH_4)$ , nitrous oxide  $(N_2O)$ , volatile organic compounds (VOCs), trace amounts of sulfur dioxide  $(SO_2)$ , and particulate matter (PM).

### Nitrogen Oxides -

Nitrogen oxides formation occurs by three fundamentally different mechanisms. The principal mechanism of  $NO_x$  formation in natural gas combustion is thermal  $NO_x$ . The thermal  $NO_x$  mechanism occurs through the thermal dissociation and subsequent reaction of nitrogen ( $N_2$ ) and oxygen ( $O_2$ ) molecules in the combustion air. Most  $NO_x$  formed through the thermal  $NO_x$  mechanism occurs in the high temperature flame zone near the burners. The formation of thermal  $NO_x$  is affected by three furnace-zone factors: (1) oxygen concentration, (2) peak temperature, and (3) time of exposure at peak temperature. As these three factors increase,  $NO_x$  emission levels increase. The emission trends due to changes in these factors are fairly consistent for all types of natural gas-fired boilers and furnaces. Emission levels vary considerably with the type and size of combustor and with operating conditions (e.g., combustion air temperature, volumetric heat release rate, load, and excess oxygen level).

The second mechanism of  $NO_x$  formation, called prompt  $NO_x$ , occurs through early reactions of nitrogen molecules in the combustion air and hydrocarbon radicals from the fuel. Prompt  $NO_x$  reactions occur within the flame and are usually negligible when compared to the amount of  $NO_x$  formed through the thermal  $NO_x$  mechanism. However, prompt  $NO_x$  levels may become significant with ultra-low- $NO_x$  burners.

The third mechanism of  $NO_x$  formation, called fuel  $NO_x$ , stems from the evolution and reaction of fuel-bound nitrogen compounds with oxygen. Due to the characteristically low fuel nitrogen content of natural gas,  $NO_x$  formation through the fuel  $NO_x$  mechanism is insignificant.

## Carbon Monoxide -

The rate of CO emissions from boilers depends on the efficiency of natural gas combustion. Improperly tuned boilers and boilers operating at off-design levels decrease combustion efficiency resulting in increased CO emissions. In some cases, the addition of  $NO_x$  control systems such as low  $NO_x$  burners and flue gas recirculation (FGR) may also reduce combustion efficiency, resulting in higher CO emissions relative to uncontrolled boilers.

## Volatile Organic Compounds -

The rate of VOC emissions from boilers and furnaces also depends on combustion efficiency. VOC emissions are minimized by combustion practices that promote high combustion temperatures, long residence times at those temperatures, and turbulent mixing of fuel and combustion air. Trace amounts of VOC species in the natural gas fuel (e.g., formaldehyde and benzene) may also contribute to VOC emissions if they are not completely combusted in the boiler.

### Sulfur Oxides -

Emissions of  $SO_2$  from natural gas-fired boilers are low because pipeline quality natural gas typically has sulfur levels of 2,000 grains per million cubic feet. However, sulfur-containing odorants are added to natural gas for detecting leaks, leading to small amounts of  $SO_2$  emissions. Boilers combusting unprocessed natural gas may have higher  $SO_2$  emissions due to higher levels of sulfur in the natural gas. For these units, a sulfur mass balance should be used to determine  $SO_2$  emissions.

## Particulate Matter -

Because natural gas is a gaseous fuel, filterable PM emissions are typically low. Particulate matter from natural gas combustion has been estimated to be less than 1 micrometer in size and has filterable and condensable fractions. Particulate matter in natural gas combustion are usually larger molecular weight hydrocarbons that are not fully combusted. Increased PM emissions may result from poor air/fuel mixing or maintenance problems.

## Greenhouse Gases -6-9

 $CO_2$ ,  $CH_4$ , and  $N_2O$  emissions are all produced during natural gas combustion. In properly tuned boilers, nearly all of the fuel carbon (99.9 percent) in natural gas is converted to  $CO_2$  during the combustion process. This conversion is relatively independent of boiler or combustor type. Fuel carbon not converted to  $CO_2$  results in  $CH_4$ , CO, and/or VOC emissions and is due to incomplete combustion. Even in boilers operating with poor combustion efficiency, the amount of  $CH_4$ , CO, and VOC produced is insignificant compared to  $CO_2$  levels.

Formation of  $N_2O$  during the combustion process is affected by two furnace-zone factors.  $N_2O$  emissions are minimized when combustion temperatures are kept high (above 1475°F) and excess oxygen is kept to a minimum (less than 1 percent).

Methane emissions are highest during low-temperature combustion or incomplete combustion, such as the start-up or shut-down cycle for boilers. Typically, conditions that favor formation of  $N_2O$  also favor emissions of methane.

### 1.4.4 Controls<sup>4,10</sup>

## NO<sub>x</sub> Controls -

Currently, the two most prevalent combustion control techniques used to reduce  $NO_x$  emissions from natural gas-fired boilers are flue gas recirculation (FGR) and low  $NO_x$  burners. In an FGR system, a portion of the flue gas is recycled from the stack to the burner windbox. Upon entering the windbox, the recirculated gas is mixed with combustion air prior to being fed to the burner. The recycled flue gas consists of combustion products which act as inerts during combustion of the fuel/air mixture. The FGR system reduces  $NO_x$  emissions by two mechanisms. Primarily, the recirculated gas acts as a dilutent to reduce combustion temperatures, thus suppressing the thermal  $NO_x$  mechanism. To a lesser extent, FGR also reduces  $NO_x$  formation by lowering the oxygen concentration in the primary flame zone. The amount of recirculated flue gas is a key operating parameter influencing  $NO_x$  emission rates for these systems. An FGR system is normally used in combination with specially designed low  $NO_x$  burners capable of sustaining a stable flame with the increased inert gas flow resulting from the use of FGR. When low  $NO_x$ burners and FGR are used in combination, these techniques are capable of reducing  $NO_x$  emissions by 60 to 90 percent.

Low NO<sub>x</sub> burners reduce NO<sub>x</sub> by accomplishing the combustion process in stages. Staging partially delays the combustion process, resulting in a cooler flame which suppresses thermal NO<sub>x</sub> formation. The two most common types of low NO<sub>x</sub> burners being applied to natural gas-fired boilers are staged air burners and staged fuel burners. NO<sub>x</sub> emission reductions of 40 to 85 percent (relative to uncontrolled emission levels) have been observed with low NO<sub>x</sub> burners.

Other combustion control techniques used to reduce  $NO_x$  emissions include staged combustion and gas reburning. In staged combustion (e.g., burners-out-of-service and overfire air), the degree of staging is a key operating parameter influencing  $NO_x$  emission rates. Gas reburning is similar to the use of overfire

in the use of combustion staging. However, gas reburning injects additional amounts of natural gas in the upper furnace, just before the overfire air ports, to provide increased reduction of  $NO_x$  to  $NO_2$ .

Two postcombustion technologies that may be applied to natural gas-fired boilers to reduce  $NO_x$  emissions are selective noncatalytic reduction (SNCR) and selective catalytic reduction (SCR). The SNCR system injects ammonia (NH<sub>3</sub>) or urea into combustion flue gases (in a specific temperature zone) to reduce  $NO_x$  emission. The Alternative Control Techniques (ACT) document for  $NO_x$  emissions from utility boilers, maximum SNCR performance was estimated to range from 25 to 40 percent for natural gas-fired boilers.<sup>12</sup> Performance data available from several natural gas fired utility boilers with SNCR show a 24 percent reduction in  $NO_x$  for applications on wall-fired boilers and a 13 percent reduction in  $NO_x$  for applications on wall-fired boilers and a 13 percent reduction in  $NO_x$  for applications to meet permitted levels. In these cases, the SNCR system may not be operated to achieve maximum  $NO_x$  reduction. The SCR system involves injecting  $NH_3$  into the flue gas in the presence of a catalyst to reduce  $NO_x$  emissions. No data were available on SCR performance on natural gas fired boilers at the time of this publication. However, the ACT Document for utility boilers estimates  $NO_x$  reduction efficiencies for SCR control ranging from 80 to 90 percent.<sup>12</sup>

Emission factors for natural gas combustion in boilers and furnaces are presented in Tables 1.4-1, 1.4-2, 1.4-3, and 1.4-4.<sup>11</sup> Tables in this section present emission factors on a volume basis (lb/10<sup>6</sup> scf). To convert to an energy basis (lb/MMBtu), divide by a heating value of 1,020 MMBtu/10<sup>6</sup> scf. For the purposes of developing emission factors, natural gas combustors have been organized into three general categories: large wall-fired boilers with greater than 100 MMBtu/hr of heat input, boilers and residential furnaces with less than 100 MMBtu/hr of heat input, and tangential-fired boilers. Boilers within these categories share the same general design and operating characteristics and hence have similar emission characteristics when combusting natural gas.

Emission factors are rated from A to E to provide the user with an indication of how "good" the factor is, with "A" being excellent and "E" being poor. The criteria that are used to determine a rating for an emission factor can be found in the Emission Factor Documentation for AP-42 Section 1.4 and in the introduction to the AP-42 document.

1.4.5 Updates Since the Fifth Edition

The Fifth Edition was released in January 1995. Revisions to this section are summarized below. For further detail, consult the Emission Factor Documentation for this section. These and other documents can be found on the Emission Factor and Inventory Group (EFIG) home page (http://www.epa.gov/ttn/chief).

Supplement D, March 1998

- Text was revised concerning Firing Practices, Emissions, and Controls.
- All emission factors were updated based on 482 data points taken from 151 source tests. Many new emission factors have been added for speciated organic compounds, including hazardous air pollutants.

July 1998 - minor changes

• Footnote D was added to table 1.4-3 to explain why the sum of individual HAP may exceed VOC or TOC, the web address was updated, and the references were reordered.

# Table 1.4-1. EMISSION FACTORS FOR NITROGEN OXIDES (NOx) AND CARBON MONOXIDE (CO)FROM NATURAL GAS COMBUSTIONa

	NO <sup>, b</sup>		СО		
Combustor Type (MMBtu/hr Heat Input) [SCC]	Emission Factor (lb/10 <sup>6</sup> scf)	Emission Factor Rating	Emission Factor (lb/10 <sup>6</sup> scf)	Emission Factor Rating	
Large Wall-Fired Boilers					
[1-01-006-01, 1-02-006-01, 1-03-006-01]					
Uncontrolled (Pre-NSPS) <sup>c</sup>	280	А	84	В	
Uncontrolled (Post-NSPS) <sup>c</sup>	190	А	84	В	
Controlled - Low NO <sub>x</sub> burners	140	А	84	В	
Controlled - Flue gas recirculation	100	D	84	В	
Small Boilers (<100) [1-01-006-02, 1-02-006-02, 1-03-006-02, 1-03-006-03]					
Uncontrolled	100	В	84	В	
Controlled - Low NO <sub>x</sub> burners	50	D	84	В	
Controlled - Low NO <sub>x</sub> burners/Flue gas recirculation	32	С	84	В	
Tangential-Fired Boilers (All Sizes) [1-01-006-04]					
Uncontrolled	170	А	24	С	
Controlled - Flue gas recirculation	76	D	98	D	
Residential Furnaces (<0.3) [No SCC]					
Uncontrolled	94	В	40	В	

<sup>a</sup> Reference 11. Units are in pounds of pollutant per million standard cubic feet of natural gas fired. To convert from  $lb/10^{6}$  scf to  $kg/10^{6}$  m<sup>3</sup>, multiply by 16. Emission factors are based on an average natural gas higher heating value of 1,020 Btu/scf. To convert from  $1b/10^{6}$  scf to lb/MMBtu, divide by 1,020. The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. SCC = Source Classification Code. ND = no data. NA = not applicable. <sup>b</sup> Expressed as NO<sub>2</sub>. For large and small wall fired boilers with SNCR control, apply a 24 percent reduction to the appropriate NO x emission factor. For

<sup>b</sup> Expressed as NO<sub>2</sub>. For large and small wall fired boilers with SNCR control, apply a 24 percent reduction to the appropriate NO x emission factor. For tangential-fired boilers with SNCR control, apply a 13 percent reduction to the appropriate NO x emission factor.
 <sup>c</sup> NSPS=New Source Performance Standard as defined in 40 CFR 60 Subparts D and Db. Post-NSPS units are boilers with greater than 250 MMBtu/hr of

<sup>c</sup> NSPS=New Source Performance Standard as defined in 40 CFR 60 Subparts D and Db. Post-NSPS units are boilers with greater than 250 MMBtu/hr of heat input that commenced construction modification, or reconstruction after August 17, 1971, and units with heat input capacities between 100 and 250 MMBtu/hr that commenced construction modification, or reconstruction after June 19, 1984.

1.4-5

Pollutant	Emission Factor (lb/10 <sup>6</sup> scf)	Emission Factor Rating
CO <sub>2</sub> <sup>b</sup>	120,000	А
Lead	0.0005	D
N <sub>2</sub> O (Uncontrolled)	2.2	Е
N <sub>2</sub> O (Controlled-low-NO <sub>X</sub> burner)	0.64	Е
PM (Total) <sup>c</sup>	7.6	D
PM (Condensable) <sup>c</sup>	5.7	D
PM (Filterable) <sup>c</sup>	1.9	В
$\mathrm{SO}_2^{\mathrm{d}}$	0.6	А
TOC	11	В
Methane	2.3	В
VOC	5.5	С

# TABLE 1.4-2.EMISSION FACTORS FOR CRITERIA POLLUTANTS AND GREENHOUSE GASESFROM NATURAL GAS COMBUSTION<sup>a</sup>

<sup>a</sup> Reference 11. Units are in pounds of pollutant per million standard cubic feet of natural gas fired. Data are for all natural gas combustion sources. To convert from  $lb/10^6$  scf to  $kg/10^6$  m<sup>3</sup>, multiply by 16. To convert from  $lb/10^6$  scf to 1b/MMBtu, divide by 1,020. The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. TOC = Total Organic Compounds. VOC = Volatile Organic Compounds.

- <sup>b</sup> Based on approximately 100% conversion of fuel carbon to  $CO_2$ .  $CO_2[lb/10^6 \text{ scf}] = (3.67)$  (CON) (C)(D), where CON = fractional conversion of fuel carbon to  $CO_2$ , C = carbon content of fuel by weight (0.76), and D = density of fuel,  $4.2 \times 10^4 \text{ lb}/10^6 \text{ scf}$ .
- <sup>c</sup> All PM (total, condensible, and filterable) is assumed to be less than 1.0 micrometer in diameter. Therefore, the PM emission factors presented here may be used to estimate  $PM_{10}$ ,  $PM_{2.5}$  or  $PM_1$  emissions. Total PM is the sum of the filterable PM and condensible PM. Condensible PM is the particulate matter collected using EPA Method 202 (or equivalent). Filterable PM is the particulate matter collected on, or prior to, the filter of an EPA Method 5 (or equivalent) sampling train.

<sup>d</sup> Based on 100% conversion of fuel sulfur to  $SO_2$ . Assumes sulfur content is natural gas of 2,000 grains/10<sup>6</sup> scf. The  $SO_2$  emission factor in this table can be converted to other natural gas sulfur contents by multiplying the  $SO_2$  emission factor by the ratio of the site-specific sulfur content (grains/10<sup>6</sup> scf) to 2,000 grains/10<sup>6</sup> scf.

CAS No.	Pollutant	Emission Factor (lb/10 <sup>6</sup> scf)	Emission Factor Rating
91-57-6	2-Methylnaphthalene <sup>b, c</sup>	2.4E-05	D
56-49-5	3-Methylchloranthrene <sup>b, c</sup>	<1.8E-06	E
	7,12-Dimethylbenz(a)anthracene <sup>b,c</sup>	<1.6E-05	E
83-32-9	Acenaphthene <sup>b,c</sup>	<1.8E-06	Е
203-96-8	Acenaphthylene <sup>b,c</sup>	<1.8E-06	Е
120-12-7	Anthracene <sup>b,c</sup>	<2.4E-06	Е
56-55-3	Benz(a)anthracene <sup>b,c</sup>	<1.8E-06	Е
71-43-2	Benzene <sup>b</sup>	2.1E-03	В
50-32-8	Benzo(a)pyrene <sup>b,c</sup>	<1.2E-06	Е
205-99-2	Benzo(b)fluoranthene <sup>b,c</sup>	<1.8E-06	Е
191-24-2	Benzo(g,h,i)perylene <sup>b,c</sup>	<1.2E-06	Е
205-82-3	Benzo(k)fluoranthene <sup>b,c</sup>	<1.8E-06	Е
106-97-8	Butane	2.1E+00	Е
218-01-9	Chrysene <sup>b,c</sup>	<1.8E-06	Е
53-70-3	Dibenzo(a,h)anthracene <sup>b,c</sup>	<1.2E-06	Е
25321-22-6	Dichlorobenzene <sup>b</sup>	1.2E-03	Е
74-84-0	Ethane	3.1E+00	Е
206-44-0	Fluoranthene <sup>b,c</sup>	3.0E-06	Е
86-73-7	Fluorene <sup>b,c</sup>	2.8E-06	Е
50-00-0	Formaldehyde <sup>b</sup>	7.5E-02	В
110-54-3	Hexane <sup>b</sup>	1.8E+00	Е
193-39-5	Indeno(1,2,3-cd)pyrene <sup>b,c</sup>	<1.8E-06	Е
91-20-3	Naphthalene <sup>b</sup>	6.1E-04	Е
109-66-0	Pentane	2.6E+00	Е
85-01-8	Phenanathrene <sup>b,c</sup>	1.7E-05	D

# TABLE 1.4-3. EMISSION FACTORS FOR SPECIATED ORGANIC COMPOUNDS FROM NATURAL GAS COMBUSTION<sup>a</sup>

# TABLE 1.4-3. EMISSION FACTORS FOR SPECIATED ORGANIC COMPOUNDS FROM NATURAL GAS COMBUSTION (Continued)

CAS No.	Pollutant	Emission Factor (lb/10 <sup>6</sup> scf)	Emission Factor Rating
74-98-6	Propane	1.6E+00	Е
129-00-0	Pyrene <sup>b, c</sup>	5.0E-06	Е
108-88-3	Toluene <sup>b</sup>	3.4E-03	С

<sup>a</sup> Reference 11. Units are in pounds of pollutant per million standard cubic feet of natural gas fired. Data are for all natural gas combustion sources. To convert from lb/10<sup>6</sup> scf to kg/10<sup>6</sup> m<sup>3</sup>, multiply by 16. To convert from 1b/10<sup>6</sup> scf to lb/MMBtu, divide by 1,020. Emission Factors preceeded with a less-than symbol are based on method detection limits.

<sup>b</sup> Hazardous Air Pollutant (HAP) as defined by Section 112(b) of the Clean Air Act.

<sup>c</sup> HAP because it is Polycyclic Organic Matter (POM). POM is a HAP as defined by Section 112(b) of the Clean Air Act.

<sup>d</sup> The sum of individual organic compounds may exceed the VOC and TOC emission factors due to differences in test methods and the availability of test data for each pollutant.

CAS No.	Pollutant	Emission Factor (lb/10 <sup>6</sup> scf)	Emission Factor Rating
7440-38-2	Arsenic <sup>b</sup>	2.0E-04	Е
7440-39-3	Barium	4.4E-03	D
7440-41-7	Beryllium <sup>b</sup>	<1.2E-05	Е
7440-43-9	Cadmium <sup>b</sup>	1.1E-03	D
7440-47-3	Chromium <sup>b</sup>	1.4E-03	D
7440-48-4	Cobalt <sup>b</sup>	8.4E-05	D
7440-50-8	Copper	8.5E-04	С
7439-96-5	Manganese <sup>b</sup>	3.8E-04	D
7439-97-6	Mercury <sup>b</sup>	2.6E-04	D
7439-98-7	Molybdenum	1.1E-03	D
7440-02-0	Nickel <sup>b</sup>	2.1E-03	С
7782-49-2	Selenium <sup>b</sup>	<2.4E-05	Е
7440-62-2	Vanadium	2.3E-03	D
7440-66-6	Zinc	2.9E-02	Е

## TABLE 1.4-4. EMISSION FACTORS FOR METALS FROM NATURAL GAS COMBUSTION<sup>a</sup>

<sup>a</sup> Reference 11. Units are in pounds of pollutant per million standard cubic feet of natural gas fired. Data are for all natural gas combustion sources. Emission factors preceeded by a less-than symbol are based on method detection limits. To convert from lb/10<sup>6</sup> scf to kg/10<sup>6</sup> m<sup>3</sup>, multiply by l6. To convert from lb/10<sup>6</sup> scf to 1b/MMBtu, divide by 1,020.
<sup>b</sup> Hazardous Air Pollutant as defined by Section 112(b) of the Clean Air Act.

References For Section 1.4

- 1. *Exhaust Gases From Combustion And Industrial Processes*, EPA Contract No. EHSD 71-36, Engineering Science, Inc., Washington, DC, October 1971.
- 2. *Chemical Engineers' Handbook, Fourth Edition*, J. H. Perry, Editor, McGraw-Hill Book Company, New York, NY, 1963.
- 3. *Background Information Document For Industrial Boilers*, EPA-450/3-82-006a, U. S. Environmental Protection Agency, Research Triangle Park, NC, March 1982.
- 4. *Background Information Document For Small Steam Generating Units*, EPA-450/3-87-000, U. S . Environmental Protection Agency, Research Triangle Park, NC, 1987.
- 5. J. L. Muhlbaier, "Particulate and Gaseous Emissions From Natural Gas Furnaces and Water Heaters", *Journal Of The Air Pollution Control Association*, December 1981.
- 6. L. P. Nelson, *et al.*, *Global Combustion Sources Of Nitrous Oxide Emissions*, Research Project 2333-4 Interim Report, Sacramento: Radian Corporation, 1991.
- 7. R. L. Peer, *et al.*, *Characterization Of Nitrous Oxide Emission Sources*, Prepared for the U. S. EPA Contract 68-D1-0031, Research Triangle Park, NC: Radian Corporation, 1995.
- 8. S. D. Piccot, et al., Emissions and Cost Estimates For Globally Significant Anthropogenic Combustion Sources Of NO<sub>x</sub>, N<sub>2</sub>O, CH<sub>4</sub>, CO, and CO<sub>2</sub>, EPA Contract No. 68-02-4288, Research Triangle Park, NC: Radian Corporation, 1990.
- 9. Sector-Specific Issues and Reporting Methodologies Supporting the General Guidelines for the Voluntary Reporting of Greenhouse Gases under Section 1605(b) of the Energy Policy Act of 1992 (1994) DOE/PO-0028, Volume 2 of 3, U.S. Department of Energy.
- J. P. Kesselring and W. V. Krill, "A Low-NO<sub>x</sub> Burner For Gas-Fired Firetube Boilers", *Proceedings: 1985 Symposium On Stationary Combustion NO<sub>x</sub> Control, Volume 2*, EPRI CS-4360, Electric Power Research Institute, Palo Alto, CA, January 1986.
- 11. *Emission Factor Documentation for AP-42 Section 1.4—Natural Gas Combustion*, Technical Support Division, Office of Air Quality Planning and Standards, U. S. Environmental Protection Agency, Research Triangle Park, NC, 1997.
- 12. Alternate Control Techniques Document NO<sub>x</sub> Emissions from Utility Boilers, EPA-453/R-94-023, U. S. Environmental Protection Agency, Research Triangle Park, NC, March 1994.

## AP-42 Section 1.4: Natural Gas Combustion Data Files

The data that supports the emission factors are presented in summary in the background report and are reported more completely in an electronic database. The database is in Microsoft Access 97<sup>®</sup>. The file is located on the CHIEF web site at http://www.epa.gov/ttn/chief/ap42c1.html.

AP-42 Section 3.2

## 3.2 Natural Gas-fired Reciprocating Engines

# 3.2.1 General<sup>1-3</sup>

Most natural gas-fired reciprocating engines are used in the natural gas industry at pipeline compressor and storage stations and at gas processing plants. These engines are used to provide mechanical shaft power for compressors and pumps. At pipeline compressor stations, engines are used to help move natural gas from station to station. At storage facilities, they are used to help inject the natural gas into high pressure natural gas storage fields. At processing plants, these engines are used to transmit fuel within a facility and for process compression needs (e.g., refrigeration cycles). The size of these engines ranges from 50 brake horsepower (bhp) to 11,000 bhp. In addition, some engines in service are 50 - 60 years old and consequently have significant differences in design compared to newer engines, resulting in differences in emissions and the ability to be retrofitted with new parts or controls.

At pipeline compressor stations, reciprocating engines are used to power reciprocating compressors that move compressed natural gas (500 - 2000 psig) in a pipeline. These stations are spaced approximately 50 to 100 miles apart along a pipeline that stretches from a gas supply area to the market area. The reciprocating compressors raise the discharge pressure of the gas in the pipeline to overcome the effect of frictional losses in the pipeline upstream of the station, in order to maintain the required suction pressure at the next station downstream or at various downstream delivery points. The volume of gas flowing and the amount of subsequent frictional losses in a pipeline are heavily dependent on the market conditions that vary with weather and industrial activity, causing wide pressure variations. The number of engines operating at a station, the speed of an individual engine, and the amount of individual engine horsepower (load) needed to compress the natural gas is dependent on the pressure of the compressed gas received by the station, the desired discharge pressure of the gas, and the amount of gas flowing in the pipeline. Reciprocating compressors have a wider operating bandwidth than centrifugal compressors, providing increased flexibility in varying flow conditions. Centrifugal compressors powered by natural gas turbines are also used in some stations and are discussed in another section of this document.

A compressor in storage service pumps gas from a low-pressure storage field (500 - 800 psig) to a higher pressure transmission pipeline (700 - 1000 psig) and/or pumps gas from a low-pressure transmission line (500 - 800 psig) to a higher pressure storage field (800 - 2000 psig).

Storage reciprocating compressors must be flexible enough to allow operation across a wide band of suction and discharge pressures and volume variations. The compressor must be able to compress at high compression ratios with low volumes and compress at low compression ratios with high volumes. These conditions require varying speeds and load (horsepower) conditions for the reciprocating engine powering the reciprocating compressor.

Reciprocating compressors are used at processing plants for process compression needs (e.g. refrigeration cycles). The volume of gas compressed varies, but the pressure needed for the process is more constant than the other two cases mentioned above.

## 3.2.2 Process Description<sup>1-3</sup>

Natural gas-fired reciprocating engines are separated into three design classes: 2-cycle (stroke) lean-burn, 4-stroke lean-burn, and 4-stroke rich-burn. Two-stroke engines complete the power cycle in a

Pollutant	Emission Factor (lb/MMBtu) <sup>b</sup> (fuel input)	Emission Factor Rating
Criteria Pollutants and Greenhou	se Gases	
NO <sub>x</sub> <sup>c</sup> 90 - 105% Load	4.08 E+00	В
NO <sub>x</sub> <sup>c</sup> <90% Load	8.47 E-01	В
CO <sup>c</sup> 90 - 105% Load	3.17 E-01	С
CO <sup>c</sup> <90% Load	5.57 E-01	В
$CO_2^{d}$	1.10 E+02	А
SO <sub>2</sub> <sup>e</sup>	5.88 E-04	А
TOC <sup>f</sup>	1.47 E+00	А
Methane <sup>g</sup>	1.25 E+00	С
VOC <sup>h</sup>	1.18 E-01	С
PM10 (filterable) <sup>i</sup>	7.71 E-05	D
PM2.5 (filterable) <sup>i</sup>	7.71 E-05	D
PM Condensable <sup>j</sup>	<mark>9.91 E-03</mark>	D
Trace Organic Compounds	•	
1,1,2,2-Tetrachloroethane <sup>k</sup>	<4.00 E-05	E
1,1,2-Trichloroethane <sup>k</sup>	<3.18 E-05	E
1,1-Dichloroethane	<2.36 E-05	E
1,2,3-Trimethylbenzene	2.30 E-05	D
1,2,4-Trimethylbenzene	1.43 E-05	С
1,2-Dichloroethane	<2.36 E-05	Е
1,2-Dichloropropane	<2.69 E-05	Е
1,3,5-Trimethylbenzene	3.38 E-05	D
1,3-Butadiene <sup>k</sup>	2.67E-04	D
1,3-Dichloropropene <sup>k</sup>	<2.64 E-05	Е
2-Methylnaphthalene <sup>k</sup>	3.32 E-05	С
2,2,4-Trimethylpentane <sup>k</sup>	2.50 E-04	С
Acenaphthene <sup>k</sup>	1.25 E-06	С

# Table 3.2-2. UNCONTROLLED EMISSION FACTORS FOR 4-STROKE LEAN-BURN ENGINESa(SCC 2-02-002-54)

<b>2</b> 11	Emission Factor (lb/MMBtu) <sup>b</sup>	Emission Factor
Pollutant	(fuel input)	Rating
Acenaphthylene <sup>K</sup>	5.53 E-06	С
Acetaldehyde <sup>k,1</sup>	8.36 E-03	А
Acrolein <sup>k,l</sup>	5.14 E-03	А
Benzene <sup>k</sup>	4.40 E-04	А
Benzo(b)fluoranthene <sup>k</sup>	1.66 E-07	D
Benzo(e)pyrene <sup>k</sup>	4.15 E-07	D
Benzo(g,h,i)perylenek	4.14 E-07	D
Biphenyl <sup>k</sup>	2.12 E-04	D
Butane	5.41 E-04	D
Butyr/Isobutyraldehyde	1.01 E-04	С
Carbon Tetrachloride <sup>k</sup>	<3.67 E-05	Е
Chlorobenzene <sup>k</sup>	<3.04 E-05	E
Chloroethane	1.87 E-06	D
Chloroform <sup>k</sup>	<2.85 E-05	E
Chrysene <sup>k</sup>	6.93 E-07	С
Cyclopentane	2.27 E-04	С
Ethane	1.05 E-01	С
Ethylbenzene <sup>k</sup>	3.97 E-05	В
Ethylene Dibromide <sup>k</sup>	<4.43 E-05	Е
Fluoranthene <sup>k</sup>	1.11 E-06	С
Fluorene <sup>k</sup>	5.67 E-06	С
Formaldehyde <sup>k,1</sup>	5.28 E-02	А
Methanol <sup>k</sup>	2.50 E-03	В
Methylcyclohexane	1.23 E-03	С
Methylene Chloride <sup>k</sup>	2.00 E-05	С
n-Hexane <sup>k</sup>	1.11 E-03	С
n-Nonane	1.10 E-04	С

# Table 3.2-2. UNCONTROLLED EMISSION FACTORS FOR 4-STROKE LEAN-BURN ENGINES (Continued)

Pollutant	Emission Factor (lb/MMBtu) <sup>b</sup> (fuel input)	Emission Factor Rating
n-Octane	3.51 E-04	С
n-Pentane	2.60 E-03	С
Naphthalene <sup>k</sup>	7.44 E-05	С
PAH <sup>k</sup>	2.69 E-05	D
Phenanthrene <sup>k</sup>	1.04 E-05	D
Phenol <sup>k</sup>	2.40 E-05	D
Propane	4.19 E-02	С
Pyrene <sup>k</sup>	1.36 E-06	С
Styrene <sup>k</sup>	<2.36 E-05	Е
Tetrachloroethane <sup>k</sup>	2.48 E-06	D
Toluene <sup>k</sup>	4.08 E-04	В
Vinyl Chloride <sup>k</sup>	1.49 E-05	С
Xylene <sup>k</sup>	1.84 E-04	В

## Table 3.2-2. UNCONTROLLED EMISSION FACTORS FOR 4-STROKE LEAN-BURN **ENGINES** (Continued)

<sup>a</sup> Reference 7. Factors represent uncontrolled levels. For NO<sub>v</sub>, CO, and PM10, "uncontrolled" means no combustion or add-on controls; however, the factor may include turbocharged units. For all other pollutants, "uncontrolled" means no oxidation control; the data set may include units with control techniques used for NOx control, such as PCC and SCR for lean burn engines, and PSC for rich burn engines. Factors are based on large population of engines. Factors are for engines at all loads, except as indicated. SCC = Source Classification Code. TOC = Total Organic Compounds. PM-10 = Particulate Matter  $\leq$  10 microns ( $\mu$ m) aerodynamic diameter. A "<" sign in front of a factor means that the corresponding emission factor is based on one-half of the method detection limit. <sup>b</sup> Emission factors were calculated in units of (lb/MMBtu) based on procedures in EPA Method 19. To convert from (lb/MMBtu) to (lb/ $10^6$  scf), multiply by the heat content of the fuel. If the heat content is not available, use 1020 Btu/scf. To convert from

(lb/MMBtu) to (lb/hp-hr) use the following equation:

lb/hp-hr = (lb/MMBtu) (heat input, MMBtu/hr) (1/operating HP, 1/hp)

<sup>&</sup>lt;sup>c</sup> Emission tests with unreported load conditions were not included in the data set.

<sup>&</sup>lt;sup>d</sup> Based on 99.5% conversion of the fuel carbon to  $CO_2$ .  $CO_2$  [lb/MMBtu] = (3.67)(%CON)(C)(D)(1/h), where %CON = percent conversion of fuel carbon to  $CO_2$ , C = carbon content of fuel by weight (0.75), D = density of fuel, 4.1 E+04 lb/10<sup>6</sup> scf. and

h = heating value of natural gas (assume 1020 Btu/scf at  $60^{\circ}$ F).

- <sup>e</sup> Based on 100% conversion of fuel sulfur to  $SO_2$ . Assumes sulfur content in natural gas of  $2,000 \text{ gr}/10^6 \text{scf.}$
- Emission factor for TOC is based on measured emission levels from 22 source tests.
- <sup>g</sup> Emission factor for methane is determined by subtracting the VOC and ethane emission factors from the TOC emission factor. Measured emission factor for methane compares well with the calculated emission factor, 1.31 lb/MMBtu vs. 1.25 lb/MMBtu, respectively.
- $^{\rm h}$  VOC emission factor is based on the sum of the emission factors for all speciated organic compounds less ethane and methane.
- Considered  $\leq 1 \ \mu m$  in aerodynamic diameter. Therefore, for filterable PM emissions, PM10(filterable) = PM2.5(filterable).
- <sup>j</sup> PM Condensable = PM Condensable Inorganic + PM-Condensable Organic
- Hazardous Air Pollutant as defined by Section 112(b) of the Clean Air Act.
- For lean burn engines, aldehyde emissions quantification using CARB 430 may reflect interference with the sampling compounds due to the nitrogen concentration in the stack. The presented emission factor is based on FTIR measurements. Emissions data based on CARB 430 are available in the background report.

AP-42 Section 3.3

## 3.3 Gasoline And Diesel Industrial Engines

## 3.3.1 General

The engine category addressed by this section covers a wide variety of industrial applications of both gasoline and diesel internal combustion (IC) engines such as aerial lifts, fork lifts, mobile refrigeration units, generators, pumps, industrial sweepers/scrubbers, material handling equipment (such as conveyors), and portable well-drilling equipment. The three primary fuels for reciprocating IC engines are gasoline, diesel fuel oil (No.2), and natural gas. Gasoline is used primarily for mobile and portable engines. Diesel fuel oil is the most versatile fuel and is used in IC engines of all sizes. The rated power of these engines covers a rather substantial range, up to 250 horsepower (hp) for gasoline engines and up to 600 hp for diesel engines. (Diesel engines greater than 600 hp are covered in Section 3.4, "Large Stationary Diesel And All Stationary Dual-fuel Engines".) Understandably, substantial differences in engine duty cycles exist. It was necessary, therefore, to make reasonable assumptions concerning usage in order to formulate some of the emission factors.

### 3.3.2 Process Description

All reciprocating IC engines operate by the same basic process. A combustible mixture is first compressed in a small volume between the head of a piston and its surrounding cylinder. The mixture is then ignited, and the resulting high-pressure products of combustion push the piston through the cylinder. This movement is converted from linear to rotary motion by a crankshaft. The piston returns, pushing out exhaust gases, and the cycle is repeated.

There are 2 methods used for stationary reciprocating IC engines: compression ignition (CI) and spark ignition (SI). This section deals with both types of reciprocating IC engines. All diesel-fueled engines are compression ignited, and all gasoline-fueled engines are spark ignited.

In CI engines, combustion air is first compression heated in the cylinder, and diesel fuel oil is then injected into the hot air. Ignition is spontaneous because the air temperature is above the autoignition temperature of the fuel. SI engines initiate combustion by the spark of an electrical discharge. Usually the fuel is mixed with the air in a carburetor (for gasoline) or at the intake valve (for natural gas), but occasionally the fuel is injected into the compressed air in the cylinder.

CI engines usually operate at a higher compression ratio (ratio of cylinder volume when the piston is at the bottom of its stroke to the volume when it is at the top) than SI engines because fuel is not present during compression; hence there is no danger of premature autoignition. Since engine thermal efficiency rises with increasing pressure ratio (and pressure ratio varies directly with compression ratio), CI engines are more efficient than SI engines. This increased efficiency is gained at the expense of poorer response to load changes and a heavier structure to withstand the higher pressures.<sup>1</sup>

### 3.3.3 Emissions

Most of the pollutants from IC engines are emitted through the exhaust. However, some total organic compounds (TOC) escape from the crankcase as a result of blowby (gases that are vented from the oil pan after they have escaped from the cylinder past the piston rings) and from the fuel tank and carburetor because of evaporation. Nearly all of the TOCs from diesel CI engines enter the

# Table 3.3-2.SPECIATED ORGANIC COMPOUND EMISSIONFACTORS FOR UNCONTROLLED DIESEL ENGINES<sup>a</sup>

	Emission Factor		
Pollutant	(Fuel Input) (lb/MMBtu)		
Benzene <sup>b</sup>	9.33 E-04		
Toluene <sup>b</sup>	4.09 E-04		
Xylenes <sup>b</sup>	2.85 E-04		
Propylene 🗭	2.58 E-03		
1,3-Butadiene <sup>b,c</sup>	<3.91 E-05		
Formaldehyde <sup>b</sup>	1.18 E-03		
Acetaldehyde <sup>b</sup>	7.67 E-04		
Acrolein <sup>b</sup>	<9.25 E-05		
Polycyclic aromatic hydrocarbons (PAH)			
Naphthalene <sup>b</sup>	8.48 E-05		
Acenaphthylene	<5.06 E-06		
Acenaphthene	<1.42 E-06		
Fluorene	2.92 E-05		
Phenanthrene	2.94 E-05		
Anthracene	1.87 E-06		
Fluoranthene	7.61 E-06		
Pyrene	4.78 E-06		
Benzo(a)anthracene	1.68 E-06		
Chrysene	3.53 E-07		
Benzo(b)fluoranthene	<9.91 E-08		
Benzo(k)fluoranthene	<1.55 E-07		
Benzo(a)pyrene	<1.88 E-07		
Indeno(1,2,3-cd)pyrene	<3.75 E-07		
Dibenz(a,h)anthracene	<5.83 E-07		
Benzo(g,h,l)perylene	<4.89 E-07		
TOTAL PAH	1.68 E-04		

<sup>a</sup> Based on the uncontrolled levels of 2 diesel engines from References 6-7. Source Classification Codes 2-02-001-02, 2-03-001-01. To convert from lb/MMBtu to ng/J, multiply by 430.
 <sup>b</sup> Hazardous air pollutant listed in the *Clean Air Act*.
 <sup>c</sup> Based on data from 1 engine.

Unit 8 CAT CoGen Specifications

### PRESBYTERIAN HOSPITAL COGEN PLANT EXTENDED DESCRIPTION FOR QUOTATION NO. 30686733.01

## G3516H

#### GAS ENGINE SITE SPECIFIC TECHNICAL DATA PHS COGEN

RATING STRATEGY:



#### GENSET - WITHOUT RADIATOR

ENGINE SPEED (rpm): COMPRESSION RATIO: AFTERCOOLER TYPE: AFTERCOOLER - STAGE 2 INLET (\*F): AFTERCOOLER - STAGE 1 INLET (\*F): JACKET WATER OUTLET (\*F): ASPIRATION: COOLING SYSTEM: CONTROL SYSTEM: EXHAUST MANIFOLD: COMBUSTION: NOX EMISSION LEVEL (g/bhp-hr NOX): SET POINT TIMING:

#### 1500 12.1 SCAC 120 198 210 TA JW+OC+1AC, 2AC+GB ADEM4 W/ IM DRY LOW EMISSION 1.0 18

FUEL SYSTEM: SITE CONDITIONS: FUEL: FUEL PRESSURE RANGE(psig): (See note 1) FUEL METHANE NUMBER: FUEL LHV (Btu/sef): ALTITUDE(ft): INLET AIR TEMPERATURE(\*F): STANDARD RATED POWER: POWER FACTOR: VOLTAGE(V): HIGH ALTITUDE/AMBIENT CAT LOW PRESSURE WITH AIR FUEL RATIO CONTROL Nat Gas

1.5-5.0 84.7 905 5098 86 2763 bhp@1500rpm

1.0 12470

				RATING	SITE RATING AT MAXIMUM INLET AIR TEMPERATURE		
RATING		NOTES	LOAD	100%	100%	75%	50%
GENSET POWER	(WITH GEARBOX, WITHOUT FAN)	. (2)(3)	ekW	1978	1978	1484	989
GENSET POWER	(WITH GEARBOX, WITHOUT FAN)	(2)(3)	kVA	1978	1978	1484	989
ENGINE POWER	(WITHOUT GEARBOX, WITHOUT FAN)	(3)	bhp	2746	2746	2065	1387
INLET AIR TEMPERATURE			۴F	86	86	86	86
GENERATOR EFFICIENCY		(2)	%	97.5	97.5	97.2	96.5
GENSET EFFICIENCY	(ISO 3046/1)	(4)(5)	%	43.5	43.5	42.5	40.2
THERMAL EFFICIENCY		(4)(6)	%	42.3	42.3	43.5	45.8
TOTAL EFFICIENCY		(4)(7)	96	85.8	85.8	86. <b>0</b>	86.0
ENGINE DATA	A share and a share of the						
GENSET FUEL CONSUMPTION	(ISO 3046/1)	(8)	Btu/ekW-hr	7839	7839	8026	8482
GENSET FUEL CONSUMPTION	(NOMINAL)	(8)	Btu/ekW-hr	8110	8110	8302	8775
ENGINE FUEL CONSUMPTION	(NOMINAL)	(8)	Btu/bhp-hr	5843	5843	5964	6258
AIR FLOW (@inlet air temp, 14.7 psia)	(WET)	(9)	ft3/min	5130	5130	3862	2630
AIR FLOW	(WET)	(9)	Ho/hr	22370	22370	16843	11471
FUEL FLOW (60°F, 14.7 psia)			scfm	295	295	227	160
INLET MANIFOLD PRESSURE		(10)	in Ho(abs)	135.0	135.0	102.1	70.4
EXHAUST TEMPERATURE - ENGINE OL	ITLET	(11)	۴F	768	768	824	911
EXHAUST GAS ELOW (@engine outlet te	mp 14.5 osia) (WET)	(12)	ft3/min	12424	12424	9790	7136
EXHAUST GAS MASS FLOW	(WET)	(12)	lb/hr	23179	23179	17464	11909
MAX INLET RESTRICTION	(((=))	(13)	in H2O	9.93	993	5.62	249
MAX EXHAUST RESTRICTION		(13)	in H2O	19.86	19.86	11.24	5.37
			1	1			
EMISSIONS DATA - ENGINE	001						
NOX (as NO2)		(14)(15)	g/onp-nr	1.00	1.00	1.00	1.00
CO		(14)(15)	g/onp-nr	1.62	1.62	1.57	1.50
THC (mol. wt. of 15.84)		(14)(15)	g/onp-nr	1.88	1.88	2.27	2.41
NMHC (mol. wt. of 15.84)		(14)(15)	g/bnp-hr	0.32	0.32	0.39	0.41
NMNEHC (VOCs) (mol. wt. of 15.84)		(14)(15)(16)	g/pnp-nr	0.30	0.30	0.36	0.39
HCHO (Formaldenyde)		(14)(15)	g/pnp-nr	0.19	0.19	0.19	0.21
CO2		(14)(15)	g/bhp-hr	412	412	417	433
EXHAUST OXYGEN		(14)(17)	% DR1	9.4	9.4	9.5	0.0
HEAT REJECTION							
LHV INPUT		(18)	Btu/min	26/382	267382	205301	144656
HEAT REJ. TO JACKET WATER (JW)		(19)	Btu/min	26808	26808	22617	1/981
HEAT REJ. TO ATMOSPHERE	(INCLUDES GENERATOR)	(19)	Btu/min	6655	6655	5833	5221
HEAT REJ. TO LUBE OIL (OC)	0.010151	(19)	Btu/min	10/2/	10/2/	9669	8365
HEAT REJECTION TO EXHAUST (LHV T	O 248°F)	(19)	Btu/min	53492	53492	44811	35449
HEAT REJ. TO A/C - STAGE 1 (1AC)		(19)(21)	Btu/min	22570	22570	12083	4278
HEAT REJ. TO A/C - STAGE 2 (2AC)		(19)(21)	Btu/min	12543	12543	8563	4891
HEAT REJECTION FROM GEARBOX (GI	3)	(19)	Btu/min	1060	1060	797	535
PUMP POWER		(20)	Btu/min	963	963	963	963
COOLING SYSTEM SIZING	CRITERIA		•	<b>.</b>			
TOTAL JACKET WATER CIRCUIT (JW+C	OC+1AC)	(22)	Btu/min	72452	72452		
TOTAL STAGE 2 AFTERCOOLER CIRCU	IIT (2AC+GB)	(22)	Btu/min	15836	15836		
HEAT REJECTION TO EXHAUST (LHV T	O 248°F)	(22)	Btu/min	58842	58842		
A cooling system safety factor of 0% has b	een added to the cooling system sizing criteria.					J	
MINIMUM HEAT RECOVERY	a summer of the second second						
TOTAL JACKET WATER CIRCUIT (JW+C	OC+1AC)	(23)	Btu/min	54150	54150		
		(22)	Btu/min	12923	12923	1	
TOTAL STAGE 2 AFTERCOOLER CIRCU	IIT (2AC+GB)	(23)	Diamin	12020			

is the maximum engine capability for the specified fuel at site altitude and maximum site inlet air temperature. Maximum rating is the maximum capability at the specified aftercooler inlet temperature for the specified fuel at site altitude and reduced inlet air temperature. Lowest load point is the lowest continuous duty operating load allowed. No overload permitted at rating shown.




#### **Application & Performance Warranty Data**

#### **Project Information**

Site Location:	Albuquerque, NM
Project Name:	PHS-New Tower
Application:	Continuous Power, Cogen
Number Of Engines:	1 .
Operating Hours per Year:	8760
Engine Specifications	
Engine Manufacturer:	Caterpillar
Model Number:	G3516H
Rated Speed:	1500 RPM
Type of Fuel:	Natural Gas
Type of Lube Oil:	0.6 wt% sulfated ash or less
Lube Oil Consumption:	0.1 % Fuel Consumption
Number of Exhaust Manifolds:	1

#### **Engine Cycle Data**

Load	Speed	Power	Exhaust Flow	Exhaust Temp.	Fuel Cons.	NOx	со	NMNEHC	CH <sub>2</sub> O	O <sub>2</sub>	H <sub>2</sub> O
%		bhp	lb/hr	F		g/bhp-hr	g/bhp-hr	g/bhp-hr	g/bhp-hr	%	%
100	Rated	2,611	23,040	779		0.5	1.78	0.4	0.22	9.5	17.5

#### Emission Data (100% Load)

TH	111	R	aw Engin	e Emissio	ns	111	11	Та	rget Outl	et Emissio	ons		
Emission	g/bhp- hr	g/kW-hr	tons/yr	ppmvd @ 15% O <sub>2</sub>	ppmvd	lb/MW- hr	g/bhp- hr	g/kW-hr	tons/yr	ppmvd @ 15% O <sub>2</sub>	ppmvd	lb/MW- hr	Calculated Reduction
NO <sub>x</sub> *	0.5	0.671	2.59	49	96	1.48							
CO	1.78	2.387	9.22	289	558	5.26	0.36	0.477	1.84	58	112	1.05	80%
NMNEHC**	0.4	0.536	2.07	113	219	1.18	0.24	0.322	1.24	68	131	0.71	40%
CH <sub>2</sub> O	0.22	0.295	1.14	33	64	0.65	0.07	0.089	0.34	10	19	0.2	70%
								TTT			I $I$ $I$		

\* MW referenced as NO<sub>2</sub>

MW referenced as CH4. Propane in the exhaust shall not exceed 15% by volume of the NMNEHC compounds in the exhaust, excluding aldehydes. The 15% (vol.) shall be established on a wet basis, reported on a methane molecular weight basis. The measurement of exhaust NMNEHC composition shall be based upon EPA method 320 (FTIR), and shall exclude formaldehyde.

Units 3 and 4 Boiler Manufacture Specifications

#### **Power Flame Incorporated**



### Typical Flue Product Emissions Data for Power Flame Burners

	Natural Gas	L.P. Gas	# 2 Fuel Oil <sup>(1)</sup>		
Carbon Monoxide - CO	.037 lb CO 10 <sup>6</sup> BTU input (50 PPM)	.037 lb CO 10 <sup>6</sup> BTU input (50 PPM)	.037 lb per 10 <sup>6</sup> BTU INPUT (50 PPM)		
Sulfur Dioxide - SO <sub>2</sub>	(1.05) x (% Su	(1.05) x (% Sulfur by weight in fuel) = lb SO <sub>2</sub> per $10^6$ BTU Input			
Particulate Matter	.0048 lb PM per 10 <sup>6</sup> BTU input .0048 lb PM per 10 <sup>6</sup> BT		.0143 lb PM per 10 <sup>6</sup> BTU input		
Hydrocarbons	.025 lb HC's per 10 <sup>6</sup> BTU input	.025 lb HC's per 10 <sup>6</sup> BTU input	.038 lb HC's per 10 <sup>6</sup> BTU input		
CO <sub>2</sub>	9 % to 10%	10% to 12%	10% to 13%		
Nitrogen Oxides - NO <sub>x</sub>					
Standard J, FDM & X4 Gas	.088 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.092 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	N/A		
Burners	(75 PPM)	(75 PPM)	N/A		
Standard C(R) Burners	.088 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.092 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.159 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU Input		
	(75 PPM)	(75 PPM)	(90) PPM <sup>(2)</sup>		
LNIC(R) Burners	.029 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.031 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.159 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU Input		
Fire box/Cast Iron boilers	(25 PPM)	(25 PPM)	(90) PPM <sup>(2)</sup>		
LNIC(R) Burners	.024 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.031 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.159 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU Input		
Water tube boilers	(20 PPM)	(25 PPM)	(90) PPM <sup>(2)</sup>		
LNIAC Burners	.029 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.031 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.12 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU Input		
	(25 PPM)	(25 PPM)	(90) PPM		
CM Burners	.070 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.074 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.146 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU Input		
	(60 PPM) <sup>(4)</sup>	(60 PPM) <sup>(4)</sup>	(110) PPM		
LNICM Burners	.029 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.031 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.12 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU Input		
Fire box/Cast Iron boilers	(25) PPM	(25) PPM	(90) PPM		
LNICM Burners	.029 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.031 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.12 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU Input		
Water tube boilers	(20) PPM	(20) PPM	(90) PPM		
NPM Premix Burners	.029 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.031 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	N/A		
	(25) PPM	(25) PPM	N/A		
Nova Plus Burners	.010 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	.015 lb NO <sub>x</sub> per 10 <sup>6</sup> BTU input	N/A		
NVC AND NP2	( 9) PPM	(12) PPM	N/A		

(1) NOx emissions at 3 % 02 will vary based on the percent of fuel bound nitrogen (these are based on .02%) and boiler or heat exchanger configurations

(2) 90 PPM NOx on cast iron sectional, fire box and water tube boiler, 120 PPM on fire tube boilers.

(3) Burning natural gas the VOC are estimated at 0.003 # per million BTU and SO<sub> $\chi$ </sub> are 0.0005 # per million BTU.

 (4) In some applications the CMAX will achieve less than 60 PPM without flue gas recirculation - consult factory. These emission rates are general estimates and do not constitute guarantees by Power Flame Inc. In instances where guarantees are required, please consult the factory with the specific application information. All NOx numbers stated are corrected to 3% O<sub>2</sub>

## Unit 6 Boiler Manufacture Specifications

#### East Expansion Phase 1 – Infrastructure/Seismic Presbyterian Hospital Albuquerque, New Mexico

#### 2.6 PERFORMANCE DATA

A. Emissions shall not exceed the following PPM when burning natural gas:

Firing Rate	25%	50%	75%	100%
NOx	3 <mark>0</mark>	<mark>30</mark>	<mark>30</mark>	<mark>30</mark>
CO	108	102	100	97

#### 2.7 APPROVED MANUFACTURERS

A. Burnham, Superior

#### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- A. Rigging: Verify that housekeeping pad is level in accordance with manufacturer's recommendations, rig boiler into place on housekeeping pad, verify that unit is level in accordance with manufacturer's recommendations, and anchor.
- B. Piping: Provide boiler feed, steam, fuel, blowdown, blowoff, compressed air and safety relief piping as per drawings, specifications, and manufacturer's recommendations. Provide new chemical feeder and piping as per drawings and specification.
- C. Wiring: Electrical contractor shall provide power wiring as per manufacturer's recommendations, electrical drawings and Division 16. Provide additional control wiring as per control drawings, specifications, and manufacturer's recommendations.
- 3.2 Provide services of a factory trained technician for all necessary start-up services, including boil-out, startup, and verification of all safety and operating controls. Submit start-up report including all items required by manufacturer, and:
  - A. Efficiency per flue gas analysis at 100%, 75%, 50% and 25% firing on natural gas and fuel oil.
  - B. Emissions at 100% firing on both natural gas and fuel oil, including NOx, CO, SO2, UHC, and PM10
- 3.3 Demonstrate to Owner's operating personnel that all aspects of system operation are functioning properly.
- 3.4 Provide three 2-hour training sessions to instruct Owner's personnel in all aspects of unit operation. Training sessions will be on different days. Schedule training minimum two weeks in advance and submit attendance list to Owner's Representative.
- 3.5 Spare Parts: Supply the following spare parts and test instruments, properly labeled in boxes:
  - A. One set of sight glasses and gauge glasses
  - B. One set of bulbs
  - C. One set of fuses
  - D. One set of waterside gaskets

#### BOILER 15620 - 4

## Public Regulatory Commission Natural Gas Sulfur Requirements

#### NEW MEXICO GAS COMPANY

NEW MEXICO PUBLIC REGULATION COMMISSION FILED

#### FIRST REVISED SAMPLE FORM NO. 46 CANCELLING ORIGINAL SAMPLE FORM NO. 46 2009 NOV 16 FILL 427

#### RESIDENTIAL AND SMALL VOLUME END-USER TRANSPORTATION CONTRACT Page 1 of 1

Please see attached Residential and Small Volume End-User Transportation Contract Form.

EFFECTIVE

DEC 15 2009 REPLACED BY NMPRC By Operation of Law Advice Notice No. 5

John M. Fernald Director, Regulatory Affairs

#### FIRST REVISED SAMPLE FORM NO. 46 CANCELLING ORGINAL SAMPLE FORM NO. 46

#### **RESIDENTIAL AND SMALL VOLUME END-USER TRANSPORTATION CONTRACT**

CONTRACT NO.

DATE \_\_\_\_\_

#### TRANSPORTATION CUSTOMER

#### AND

#### NEW MEXICO GAS COMPANY

## TABLE OF CONTENTS

DACE

ARTICLE

MINICLE		PAUE
I	DEFINITIONS	1
П	RECEIPTS AND DELIVERIES OF GAS	3
III	FACILITIES	6
IV	QUALITY	6
V	MEASUREMENT EQUIPMENT	9
VI	GAS MEASUREMENT	10
VII	CONTROL, OWNERSHIP, AND WARRANTIES	11
VIII	TRANSPORTATION CHARGES	12
IX	TAXES	12
Х	TRANSPORTATION CUSTOMER BILLING AND PAYMENT	12
XI	FINANCIAL RESPONSIBILITY AND QUALIFICATIONS	14
XII	REGULATION	15
XIII	TERM	16
XIV	FORCE MAJEURE	16
XV	OTHER CONTRACTS OR AGREEMENTS	17
XVI	NOTICES	17
XVII	END-USER BILLING AND PAYMENT	18
XVIII	MISCELLANEOUS	19
ATTACHMENT 1	RESIDENTIAL AND SMALL VOLUME END-USER NOMINATION	
	PROCEDURE	21
ATTACHMENT 2	RULE NO. 33 - RESIDENTIAL AND SMALL VOLUME END-USERS	
	TRANSPORTATION BALANCING RULE	29
	EXHIBITS	

EXHIBITS A	RECEIPT POINTS	30
EXHIBITS B	DELIVERY POINTS	31
EXHIBIT C	DELIVERY POINT CHANGE ORDERS	32
EXHIBIT D	CODE OF CONDUCT	33

NOTE: This page is not considered a part of the Contract but is for the convenience of the parties only and may be removed at any time by either party hereto.

## EFFECTIVE

DEC 15 2009

REPLACED BY NMPRC By \_\_\_\_Operation of Law

#### FIRST REVISED SAMPLE FORM NO. 46 CANCELLING ORIGINAL SAMPLE FORM NO. 46 RESIDENTIAL AND SMALL VOLUME END-USER TRANSPORTATION CONTRACT

(b)	Shall be commercially free of water in their liquid state at the temperature and pressure at which	X
	delivered, and in no event contain water vapor in excess of seven (7) pounds per million cubic feet.	X
	The water vapor content shall be determined by use of dew-point apparatus approved by the	X
	Bureau of Mines, or by any other method that is deemed appropriate for the conditions.	X
(c)	Shall not contain more than three quarters (3/4) grains of total sulfur per one hundred (100)	X
	standard cubic feet, which includes hydrogen sulfide, carbonyl sulfide, carbon disulfide,	X
	mercaptans, and mono-, di- and poly-sulfides. The Gas shall also meet the following individual	x
	specifications for hydrogen sulfide (H <sub>2</sub> S) and mercaptans:	x
	i. Hydrogen Sulfide: The Gas shall not contain more than one-quarter (1/4) grain per one	x
	hundred (100) standard cubic feet.	x
	ii. Mercaptan Sulfur: The Gas shall not have mercaptan sulfur content greater than three	x
	tenths (0.3) grain per one hundred (100) standard cubic feet.	x
(d)	Shall not contain in excess of 2-mol% of Carbon Dioxide (CO <sub>2</sub> ).	x
(e)	Shall not contain in excess of 0.2-mol% of Oxygen (O <sub>2</sub> ). Every effort shall be made to keep the	x
	Gas free of oxygen.	x
(f)	Shall not contain in excess of 5-mol% of total inert gasses.	x
(g)	Shall be commercially free of hydrocarbons and not have a hydrocarbon dew point that exceeds	x
	fifteen degrees Fahrenheit (15°F) between 100 and 1000 Psia.	x
(h)	Shall not be delivered into any of the Company's transmission or distribution pipeline systems at a	x
	temperature less than forty degrees Fahrenheit (40° F) nor greater than one hundred twenty degrees	x
	Fahrenheit (120° F).	x
(h)	Have a minimum heating value of not less than nine hundred fifty (950) British thermal units (Btu)	x
	per cubic foot, and not to exceed greater than eleven hundred (1100) Btu per standard cubic foot.	x
(i)	Shall not contain hydrocarbons with a molecular carbon content of $C_5$ and above ( $C_5$ +) in excess of	x
	0.2 gallon per one thousand (1000) standard cubic feet.	x

## EFFECTIVE

DEC 15 2009

	REPLACED	ΒY	<b>NMPRC</b>
BY	Operation	of	Caw

7

## Maintenance Procedures for Boilers

## A PRESBYTERIAN

## Presbyterian Hospital Boiler Operations Overview January 28, 2022

4 Boilers operate at the PHS Energy Center. They are used for steam production for our sterilizers and building heat exchangers.

- 2- 500 HP Kewanee boilers (#1 and #2)
- 1- 500 HP Burnham boiler (#4)
- 1- 250 HP Superior boiler (#3)
- Boilers are run on natural gas. Diesel fuel oil is available as an emergency backup on 1, 2 and 4.

In 2021, the hours ran on each boiler were:

- Boiler 1- 6075
- Boiler 2- 1907 (17.5 of these hours on fuel oil for natural gas line rerouting due to construction)
- Boiler 3- 470
- Boiler 4- 6245 (5 of these hours on fuel oil for natural gas line rerouting due to construction)
- Boilers 1 and 4 are run the most hours because of the updated burners and VFD controls on the fans.
- Two 500 hp boilers are generally required in the winter months.
- 1 500 hp boiler is generally sufficient through the summer months.
- Operational steam pressure is 60 psi, steam flow is not monitored.

Boilers are monitored on site, 24/7 by BO2 licensed boiler operators.

- Rounds conducted hourly and recorded. Temperatures, water and steam pressures and water levels are checked.
- Daily maintenance includes blowdowns as needed and once a shift safety checks. This is just normal routine and noted on the daily logs.
- Preventive maintenance is scheduled and performed weekly, monthly and annually from our computerized maintenance management system.
- Weekly preventive maintenance includes water treatment checks and safety checks. Noted on PM reports.
- Monthly preventive maintenance includes safety checks of the high-pressure relief valves. Noted on PM reports.
- Annual preventive maintenance involves a complete teardown on each boiler and internal inspection by the
  operators, water treatment personnel and city inspectors. All actions, problems and resolutions are noted on
  the PM reports. Corrective work orders are generated as needed to complete repairs
- D/A tanks and associated pumps are all inspected daily on each shift and have their own maintenance schedule.
- Each boiler is opened annually for inspection by our insurance carrier and to check internal components.
- Water treatment service are performed with automated controllers and chemical tests are performed to monitor chemical levels. Adjustments are made as warranted from the water tests.

Keith Long, Presbyterian EW Director Engineering Email: <u>hlong4@phs.org</u> Phone: 505-563-6221

## Maintenance Procedures for CoGen (Complete O&M Document in Electronic File Included)



# Operation and Maintenance Manual

## **G3500H 60Hz Generator Sets**

GLN 1-UP (G3516H Generator Set) GFR 1-UP (G3520H Generator Set) GF4 1-UP (G3512H Generator Set) NWJ 1-UP (G3516H Generator Set)

Language: Original Instructions



Scan to access the latest service information, purchase additional media, and buy genuine Cat<sup>®</sup> parts.



## Important Safety Information

Most accidents that involve product operation, maintenance and repair are caused by failure to observe basic safety rules or precautions. An accident can often be avoided by recognizing potentially hazardous situations before an accident occurs. A person must be alert to potential hazards, including human factors that can affect safety. This person should also have the necessary training, skills and tools to perform these functions properly.

## Improper operation, lubrication, maintenance or repair of this product can be dangerous and could result in injury or death.

## Do not operate or perform any lubrication, maintenance or repair on this product, until you verify that you are authorized to perform this work, and have read and understood the operation, lubrication, maintenance and repair information.

Safety precautions and warnings are provided in this manual and on the product. If these hazard warnings are not heeded, bodily injury or death could occur to you or to other persons.

The hazards are identified by the "Safety Alert Symbol" and followed by a "Signal Word" such as "DANGER", "WARNING" or "CAUTION". The Safety Alert "WARNING" label is shown below.

The meaning of this safety alert symbol is as follows:

#### Attention! Become Alert! Your Safety is Involved.

The message that appears under the warning explains the hazard and can be either written or pictorially presented.

A non-exhaustive list of operations that may cause product damage are identified by "NOTICE" labels on the product and in this publication.

Caterpillar cannot anticipate every possible circumstance that might involve a potential hazard. The warnings in this publication and on the product are, therefore, not all inclusive. You must not use this product in any manner different from that considered by this manual without first satisfying yourself that you have considered all safety rules and precautions applicable to the operation of the product in the location of use, including site-specific rules and precautions applicable to the worksite. If a tool, procedure, work method or operating technique that is not specifically recommended by Caterpillar is used, you must satisfy yourself that it is safe for you and for others. You should also ensure that you are authorized to perform this work, and that the product will not be damaged or become unsafe by the operation, lubrication, maintenance or repair procedures that you intend to use.

The information, specifications, and illustrations in this publication are on the basis of information that was available at the time that the publication was written. The specifications, torques, pressures, measurements, adjustments, illustrations, and other items can change at any time. These changes can affect the service that is given to the product. Obtain the complete and most current information before you start any job. Cat dealers have the most current information available.

#### NOTICE

When replacement parts are required for this product Caterpillar recommends using original Caterpillar® replacement parts.

Other parts may not meet certain original equipment specifications.

When replacement parts are installed, the machine owner/user should ensure that the machine remains in compliance with all applicable requirements.

In the United States, the maintenance, replacement, or repair of the emission control devices and systems may be performed by any repair establishment or individual of the owner's choosing.

## **Table of Contents**

Foreword	. 4
Safety Section	
Safety Messages	. 6
Additional Messages	13
General Hazard Information	13
Burn Prevention	17
Fire Prevention and Explosion Prevention	18
Crushing Prevention and Cutting Prevention	19
Mounting and Dismounting	20
Ignition Systems	20
Before Starting Engine	20
Engine Starting	20
Engine Stopping	21
Generator Isolating for Maintenance	21

### **Product Information Section**

General Information			
Product Identification Information	. 31		

## **Operation Section**

Lifting and Storage	37
Installation	41
Features and Controls	43
Engine Diagnostics	47
Engine Starting	48
Engine Operation	53
Generator Operation	54

Engine Stopping 65
Maintenance Section
Refill Capacities
Maintenance Recommendations72
Maintenance Interval Schedule78
Reference Information Section
Customer Service 155
Reference Materials 157
Index Section

Index 16
----------

## **Maintenance Section**

## **Refill Capacities**

i07585620

## **Refill Capacities**

SMCS Code: 1000; 1348; 1395; 7560

## **Lubricant Capacities**

#### **Engine Lubricant Capacities**

The capacity of the engine lubrication system includes the capacity of the oil filters that are installed at the factory. Auxiliary oil filter systems (if equipped) will require more oil. Refer to the specifications that are provided by the OEM of the auxiliary oil filter system.

Table 11

Approximate Refill Capacities for G3500H Lubrication Systems			
System	G3512H	G3516H	G3520H
Engine Crankcase	291 L (77 US gal)	462 L (122 US gal)	568 L (150 US gal)

### **Gearbox Lubricant Capacities**

Table 12

Gearbox Configuration <sup>(1)</sup>	Capacity
Туре 1	74 L (19.5 US gal)
Туре 2	55 L (14.5 US gal)

<sup>(1)</sup> Refer to this Operation and Maintenance Manual, Model Views to identify the gearbox type.

## **Coolant Capacities**

To maintain the cooling system, the total cooling system capacity must be determined. The total cooling system capacity will vary between individual installations. The total cooling system capacity equals the capacity of the jacket water circuit plus the aftercooler circuit plus the external system capacity. The external system capacity may include the following components: expansion tank, heat exchanger, radiator, and piping. Refer to the specifications that are provided by Caterpillar or by the OEM of the equipment. The customer is to record the external and total cooling system capacities in the following table:

#### Table 13

#### Approximate Refill Capacities for G3500H Cooling Systems

System	G3512H	G3516H	G3520H
Jacket Water Circuit <sup>(1)</sup>	139 L (37 US gal)	208 L (55 US gal)	285 L (75 US gal)
SCAC	31 L (8.2 US gal)	31 L (8.2 US gal)	31 L (8.2 US gal)
External <sup>(2)</sup>			
Total Cool- ing System			

<sup>(1)</sup> Capacities including pumps.

<sup>(2)</sup> Filled in by customer.

i08490368

## Fluid Recommendations

SMCS Code: 1280; 1348; 1395; 7560

## Lubricant Recommendations

Due to the significant variations in the quality and in the performance of commercially available oils, Caterpillar recommends the following in order of oil performance:

- Cat Natural Gas Engine Oil (NGEO) ULTRA 40
- Cat Natural Gas Engine Oil (NGEO) Synthetic HP (SYN HP)

Cat natural gas engine oils are the preferred oils for use in ALL Cat natural gas fueled engines that are covered by Special Publication, SEBU6400. Commercial alternative natural gas engine oils are, as a group, second choice oils.

The proper SAE viscosity grade of oil is determined by the minimum ambient temperature during cold engine start-up. The proper SAE viscosity grade of oil is also determined by the maximum ambient temperature during engine operation. To determine the oil viscosity that is required for starting a cold soaked engine, refer to the minimum temperature. To select the oil viscosity for operation at the highest anticipated ambient temperature, refer to the maximum temperature in the Table. Use the highest oil viscosity that is available to meet the required temperature during start-up.

Table '	14
---------	----

Cat NGEO Recommendations Based on Engine Ratings		
Engine Oil	Engine Rating in Megawatts (MW)	
Cat NGEO Advanced 40	2.0/2.1	
Cat NGEO Synthetic HP (Syn HP)	2.5/2.6	

For additional information about oils for gas engines, see Special Publication, SEBU6400, "Cat Gas Engine Lubricant, Fuel, and Coolant Recommendations".

## Synthetic Base Stock Oil

**Note:** Refer to M0120065, "Procedure to Change Natural Gas Engine Oil (NGEO) on Certain G3500 Engines" for flushing procedures.

**Note:** Refer to M012495, "Rework Procedure for Installing NGEO SYN HP Compatible Hardware on Certain G3500 Engines" for required engine hardware updates.

Synthetic base stock oils may have different material compatibilities than compared to typical mineral base stock oils. Table 15 lists material recommendations for all lube oil components that have been determined to be compatible with CAT NGEO SYN HP. The table also lists materials that are not recommended for use with CAT NGEO SYN HP. Other Commercially available synthetic oils may not share material compatibilities. Material compatibilities of the oil with your engine should be understood to prevent engine damage.

Material compatibilities of the oil with your engine should be understood to prevent engine damage. Table 15

Material Compatibility Recommendations for use with Cat NGEO SYN HP		
Recommended Materials	Comments	
Fluorocarbon (FKM, FFKM, Viton)		
Fluorosilicone (FVMO, FSI)		
Polytetrafluoroethylene (PTFE, Teflon)		
Acrylonitrile - Butadiene (NBR)	ACN (Acrylonitrile Content) >32% Recommended	
Highly Saturated Nitrile (HNBR)	ACN (Acrylonitrile Content) >32% Recommended	
Not Recommended Materials		
Natural Rubber (NR)		
Polyisoprene ((IR, Synthetic Rubber)		

(Table 15, contd)

Isobutylene-Isoprene (IIR, Butyl)	
Acrylonitrile-Butadiene (NBR)	ACN (Acrylonitrile Content) <32% Not Recommended, typically low temperature NBR

## **Oil Consumption**

The rate of oil consumption is called Brake-Specific Oil Consumption (BSOC). The unit of measure is grams per brake kilowatt hour or pounds per brake horsepower hour. The BSOC depends on the engine model, the aspiration, the operating load, and the oil that is used. For more information on BSOC, refer to Engine Data Sheet, LEKQ4028, "Oil Consumption Data" at the following website:

emc.cat.com

BSOC for G3500H Turbocharged Aftercooled Engines			
Engine Oil	BSOC (g/bkw-h)	BSOC (lb/bhp-h)	
Cat NGEO Ultra 40	0.122	0.0002	
Cat NGEO SYN HP	0.085	0.0001	

## S·O·S Services Oil Analysis

Caterpillar recommends the S $\cdot$ O $\cdot$ S oil analysis program to monitor the condition of the oil. The analysis can help determine the maintenance requirements for the engine. The S $\cdot$ O $\cdot$ S program is part of the preventive maintenance program. For further information about the S $\cdot$ O $\cdot$ S program, see this Special Publication, "S $\cdot$ O $\cdot$ S Services Oil Analysis" topic.

## **Gearbox Lubricant**

Use only Caterpillar approved oils in the gearbox. Use of unapproved oils may compromise the operation of the gearbox. For more information on gearbox oil, consult your Cat dealer.

NOTICE Use only the oils that are specified.

Table 17

Gearbox Oil		
Gearbox Configuration	Oil	

(continued)

(Table 17, contd)

Туре 1	Cat NGEO Advanced 40
Туре 2	Synthetic Compactor Oil: Cat part number 143-5466

## **Coolant Recommendations**

During shipping and storage, the engine must be protected from damage that can be caused by freezing of the cooling system. If the engine is shipped to a location with freezing temperatures, the cooling system must contain an antifreeze mixture that will withstand the lowest ambient temperature. If the engine is stored at a location with freezing temperatures, the cooling system must contain an antifreeze mixture that will withstand the lowest ambient temperature. Frequently check the concentration of glycol in the coolant/antifreeze. Make sure that the concentration is adequate to prevent freezing. Otherwise, drain the cooling system.

Coolant/antifreeze is normally composed of three elements: water, glycol, and additives. Each element must meet specific guidelines.

#### Water

#### Deionized water or distilled water is recommended for use in engine cooling systems. If distilled water or deionized water is not available,

use water with the properties that are listed in Table 18 .

Table 18

Caterpillar Minimum Acceptable Water Requirements					
Property	ASTM Test				
Chloride <sup>-</sup> )	40 mg/L (2.4 gr per US gal)	"D512", "D4327"			
Sulfate (SO₄⁻)	100 mg/L (5.9 gr per US gal)	"D516"			
Total Hardness	170 mg/L (10 gr per US gal)	"D1126"			
Total Solids	340 mg/L (20 gr per US gal)	"D1888"			
Acidity	pH of 5.5 to 9.0	"D1293"			

#### NOTICE

Use of water that does not meet the recommendations for the cooling system will damage the cooling system.

Do not use these types of water in the cooling system: sea water, softened water that has been conditioned with salt, hard water and tap water.

Only use water that meets the recommendations for the cooling system.

If you are not sure about the properties of your water, consult one of the following sources for a water analysis:

- Cat dealer
- Local water utility company
- Agricultural agent
- Independent laboratory

#### Glycol

NOTICE

Do not use Extended Life Coolant (ELC) with Cat Gas Engines.

ELC was not formulated for use in Cat Gas Engines.

## Do not use heat transfer fluids in Cat Gas Engines.

Use only the coolant/antifreeze that is recommended.

**Preferred** – Cat Natural Gas Engine Coolant (NGEC)

Alternatively, use Cat Diesel Engine Antifreeze/ Coolant (DEAC) or a commercial heavy-duty coolant/ antifreeze that meets "ASTM D6210" or "ASTM D4985" specifications.

#### NOTICE

Do not use a commercial coolant/antifreeze that only meets the ASTM "D3306" or equivalent specification. This type of coolant/antifreeze is made for light duty automotive applications.

Use only the coolant/antifreeze that is recommended.

**Acceptable** – In applications that do not require protection from boiling or freezing, a mixture of Cat SCA and water that meets the required properties is acceptable.

**Note:** The preferred coolant/antifreeze and the acceptable mixture of SCA and water require different concentrations of SCA. Refer to the Special Publication, SEBU6400, "Supplemental Coolant Additive (SCA)" topic.

Table 19 is a list of the coolant/antifreeze that is recommended for Cat Gas Engines. The service life of the coolant/antifreeze that is used in Cat Gas Engines is also listed. **To achieve this service life**, **the coolants must be maintained. The maintenance program includes S·O·S coolant analysis.**  Table 19

Recommended Coolant/Antifreeze and Service Life of the Coolant/Antifreeze				
Coolant/Antifreeze Service Life (1)				
Cat NGEC	Three Veers			
Cat DEAC	Three Years			
Commercial Heavy-Duty Cool- ant/Antifreeze that meets "ASTM D6210"	Two Years			
Commercial Heavy-Duty Cool- ant/Antifreeze that meets "ASTM D4985"	One Year			
Cat SCA and Water	Two Years			
Commercial SCA and Water	One Year			

(1) The service life of coolant is also limited by use (service hours). Refer to the specific engine Operation and Maintenance Manual, "Maintenance Interval Schedule".

### Additives

**Preferred** – Cat Supplemental Coolant Additive (SCA)

**Acceptable** – A commercial SCA that provides 1200 mg/L (70 gr per US gal) or 1200 ppm of nitrites in the final mixture of coolant/antifreeze

Note: A 50/50 concentration of Cat NGEC or of Cat DEAC does not require a treatment with an SCA at the initial fill. Commercial heavy-duty coolant/antifreeze that meets "ASTM D6210" or "ASTM D4985" specifications may require a treatment with an SCA at the initial fill. Read the label or the instructions that are provided by the OEM of the product.

To ensure that the correct amount of SCA is in the cooling system, the concentration of SCA must be tested on a scheduled basis. Obtain an  $S \cdot O \cdot S$  coolant analysis (Level 1) or use a test kit to check the concentration of the SCA at the recommended interval.

For further information on coolant, see Special Publication, SEBU6400, "Cat Gas Engine Lubricant, Fuel, and Coolant Recommendations".

## **Fuel Recommendations**

Cat gas engines will operate successfully on a broad range of gaseous fuels. Pipeline natural gas has been used for many years. Commercial fuel gases are mixtures of gases. These fuels consist primarily of hydrocarbons (combinations of hydrogen and carbon) and some inert gases. The compositions of these gas mixtures have extreme variations. Fuels such as wellhead gas, bio-gas, and manufactured gas must be reviewed for acceptability. Analyze the fuel to determine the following characteristics:

- Composition
- Contaminants
- Heat value
- Methane number
- Specific gravity

Field gas can have varying characteristics of combustion. Field gas can contain numerous harmful impurities. The impurities can alter the BTU content. The impurities can also alter the methane number. The impurities include everything from water up to complex hydrocarbons that can lead to detonation and severe engine damage. To minimize these effects, Caterpillar recommends the following guidelines:

1. Evaluate the fuel with the Cat methane number program that is contained in Gas Engine Rating Pro (GERP) which can be found on Power Net.

Reference the engine performance data sheet for fuel usage.

- **2.** If necessary, use an engine that is configured for a fuel that has a high energy. Consult the appropriate manual for the engine to determine the recommended engine timing.
- **3.** Reduce the oil change interval according to the results of the oil analysis.

For further information on fuels, see Special Publication, SEBU6400, "Cat Gas Engine Lubricant, Fuel, and Coolant Recommendations".

## Maintenance Recommendations

i07726152

## General Maintenance Information

SMCS Code: 4450; 7000

**Note:** Read the warnings and read the instructions that are contained in the Safety Section of this manual. These warnings and instructions must be understood before you perform any operation or any maintenance procedures.

Rotating electric machines are complex structures that are exposed to the following forms of stress:

- mechanical
- electrical
- thermal
- environmental

These stresses may be of varying magnitudes. The insulation systems are susceptible to damage that is caused by the stresses that are listed above. Exposure to these stresses may shorten the effective life of the insulation system. Therefore, the service life of an electric machine will largely depend on the serviceability of the insulation systems. An inspection program and a testing procedure are recommended. An inspection program and a testing procedure will ensure that the equipment is maintained in satisfactory condition. This procedure will increase field reliability.

A regular maintenance and inspection program can provide an evaluation of the present condition of the equipment. A regular maintenance program and a regular inspection program can also reveal future problems. The frequency of this maintenance program will depend on the following factors:

- application
- environmental conditions
- operator experience
- operator philosophy

A regular maintenance program is recommended. This program would involve the following steps:

- · periodic disassembly
- knowledgeable visual examination of the equipment

the application of electrical tests

Never perform a test over the rated potential. These tests can damage insulation that is contaminated or insulation that is in marginal condition. For more information, refer to "I.E.E.E. Standard 432-1992" or consult a Caterpillar dealer.

## **Space Heaters**

The SR4B and SR5 generators used on this product can operate in high humidity conditions without problems. However, problems can occur when the generator is idle and the surrounding air is warmer than the generator. Moisture can form on the windings that will result in poor performance from the windings. Moisture can also result in damage to the windings. Whenever the generator is not active, ensure that the space heaters are in operation.

NOTICE Ensure that power has been disconnected before servicing the generator terminal box.

**Note:** An optional attachment for space heaters may be utilized in the generator terminal box. The space heaters are a source of heat.

Whenever the generator is operating, ensure that the space heaters are disconnected.

An external source of either 115 VAC or 230 VAC is required to operate the space heaters.



Illustration 48

Space heater connection to external source (H1)(H2), (H3), and (H4) terminals.

g00556903

If a 115 VAC source is available, connect both heaters in parallel across the source. If a 230 VAC source is available, connect both heaters in series across the source. Refer to Illustration 48.

## **Gearbox Heater (If Equipped)**

The gearbox can operate in normal ambient conditions without problems. Low oil temperatures can result in damage to the gearbox oil pump and sensors due to high pressure. Whenever the gearbox is not operating, ensure that the oil heater is in operation to maintain an oil temperature at or above  $30^{\circ}$  C ( $86^{\circ}$  F).

The gearbox heater can be operated while the gearbox is operating. A built-in thermostat will turn off the heater element as the oil temperature rises.

A 120 or 240 VAC external source is required to operate the gearbox heater. The external power source voltage depends on the heater utilized on the unit. Confirm the voltage required for your specific unit prior to connecting power.

i08273272

## **System Pressure Release**

**SMCS Code:** 1250; 1300; 1350; 5050

## **Coolant System**

## 🏠 WARNING

Pressurized system: Hot coolant can cause serious burn. To open cap, stop engine, wait until radiator is cool. Then loosen cap slowly to relieve the pressure. To relieve the pressure from the coolant system, turn off the engine. Allow the cooling system pressure cap to cool. Remove the cooling system pressure cap slowly to relieve pressure.

## **Fuel System**

To relieve pressure from the fuel system, close the manual valves, and purge the generator set.

### **Generator Set Oil**

To relieve pressure from the lubricating systems, turn off the engine.

i08254042

## Welding on Engines with Electronic Controls

SMCS Code: 1000

#### NOTICE

Because the strength of the frame may decrease, some manufacturers do not recommend welding onto a chassis frame or rail. Consult the OEM of the equipment or your Cat dealer regarding welding on a chassis frame or rail.

Proper welding procedures are necessary to avoid damage to the engine ECM, sensors, and associated components. When possible, remove the component from the unit and then weld the component. If removal of the component is not possible, the correct procedure must be followed. When welding on a unit that is equipped with a Cat Electronic Engine, the following is considered to be the safest procedure:

#### NOTICE

Do not ground the welder to electrical components such as the ECM or sensors. Improper grounding can cause damage to the drive train, the bearings, hydraulic components, electrical components, and other components.

Do not ground the welder across the centerline of the package. Improper grounding could cause damage to the bearings, the crankshaft, the rotor shaft, and other components.

Clamp the ground cable from the welder to the component that will be welded. Place the clamp as close as possible to the weld. This will help reduce the possibility of damage.

**Note:** Perform the welding in areas that are free from explosive hazards.

**1.** Stop the engine. Turn the switched power to the OFF position.

- 2. Disconnect the negative battery cable from the battery. If a battery disconnect switch is provided, open the switch.
- **3.** Disconnect the J1/P1 and J2/P2 connectors from the ECM. Move the harness to a position that will not allow the harness to move back accidentally, and contact any of the ECM pins.
- Disconnect any component with a microprocessor from the engine harness, such as:
  - Engine ECM
  - Product Link
  - Cell/Sat Radio
  - DOC Identity Modules



#### Illustration 49

q01075639

Use the example above. The current flow from the welder to the ground clamp of the welder will not damage any associated components.

- (1) Engine
- (2) Welding electrode
- (3) Keyswitch in the OFF position
- (4) Battery disconnect switch in the open position
- (5) Disconnected battery cables
- (6) Battery
- (7) Electrical/Electronic component
- (8) Minimum distance between the component that is being welded and any electrical/electronic component
- (9) The component that is being welded
- (10) Current path of the welder
- (11) Ground clamp for the welder
- 5. Connect the welding ground cable directly to the part that will be welded. Place the ground cable as close as possible to the weld. This location will reduce the possibility of welding current damage to bearings, hydraulic components, electrical components, and ground straps.

**Note:** If electrical/electronic components are used as a ground for the welder, current flow from the welder could severely damage the component. Current flow from the welder could also severely damage electrical/electronic components that are located between the welder ground and the weld.

**6.** Protect the wiring harness from welding debris and spatter.

7. Use standard welding practices to weld the materials.

i07585634

## **Generator Start-up Checklist**

#### SMCS Code: 4450

Table 20

		GENERATOR	START-UP C	HECKLIST				
RATING INFO	RMATION							
Engine Serial Number:				Arrangement Number:				
Generator Seri	al Number:			Arrangement	Number:			
Gearbox Seria	Number:							
GENERATOR	NAME PLATE INFORMATION							
Voltage:			Package (prir	me, continuous,	standby):		_	
Amperage:			Kilowatts:				_	
Storage Locati	on:							
Generator and	Gearbox Alignment:							
Main Stator Me	egohmmeter Reading:	Before Storag	e:		After Storage:			
Generator dried for 24 hours prior to start-up?			(Y/N)		Drying method	:		
HEATERS		Yes	No		Com	Comments		
Space heaters operating properly?								
Gearbox oil he Equipped)	ater is operating properly? (If							
Type 1 Gearbo Utilizing Cat No Gearbox oil ter fore start-up?	x GEO Advanced 40 Oil. nperature above 10° C(50° F) be-							
Type 2 Gearbox Utilizing Cat Synthetic Compactor Oil. Gearbox oil temperature above 0° C (32° F) be- fore start-up?								
Space heater of	operated 48 hrs. before start-up?							
MEGOHMMETER TEST (SEHS9124)		30 sec. reading	60 sec. reading	30 sec. corrected	60 sec. corrected	Ambient temp.	Comments	
Beginning of	Main Stator							
Storage	Main Rotor							
	Exciter Stator							
	Exciter Rotor							
	PMG Stator							
Start-up	Main Stator							
	Main Rotor							

#### (Table 20, contd)

	GENERATOR START-UP CHECKLIST						
	Exciter Stator						
	Exciter Rotor						
	PMG Stator						
	Regulator	Voltage	Amps		Comr	nents	
No Load	F1 to F2	DC					
	20 to 22	AC					
	20 to 24	AC					
	22 to 24	AC					
	26 to 28	AC					
	26 to 30	AC					
	28 to 30	AC					
Full Load	Generator Excitation Name Plate Information:	DC		Compare with	F1 to F2		
	F1 to F2	DC					
	20 to 22	AC					
	20 to 24	AC					
	22 to 24	AC					
	26 to 28	AC					
	26 to 30	AC					
	28 to 30	AC					

#### Table 21

GENERATOR START-UP CHECKLIST (CONT.)					
ELECTRICAL		Yes	No	Com	ments
	Unit properly grounded				
	Check diodes				
	Over current protection				
	Over voltage protection				
	Check for loose wiring				
	Adjust voltage				
	Adjust frequency				
MECHANICAL			Data		Comments
	Bearing temperature readings at full load	Front	Rear		
	Stator temperature readings at full load	A0B0	C0		
	Air gap on main stator	Тор	_Bottom		
	Air gap on exciter stator	Тор	Bottom		
	Air gap of PMG	Тор	_Bottom		
	Ambient air to generator at full load	Temperature			

(Tah	lo 21	contd	`
(lap	ie z i	, conta	)

	Supplier air opening to generator			Size of Opening					
SWITCH GEA	R/PARALLEL O	PERATION							
	Manufacturer:	lanufacturer:							
	Settin			Setting 1	Setting 2	Setting 3	Com	ments	
	Circuit breaker	type							
	Overload settin	g							
	Reverse power	relay							
	VAR/PF Contro	oller							
	Load share								
INSTALLATIO	N & LOAD INFO	RMATION							
	Neutral grounding system			UPS					
	Enclosure type			Size					
	Motor:			Other loads:					
	- Total SKVA			- Lighting					
	- Total HP				- Computers				
					- Welding				
					- Non-linear				
				- Other					
FULL LOAD D	ΑΤΑ								
Voltage	Amps		kW	KVARS	P.F.				

i08524606

## Maintenance Interval Schedule

#### SMCS Code: 1000; 4450; 7500

Ensure that all safety information, warnings, and instructions are read and understood before any operation or any maintenance procedures are performed. The user is responsible for the performance of maintenance, including all adjustments, the use of proper lubricants, fluids, and filters. The user is also responsible for the replacement of components due to normal wear and aging. Failure to adhere to proper maintenance intervals and procedures may result in diminished performance of the product and/or accelerated wear of components. Use fuel consumption, service hours, or calendar time, WHICH EVER OCCURS FIRST, to determine the maintenance intervals. Products that operate in severe operating conditions may require more frequent maintenance. Before each consecutive interval is performed, all maintenance from the previous interval must be performed.

## When Required

"Battery - Recycle" 80
"Battery - Replace" 81
"Battery or Battery Cable - Disconnect"
" Coolant Sample (Level 2) - Obtain"
" Engine Air Cleaner Element - Replace" 100
" Engine Oil and Filter - Change" 109
" Generator - Dry" 120
" Generator Set - Test" 126
" Generator Set Alignment - Check" 127
" Generator Winding - Test"
" Overhaul Considerations"
" Stator Winding Temperature - Test" 148
"Throttle Control Valve - Check" 148
" Varistor - Inspect" 151

## Daily

" Coolant Level - Check" 8	36
" Drive Gearbox Oil Level - Check"	97
" Engine Air Cleaner Differential Pressure - Check" 10	00
" Engine Oil Filter Differential Pressure - Check" 10	)5

" Engine Oil Level - Check"	105
"Fuel Filter Differential Pressure - Check"	117
" Fumes Disposal Filter Differential Pressure - Check"	118
" Generator Bearing Temperature - Test/ Record"	125
" Generator Load - Check"	126
" Jacket Water Heater - Check"	134
" Power Factor - Check"	142
" Voltage and Frequency - Check"	152
" Walk-Around Inspection"	152

## **Initial 250 Service Hours**

" Valve Stem Projection - Measure/Record"	150
---	-----

## **Every 250 Service Hours**

" Coolant Sample (Level 1) - Obtain"	87
" Cooling System Supplemental Coolant Additive (SCA) - Test/Add"	89
" Drive Gearbox Oil Heater - Test"	97
" Drive Gearbox Oil Sample - Obtain"	98
" Engine Oil Sample - Obtain" 1	07
" Fumes Disposal Filter - Drain" 1	17
" Space Heater - Test" 1	43

## **Every 1000 Service Hours**

" Alternator - Inspect" 80	C
"Battery Electrolyte Level - Check" 8	1
"Belts - Inspect/Adjust/Replace"	2
" Crankshaft Vibration Damper - Inspect" 9	1
" Engine Crankcase Breather - Clean" 104	4
"Fumes Disposal Filter Element - Inspect" 118	3
"Hoses and Clamps - Inspect/Replace"	2
" Inlet Air System - Check"	4
"Water Pump - Inspect"	4

## **Every 2000 Service Hours**

" Flexible Coupling (Rubber) - Inspect"	
" Gas Filter Condensation - Drain"	119

"Generator Bearing - Lubricate"	124
"Generator Set Vibration - Inspect"	127
" Stator Lead - Check"	148
" Valve Stem Projection - Measure/Record"	150

## **Every 3000 Service Hours**

" Spark Plugs -	Inspect/Adjust/Replace"	. 144
-----------------	-------------------------	-------

## **Every 4000 Service Hours**

"Crankcase Blowby - Test/Record"
" Cylinder Pressure - Test/Record"
" Drive Gearbox Oil - Change" 94
" Drive Gearbox Oil Filter - Clean/Inspect" 95
" Engine Mounts - Inspect"
" Engine Protective Devices - Check" 112
" Engine Valve Lash and Bridge - Check" 114
" Flexible Coupling (Silicone Compression) - Inspect"
" Ignition System Timing - Check/Adjust" 133
" Nitrogen Oxide Sensor - Calibrate"
" Starting Motor - Inspect"

## **Every 8000 Service Hours**

"Coolant Temperature Regulator - Replace" 8	39
" Drive Gearbox Oil Filter - Replace"	96
" Drive Gearbox Sump Oil Screen - Inspect/ Clean"	99
" Engine Speed/Timing Sensor - Clean/ Inspect"	13
" Generator Bearing - Inspect"	22
"Generator Winding Insulation - Test" 12	29

"Rotating Rectifier - Check"		2
------------------------------	--	---

## **Every 10 000 Service Hours**

"Nitrogen Oxide Sensor - Replace" 1	134
-------------------------------------	-----

## Between 12 000 and 16 000 Service Hours

" Engine Coolant Diverter Valve - Inspect" ...... 103

## Between 18 000 and 22 000 Service Hours

" Ignition Transformer - Replace"	133
" Overhaul (Top End)"	138
"Turbocharger - Inspect"	149

## Every 24 000 Service Hours or 3 Years

" Coolant (NGEC) - Change"	83
----------------------------	----

## Between 35 000 and 45 000 Service Hours

" Overhaul (In-Frame)"..... 135

## Between 70 000 and 90 000 Service Hours

" Overhaul (Major)"..... 137

Attachment D Site Location Aerial Map



Figure D-1: Aerial Map Showing Site Location NAD 83

Attachment E Facility Process Description

## **Facility Process Description**

Presbyterian Healthcare Services (PHS) Energy Center provides steam from the four existing facility boilers (Units #3 - 6) as comfort heating for the Presbyterian hospital. The facility also consists of three emergency generators (Units #1, #2, #7) to provide electrical power against the loss of commercial line power.

Presently, the boilers are permitted to each operate 8,760 hours per year. With this significant permit revision, the boilers will be limited to only three of the four boilers operating at any one time. PHS will install new burners in Permit Units 3 and 4, and recalculate emission rate of Permit Unit 6 per the manufacturer's guarantee emission rate for NOx of 30 PPM. No other change for Units 1, 2, 5, and 7 will be included in this significant permit revision.

With this significant permit revision, PHS will be adding to the Energy Center installation of a new Caterpillar (CAT) Model G3516H Natural Gas Cogeneration (CoGen) Package (Unit #8). The CoGen will produce electricity and steam (heat) for the new hospital building under construction. The package includes a G3516H natural gas engine, SR4B generator, and a Superior Boiler heat recovery steam generator (HRSG). All regulated emissions are generated by the G3516H natural gas engine. CAT rates the engine brake horsepower (BHP) for the CoGen at 2,763. The installation of the CoGen will include additional building construction to accommodate the new CoGen. The CoGen will be installed with an oxidation catalyst to control carbon monoxide (CO), volatile organic compounds (VOC), and formaldehyde (CH<sub>2</sub>O). The CoGen will be permitted to allow 8,760 hours of operation per year.

## Attachment F

## **Regulatory Applicability Determination**

The following is a list of city and federal regulations that may or may not be applicable to PHS

#### Albuquerque/Bernalillo County Regulations

### **20.11.1 NMAC– General Provisions:** Applicable to PHS

Requirement: Compliance with ambient air quality standards.

Compliance: Compliance with 20.11.8 NMAC is compliance with this regulation.

### 20.11.2 NMAC– Permit Fees: Applicable to PHS

Requirement: A one-time permit application fee will be assessed by the Albuquerque/Bernalillo County Environmental Department.

Compliance: PHS will pay all required permit revision application fees applicable to their facility.

#### 20.11.5 NMAC- Visible Air Contaminants: Applicable to PHS

Requirement: Places limits of 20 percent opacity on stationary combustion equipment.

Compliance: PHS will perform any required opacity observations using Method 9 and/or Method 22 with certified opacity observers.

#### 20.11.8 NMAC- Ambient Air Quality Standards: Applicable to PHS

Requirement: Compliance with all federal, state and local ambient air quality standards.

Compliance: PHS's Energy Center demonstrated compliance by performing and submitting dispersion modeling analysis for applicable pollutants per Albuquerque/ Bernalillo County and New Mexico State Environmental Department's modeling guidelines.

#### 20.11.20 NMAC- Airborne Particulate Matter: Applicable to PHS

Requirement: Requires the facility to obtain a permit prior to start of surface disturbances.

Compliance: PHS will apply for a 20.11.20 NMAC permit prior to the start of surface disturbances.

#### 20.11.41 NMAC– Authority to Construct: Applicable to PHS

Requirement: Requires the facility to obtain a permit prior to start of construction.

Compliance: PHS is applying for a new 20.11.41 NMAC permit with this application.

#### 20.11.49 NMAC– Excess Emissions: Applicable to PHS

Requirement: To implement requirements for the reporting of excess emissions and establish affirmative defense provisions for facility owners and operators for excess emissions.

Compliance: PHS will report all excess emissions following 20.11.49 NMAC guidelines.

#### 20.11.63 NMAC- New Source Performance Standards: Applicable to PHS

Requirement: Adoption of all federal 40 CFR Part 60 new source performance standards.

Compliance: PHS will comply with all applicable 40 CFR Part 60 NSPS that have been identified for this facility. For this facility, 40 CFR Part 60 Subpart Db, IIII, and JJJJ have been identified as applicable standards.

### **20.11.64 NMAC– Emission Standards for Hazardous Air Pollutants for Stationary Sources:** Applicable to PHS

Requirement: Adoption of all federal 40 CFR Part 61 and 63 National Emissions Standards for Hazardous Air Pollutants (HAPS).

Compliance: 40 CFR Part 63 Subpart ZZZZ has been identified as an applicable standard for Units #7 and #8.

### 20.11.66 NMAC- Process Equipment: Applicable to PHS

Requirement: The objective of this Part is to achieve attainment of regulatory air pollution standards and to minimize air pollution emissions.

Compliance: Except as otherwise provided in this section, PHS shall not cause or allow the emission of particulate matter to the atmosphere from process equipment in any one hour in total quantities in excess of the amount shown in 20.11.66.18 NMAC Table 1.

### 20.11.90 NMAC- Administration, Enforcement, Inspection: Applicable to PHS

Requirement: General requirement on record keeping and data submission. PHS will notify the bureau regarding periods of excess emissions along with the cause(s) of the excess emissions and actions taken to minimize the duration and avoid recurrence.

Compliance: It is expected that specific record keeping and data submission requirements will be specified in the 20.11.41 NMAC permit issued to PHS. It is expected the 20.11.41 NMAC permit issued to PHS will contain specific methods for determining compliance with each specific emission limitation. PHS's Energy Center will report any periods of excess emissions as required by specific 20.11.90 NMAC provisions.

### **Federal Regulations**

#### 40 CFR 50 - National Ambient Air Quality Standards: Applicable to PHS

Requirement: Compliance with federal ambient air quality standards.

Compliance: PHS's Energy Center will demonstrate compliance by performing and submitting dispersion modeling analysis for applicable pollutants per the Albuquerque/ Bernalillo County and New Mexico State Environmental Department's modeling guidelines.

## **40 CFR 60 Dc – NSPS Standards of Performance for Small Industrial-Commercial-Institutional Stream Generating Units:** Applicable to PHS

Requirement: For any affected facility to which this subpart applies is each steam generating unit for which construction, modification, or reconstruction is commenced after June 9, 1989 and that has a maximum design heat input capacity of 100 million Btu per hour of less, but greater than or equal to 10 million Btu per hour. A steam generating unit is defined as a device that combusts any fuel and produces steam or heats water or any other heat transfer medium.

Compliance: Unit **#6** is subject to NSPS 40 CFR 60 Subpart Dc and shall comply with all applicable requirements of 40 CFR Part 60 Subparts A and Dc.

## **40 CFR 60 Kb – NSPS Standards of Performance for Volatile Liquid Storage Vessels:** Not applicable to PHS

Requirement: Regulation applies to each storage vessel with a capacity greater than or equal to 75 cubic meters (m<sup>3</sup>) that is used to store volatile organic liquids (VOL) for which construction, reconstruction, or modification is commenced after July 23, 1984

Compliance: PHS has two underground 30,000 gallon (113.6  $\text{m}^3$  each) volatile liquid storage vessels each greater than 75  $\text{m}^3$  will, but with a vapor pressure less than 15.0 kPa, so neither are applicable to 40 CFR 60 Kb.

### **40 CFR 60 IIII – NSPS Standards of Performance for Stationary Compression Ignition Internal Combustion Engine:** Applicable to PHS

Requirement: The provisions of this subpart are applicable to manufacturers, owners, and operators of stationary compression ignition (CI) internal combustion engines (ICE).
Compliance: Unit #7 is applicable to Subpart IIII as an emergency stationary ICE. Pursuant to 40 CFR 60 Subpart IIII §60.4211(f), Unit #7 shall be limited to 100 hours per year of maintenance checks and readiness testing. Unit #7 may operate up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for the facility to supply power to an electric grid or otherwise supply non-emergency power as part of a financial arrangement with another entity. Routine or non-emergency operation of the unit or operation for any other purposes, except as stated above, shall be a violation of this permit.

#### **40 CFR 60 JJJJ – NSPS Standards of Performance for Stationary Compression Ignition Internal Combustion Engine:** Applicable to PHS

Requirement: The provisions of this subpart are applicable to manufacturers, owners, and operators of stationary spark ignition (SI) internal combustion engines (ICE).

Compliance: Unit #8 is applicable to NSPS Subpart JJJJ. This rule does apply to the 2,763 bhp Caterpillar G3516H engine because the maximum engine power is greater than 500 HP and the engine was manufactured on or after 07/01/08 (§60.4230(a)(4)(i)). Requirements include NOx, CO and VOC emission limits (§60.4233(e)); engine maintenance (§60.4243(b)(2)(ii)); performance testing (§60.4244(a-d)); and notification and recordkeeping (§60.4245).

#### **Emission Limits**

60.4233(e) Unit #8 must meet a nitrogen oxides (NO<sub>X</sub>) emission standard of 1.0 grams per HP-hour (g/HP-hr), a CO emission standard of 2.0 g/HP-hr, and a volatile organic compounds (VOC) emission standard of 0.7 g/HP-hr,

#### **Maintenance Requirements**

Per §60.4243(b)(2)(ii) Unit #8 must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, an initial performance test must be conducted for Unit #8 within 1 year of engine startup, with subsequent performance testing conducted every 8,760 hours or 3 years, whichever comes first, thereafter to demonstrate compliance.

#### **Performance Testing Requirements**

Per §60.4244(a-d) for Unit #8 each performance test must be conducted within 10 percent of 100 percent peak (or the highest achievable) load and according to the requirements in § 60.8 and under the specific conditions that are specified by Subpart JJJJ Table 2.

#### **Recordkeeping Requirements**

Per 60.4245 (a)(1-4) Owners and operators of all stationary SI ICE must keep records of the information in paragraphs (a)(1) through (4) of this section .

## **40 CFR 63 JJJJJJ – National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources:** Not Applicable to PHS

Requirement: You are subject to this subpart if you own or operate an industrial, commercial, or institutional boiler as defined in §63.11237 that is located at, or is part of, an area source of hazardous air pollutants (HAP), as defined in §63.2, except as specified in §63.11195.

Compliance: Units #3, 4, and 6 are located at an area source of hazardous air pollutants (HAPs) as defined by 40 CFR 63 Subpart A §63.2. Units #3, 4, and 6 are defined as a "gas-fired boiler" in accordance with 40 CFR 63 Subpart JJJJJJ §63.11237, since the unit operates 48 hours per calendar year or less firing liquid fuel, it is not currently subject to the NESHAP. If Units #3, 4, or 6 exceed 48 hours per calendar year firing liquid fuel, then the unit becomes an affected source that will be subject to 40 CFR 63 Subpart JJJJJJ.

# **40 CFR 63 ZZZZ – National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines:** Applicable to PHS

Requirement: Facilities are subject to this subpart if they own or operate a stationary RICE, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

Compliance: Unit #7 is subject to National Emissions Standard for Hazardous Air Pollutants (NESHAP) found in 40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Source Category: Stationary Reciprocating Internal Combustion Engines apply and this facility shall comply with the specific requirements found in this subpart as well as the general requirements of 40 CFR 63 Subpart A - General Provisions. The permittee shall comply with the specific requirements of subpart ZZZZ applicable to new engines.

Unit #8 is subject to 40 CFR 63 Subpart ZZZZ under §63.6590(c). Since Unit #8 has to meet the requirements of 40 CFR 40 Subpart JJJJ, no applicable requirements under 40 CFR 63 Subpart ZZZZ apply.

Attachment G Dispersion Modeling Summary

## DISPERSION MODEL REPORT FOR PRESBYTERIAN HEALTHCARE SERVICES ENERGY CENTER PERMIT #0273-M3 REVISION APPICATION

Albuquerque, New Mexico

### PREPARED FOR PRESBYTERIAN HEALTHCARE SERVICES

January 28, 2022

Prepared by

Montrose Air Quality Services, LLC



#### CONTENTS

TABLE OF CONTENTS	PAGE
1.0 INTRODUCTION	1
2.0 DISPERSION MODELING PROTOCOL	5
2.1 DISPERSION MODEL SELECTION	7
2.2 BUILDING WAKE EFFECTS	7
2.3 METEOROLOGICAL DATA	9
2.4 RECEPTORS AND TOPOGRAPHY	9
2.5 MODELED EMISSION SOURCES INPUTS	10
2.6 PARTICLE SIZE DISTRIBUTION	
2.7 NO <sub>2</sub> DISPERSION MODELING ANALYSIS	
2.8 PM <sub>2.5</sub> SECONDARY EMISSIONS MODELING	13
2.9 AMBIENT MODELING BACKGROUND	14
3.0 MODEL SUMMARY	17
3.1 SIGNIFICANT IMPACT LEVEL (SILs) MODELING ANALYSIS	19
3.2 CUMULATIVE IMPACT ANALYSIS (CIA) MODEL RESULTS	19
3.2.1 NO <sub>2</sub> Cumulative Impact Analysis Modeling Results	
3.2.2 SO <sub>2</sub> Cumulative Impact Analysis Modeling Results	
3.2.3 PM <sub>2.5</sub> Direct and Secondary Formation CIA Modeling Results	
3.2.4 PM <sub>10</sub> Cumulative Impact Analysis Modeling Results	

# FIGURESPAGEFIGURE 1 PHS Energy Center Stack Location3FIGURE 2 PHS Energy Center Location and Surrounding Area4FIGURE 3 Nearby Buildings Included in the Model Analysis8FIGURE 4 Aerial Map of NO2 Highest 8<sup>th</sup> High 1 Hour Model Result ( $\mu$ g/m<sup>3</sup>)22FIGURE 5 Aerial Map of NO2 Annual Average Model Result ( $\mu$ g/m<sup>3</sup>)23FIGURE 6 Aerial Map of SO2 Highest 4<sup>th</sup> High 1 Hour Model Result ( $\mu$ g/m<sup>3</sup>)25FIGURE 7 Aerial Map of PM2.5 Highest 8<sup>th</sup> High 24-Hour Model Result ( $\mu$ g/m<sup>3</sup>)28FIGURE 8 Aerial Map of PM2.5 Annual Average Model Result ( $\mu$ g/m<sup>3</sup>)29FIGURE 9 Aerial Map of PM10 Highest 2<sup>nd</sup> High 24-Hour Model Result ( $\mu$ g/m<sup>3</sup>)31

TABLES   PA	AGE
TABLE 1 National and New Mexico Ambient Air Quality Standards	6
TABLE 2 Standards for Which Modeling Is Not Required by NMED AQB	6
TABLE 3 Model Inputs for Point Sources at the PHS Energy Center – NO <sub>X</sub> , CO, SO <sub>2</sub> and PM	[10
TABLE 4 Monitored Seasonal NO <sub>2</sub> Background $-3^{rd}$ Highest Hourly $\mu g/m^3$	16
TABLE 5 Summary of Air Dispersion Modeling Results below SILs	19
TABLE 6 Standards for Which Modeling Is Not Required	19
TABLE 7 Summary of CIA Modeling Results	20
TABLE 8 NO2 CIA Model Results	21
TABLE 9 SO2 CIA Model Results	23
TABLE 10 PM2.5 CIA Model Results	26
TABLE 11 PM10 CIA Model Results	29

#### **1.0 INTRODUCTION**

This dispersion modeling analysis will be conducted by Montrose Air Quality Service, LLC (Montrose) on behalf of Presbyterian Healthcare Services (PHS), to evaluate ambient air quality impacts from a new Caterpillar Model G3516H Natural Gas Cogeneration (CoGen) Package to be included as a permitted emission source to Permit #0273-M3-1TR. The location for the new CoGen will be in the expanded Energy Center at 1002 Silver Ave SE. The UTM coordinates of the Energy Center is; 350,835 meters E, 3,883,175 meters N, Zone 13, NAD 83. The objective of this evaluation is to determine whether ambient air concentrations from the maximum operation of the proposed CoGen for nitrogen dioxide (NO<sub>2</sub>), carbon monoxide (CO), sulfur dioxide (SO<sub>2</sub>), and particulate matter; both 10 microns or less (PM<sub>10</sub>) and 2.5 microns or less (PM<sub>2.5</sub>); are below Class II federal and state ambient air quality standards (NAAQS and NMAAQS) found in 40 CFR Part 50 and the City of Albuquerque/Bernalillo County Health Division (AEHD) air quality regulation 20.11.8 NMAC, respectively.

The dispersion modeling will be conducted using the American Meteorological Society/Environmental Protection Agency Regulatory Model Improvement Committee Dispersion Model (AERMOD), *Version 21112*. This model is recommended by EPA for determining Class II impacts within 50 km of the source being assessed. Additionally, AERMOD was developed to handle complex terrain. In this analysis, AERMOD will be used to estimate pollutant ambient air concentrations from the all existing and new PHS Energy Center emission sources. Montrose employs the general modeling procedures outlined in "Permit Modeling Guidelines, Albuquerque Environmental Health Department", revised 10/10/2019, "New Mexico Air Pollution Control Bureau, Dispersion Modeling Guidelines", revised 10/26/2020, and the most up to date EPA's *Guideline on Air Quality Models*.

With this permit modification, PHS will install the CoGen plant to produce electricity and steam (heat) for the new hospital wing building under construction. Presently, the permit for the Energy Center included four (4) steam boilers and three (3) emergency generators. In addition to installation of the CoGen, PHS will be installing new and more efficient burners on steam boilers 1 and 2 (Permit Units 3 and 4). For steam boiler 4 (Permit Unit 6), the NO<sub>X</sub> emission rate will be recalculated using the manufacturer's PPM guarantee of 30. The revised emission rates will be included in the permit modification application.

Three of the four boilers are allowed to combust both natural gas or #2 diesel, while the other can only combust natural gas. Per Permit #0273-M3-1TR Condition I.1.d.viii, Units #3, 4, and 6 are allowed to operate 48 hours per year combusting #2 diesel. Over the last 5 years the total hours combusting #2 diesel is 17.5 hours for Unit 4 and 5 hours for Unit 6 (see Attachment A). Because of the limited time the facility combusts #2 diesel, all modeled emission rates from the boiler will be based on combusting natural gas.

For the boilers modeled exhaust parameters, the boiler manufacturers were contacted and the manufacturer provided the following information; stack exhaust temperature at maximum and exhaust flowrate at maximum (see Attachment B). Stack height and stack diameter were determined by site inspection.

The three (3) emergency generators included in Permit #0273-M3-1TR will not be included in the dispersion modeling analysis, because these sources are intermittent. Emergency generators, with exception of loss of generating power, are tested monthly. Testing takes less than an hour per engine, so total testing hours is approximately 12 hours per year per emergency generator.

Presently, the boilers are allowed to operate 8760 hours each. For this permit modification, PHS will restrict the use of the boilers to only three boilers operating under maximum conditions at any one time for 8760 hours per year. This requested permit change will add additional permit conditions to the present operation of the boilers, recordkeeping and reporting.

With four existing boilers, there are four combinations of three boilers operating at any one time. The dispersion model analysis will be run for these 4 "Model Group" sources. To present these scenarios, each boiler combination will be modeled with maximum operation of the CoGen, applicable neighboring sources, and representative background.

Figure 1 below shows the PHS Energy Center and location of the existing permitted boiler stacks and proposed CoGen stack. Figure 2 shows the PHS Energy Center, PHS Energy Center restricted boundary, and surrounding area. Fencing around the PHS Energy Center and the PHS Energy Center building will be used as the modeling boundary. The fenced area is restricted to PHS employees only, specifically the PHS Energy Center employees or authorized contractors.

PHS will model any additional neighboring sources identified by the AEHD ADP Modeling Section. Initial neighboring source proposed to include in the modeling is the University of New Mexico's Ford Energy Center (1643-M1), University of New Mexico's Steam Plant (1601-M1-RV1), Lovelace Medical Center (1509-M2-1AR), NM Scientific Labs (2165-M1-RV1), WR-AAT (0051-M1-3TR), Clean Energy (0649-RV1), Ameripride (1518-M1), and US Transport (1523-M1-3AR).



FIGURE 1: PHS Energy Center Stack Locations



FIGURE 2: PHS Energy Center Location and Surrounding Area

#### 2.0 DISPERSION MODELING PROTOCOL

This section identifies the technical approach and dispersion model inputs that will be used for the Class II federal and State ambient air quality standards for this permit application. AEHD AQP requires that all applicable criteria pollutant emissions be modeled using the most recent versions of US EPA's approved models and be compared with National Ambient Air Quality Standards (NAAQS), and New Mexico Ambient Air Quality Standards (NMAAQS). Table 1 shows the NAAQS and NMAAQS that the source's ambient impacts must meet in order to demonstrate compliance. Table 1 also lists the Class II Significant Impact Levels (SILs) which are used to assess whether a source has a significant impact at downwind receptors.

The dispersion modeling analysis will be performed to estimate concentrations resulting from the maximum permitted operation of the PHS Energy Center sources using the proposed maximum permitted emission rates while specified emission sources are operating. The modeling will determine the maximum off-site concentrations for NO<sub>2</sub>, CO, SO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub>, for comparison with modeling significance levels, national/New Mexico/Bernalillo County ambient air quality standards (AAQS). For this modeling analysis, particulate emissions from PHS sources assumes  $PM = PM_{10} = PM_{2.5}$  are equal. The modeling will follow the guidance and protocols outlined in the "Permit Modeling Guidelines, Albuquerque Environmental Health Department", revised 10/10/2019, "New Mexico Air Pollution Control Bureau, Dispersion Modeling Guidelines", revised 01/01/2019, and the most up to date EPA's *Guideline on Air Quality Models*.

Initial radius of impact (ROI) modeling will be performed for all PHS Energy Center sources only to determine pollutants and averaging periods that exceed significant impact levels (SILs). If initial modeling for any pollutant and averaging period exceeds SILs, then cumulative modeling will be performed for those pollutants and averaging periods. The cumulative impacts model will include all receptors for which the ROI model indicates that the SILs are exceeded and will include any identified neighboring emission sources and will incorporate background ambient concentrations. Table 1 lists the SILs, NAAQS and NMAAQS for each pollutant averaging period. Table 2 lists ambient air quality standards for which modeling is not required by NMED AQB, when an approved surrogate standard is modeled.

Pollutant	Avg. Period	Sig. Lev. (µg/m <sup>3</sup> )	Class I Sig. Lev. (µg/m <sup>3</sup> )	NAAQS	NMAAQS	PSD Increment Class I	PSD Increment Class II
60	8-hour	500		9,000 ppb <sup>(1)</sup>	8,700 ppb <sup>(2)</sup>		
0	1-hour	2,000		35,000 ppb <sup>(1)</sup>	13,100 ppb <sup>(2)</sup>		
	annual	1.0	0.1	53 ppb <sup>(3)</sup>	50 ppb <sup>(2)</sup>	2.5 µg/m <sup>3</sup>	25 µg/m <sup>3</sup>
NO <sub>2</sub>	24-hour	5.0			100 ppb <sup>(2)</sup>		
	1-hour	7.52		100 ppb <sup>(4)</sup>			
DM	annual	0.2	0.05	$12 \ \mu g/m^{3(5)}$		$1 \ \mu g/m^3$	$4 \ \mu g/m^3$
PM <sub>2.5</sub>	24-hour	1.2	0.27	$35 \ \mu g/m^{3(6)}$		2 µg/m <sup>3</sup>	9 μg/m <sup>3</sup>
DM	annual	1.0	0.2			$4 \ \mu g/m^3$	$17 \ \mu g/m^3$
$PM_{10}$	24-hour	5.0	0.3	$150 \ \mu g/m^{3(7)}$		8 μg/m <sup>3</sup>	30 µg/m <sup>3</sup>
	annual	1.0	0.1		20 ppb <sup>(2)</sup>	$2 \ \mu g/m^3$	20 µg/m <sup>3</sup>
50	24-hour	5.0	0.2		100 ppb <sup>(2)</sup>	5 µg/m <sup>3</sup>	91 µg/m <sup>3</sup>
$50_2$	3-hour	25.0	1.0	500 ppb <sup>(1)</sup>		25 µg/m <sup>3</sup>	$512 \ \mu g/m^3$
	1-hour	7.8		75 ppb <sup>(8)</sup>			

 TABLE 1: National and New Mexico Ambient Air Quality Standard Summary

Standards converted from ppb to  $\mu g/m^3$  use a reference temperature of 25° C and a reference pressure of 760 millimeters of mercury.

(1) Not to be exceeded more than once each year.

(2) Not to be exceeded.

(3) Annual mean.

(4) 98th percentile of 1-hour daily maximum concentrations, averaged over 3 years.

(5) Annual mean, averaged over 3 years.

(6) 98th percentile of 24-hour daily maximum concentrations, averaged over 3 years.

(7) Not to be exceeded more than once per year on average over 3 years.

(8) 99th percentile of 1-hour daily maximum concentrations, averaged over 3 years.

Standard not Modeled	Surrogate that Demonstrates Compliance
CO 8-hour NAAQS	CO 8-hour NMAAQS
CO 1-hour NAAQS	CO 1-hour NMAAQS
NO2 annual NAAQS	NO2 annual NMAAQS
NO2 24-hour NMAAQS	NO2 1-hour NAAQS
O3 8-hour	Regional modeling
SO <sub>2</sub> annual NMAAQS	SO <sub>2</sub> 1-hour NAAQS
SO <sub>2</sub> 24-hour NMAAQS	SO <sub>2</sub> 1-hour NAAQS
SO <sub>2</sub> 3-hour NAAQS	SO <sub>2</sub> 1-hour NAAQS

#### **2.1 DISPERSION MODEL SELECTION**

The dispersion modeling will be conducted using the American Meteorological Society/Environmental Protection Agency Regulatory Model Improvement Committee Dispersion Model (AERMOD), *Version 21112*. This model is recommended by EPA for determining Class II impacts within 50 km of the source being assessed. Additionally, AERMOD was developed to handle complex terrain. In this analysis, AERMOD will be used to estimate pollutant ambient air concentrations for NO<sub>2</sub>, CO, SO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub>, from the modified PHS Energy Center plant emission sources.

AERMOD is a Gaussian plume dispersion model that is based on planetary boundary layer principles for characterizing atmospheric stability. The model evaluates the non-Gaussian vertical behavior of plumes during convective conditions with the probability density function and the superposition of several Gaussian plumes. The AERMOD modeling system has three components: AERMAP, AERMET, and AERMOD. AERMAP is the terrain preprocessor program. AERMET is the meteorological data preprocessor. AERMOD includes the dispersion modeling algorithms and was developed to handle simple and complex terrain issues using improved algorithms. AERMOD uses the dividing streamline concept to address plume interactions with elevated terrain. AERMOD will be run using all the regulatory default options.

#### Urban or Rural

The dispersion modeling meteorological data set was created using rural attributes, but because the meteorological data uses NWS data and not site-specific data the use of this meteorological data for AERMOD urban mode is acceptable. While a large area surrounding PHS Energy Center is low level housing with trees, the PHS hospital structures supported by the Energy Center, nearby freeway, and the proximity of downtown Albuquerque should be considered a potential for urban heat island influence across the full modeling domain. To account for the dispersive nature of the "convective-like" boundary layer that forms during nighttime conditions due to the urban heat island effect, AERMOD enhances the turbulence for urban nighttime conditions over that which is expected in the adjacent rural, stable boundary layer, and also defines an urban boundary layer height to account for limited mixing that may occur under these conditions. For this modeling analysis, the Urban mode will be used with the July 1, 2019 Albuquerque population input of 560,513 (https://www.census.gov/quickfacts/albuquerquecitynewmexico) and default surface roughness height of 1.

#### **2.2 BUILDING WAKE EFFECTS**

Buildings are located at the site that will impact plume downwash effects on the PHS Energy Center sources. These buildings located near point sources will be included in building downwash calculations. Figure 3 shows proposed buildings and location to the Energy Center.



FIGURE 3: Nearby Buildings Included in the Model Analysis

#### 2.3 METEOROLOGICAL DATA

The meteorological data input file to be used in this dispersion modeling analysis is Albuquerque met data covering years 2014 through 2018 (AERMET *Version 19191* dated 01/31/2020) available from the AEHD AQP.

#### 2.4 RECEPTORS AND TOPOGRAPHY

Modeling will be completed using as many receptor locations as required to ensure that the maximum estimated impacts are identified. ROI modeling will be performed with receptors within 15 kilometers of the model boundary. Because of the nature of the emissions from the site, it is expected the maximum modeled concentrations will be on or near the site's fenceline.

The refined receptor grid will include receptors located at 10-meter spacing from the facility boundary out to 100 meters; 25-meter spacing from 100 meters out to 400 meters; 50-meter spacing from 400 meters out to 500 meters; 100-meter spacing from 500 meters out to 1,000 meters; 250-meter spacing from 1,000 meters out to 3,000 meters; and 500-meter spacing from 3,000 meters out to 5,000 meters, and 1000-meter spacing from 5,000 meters out to 15,000 meters. Fenceline receptor spacing will be 10 meters. Fenceline receptors are located at the fence that surrounds the Energy Center employee parking lot and along the north and west sides of the Energy Center where the public may walk or drive.

For elevate public locations, both PHS parking garages, flagpole receptors will be used surrounding each parking garage open level height, plus the top of the parking garages. The flagpole height matches the height above the base elevation of the parking structure to the various parking levels opening in the side of each parking structure building.

For the I-40 elevated freeway located next to the Energy Center, additional receptors are placed down the center of northbound lane and adjusted using flagpole receptors that determine the concentration at these receptors by adding to the NED determined elevation height to the elevation at the 15-foot height from base elevation of the PHS Energy Center, based on visual observations of freeway to Energy Center height. For all PHS and neighboring buildings, with the exception of the two PHS parking structures and Rachel's Courtyard on the 6<sup>th</sup> floor of the main hospital, the public will be restricted, so receptors that fall onto the top of buildings will be deleted.

All model receptors will be preprocessed using the AERMAP software (*Version 18081*) associated with AERMOD. The AERMAP software establishes a base elevation and a height scale for each receptor location. The height scale is a measure of the receptor's location and base elevation and its relation to the terrain feature that has the greatest influence in dispersion for that receptor. AERMAP will be processed using U.S. Geological Survey (USGS) national elevation data (NED). Output from AERMAP will be used as input to the AERMOD runstream file for each model run.

#### 2.5 MODELED EMISSION SOURCES INPUTS

PHS presently operated 4 steam boilers under Permit #0273-M3-1TR. Each boiler is allowed to operate 8760 hours per year. For this permit modification, PHS will install a new CoGen and limit the boilers to operation of only three boilers at any one time. Emissions from exhaust stacks will be modeled as point sources. Model input parameters are based on actual release height, release diameter, release velocity or flow rate, and release temperature. PHS Energy Center boilers modeled stack releases are vertical and include raincaps. The new CoGen modeled stack release will be a vertical. Table 3 summarize the model inputs for the PHS Energy Center emission sources.

Source Description	Model ID	Stack Height (m)	Stack Temp. (K)	Exit Vel. (m/s)	Stack Dia. (m)	NOx Emission Rate (lb/hr)	CO Emission Rate (lb/hr)	SO2 Emission Rate (lb/hr)	PM Emission Rate (lb/hr)
PHS NG Boiler Unit 3	В3	11.2776	477.5944	8.403038	0.7112	1.46475	0.77423	0.04955	0.10044
PHS NG Boiler Unit 4	B4	11.2776	477.5944	8.403038	0.7112	1.46475	0.77423	0.04955	0.10044
PHS NG Boiler Unit 5	В5	11.2776	477.5944	6.601035	0.5080	1.00000	0.90000	0.01000	0.08000
PHS NG Boiler Unit 6	B6	11.2776	477.5944	13.364623	0.6096	1.05701	2.10000	0.02000	0.20000
PHS New CoGen	COGEN	14.9352	463.7056	19.670385	0.5080	6.09127	9.86786	0.03793	0.16123

TABLE 3: Summary of Model Inputs for Point Sources at the PHS Energy Center Plant – NOx, CO, SO2 and PM

#### 2.6 PARTICLE SIZE DISTRIBUTION

No particle size distribution will be included in the particulate modeling for either PHS or neighboring sources.

#### 2.7 NO<sub>2</sub> DISPERSION MODELING ANALYSIS

The AERMOD model predicts ground-level concentrations of any generic pollutant without chemical transformations. Thus, the modeled NO<sub>X</sub> emission rate will give ground-level modeled concentrations of NO<sub>X</sub>. NAAQS values are presented as NO<sub>2</sub>.

EPA has a three-tier approach to modeling NO<sub>2</sub> concentrations.

- Tier I total conversion, or all NOx = NO<sub>2</sub>
- Tier II Ambient Ratio Method 2 (ARM2)
- Tier III case-by-case detailed screening methods, such as Ozone Limiting Method (OLM) and Plume Volume Molar Ratio Method (PVMRM) and NO<sub>2</sub>/NO<sub>X</sub> in-stack ratio

Initial modeling will be performed using the Tier II methodology (ARM2). If these modeling iterations demonstrate that less conservative methods for determining 1-hour and annual NO<sub>2</sub> compliance would be needed for this project, then the ambient impact of 1-hour and annual NOx predicted by the model will use Tier III – OLM or PVMRM.

When using ARM2, two inputs can be selected in the model. For this modeling analysis, EPA default minimum and maximum ambient NO<sub>2</sub>/NO<sub>x</sub> ratios for the ambient air of 0.50 and 0.90, respectively, will be used. For OLM or PVMRM, three inputs can be selected in the model: the in-stack-ratio (ISR), the NO<sub>2</sub>/NO<sub>x</sub> equilibrium ratio for the ambient air, and the ambient ozone concentration. The ISR will be determined for each source or group of sources. The NO<sub>2</sub>/NO<sub>x</sub> equilibrium ratio will be the EPA default of 0.90. Ozone input is determined from monitored ozone data collected from Del Norte city monitoring station matching the modeled met years 2014 – 2018.

PVMRM is known to work best with relatively isolated sources, but it can potentially overestimate the NO-to-NO<sub>2</sub> conversion when plumes have significant overlap, as it can overestimate the amount of entrained ozone. OLM is somewhat less sophisticated than PVMRM as it does not estimate entrained ozone, but bases the NO-to-NO<sub>2</sub> conversion on the total amount of ozone present in the atmosphere. PHS Energy Center sources are located within a 50-foot area causing plume overlap. Since PVMRM is known for over estimation of the amount of entrained ozone for overlapping plumes, OLM modeling will be used for the PHS Energy Center NO2 1-Hour modeling analysis. For PHS Energy Center OLM modeling, the model will be run with all PHS Energy Center sources and all included neighbor sources combined into an OLM Group All (OLMGPALL) sources. This will limit the NO-to-NO<sub>2</sub> conversion for overlapping plumes.

To determine the ISR for each source, a search was performed for the PHS boilers and proposed CoGen. A document prepared by the California Air Pollution Control Officers Association

Prepared by Montrose Air Quality Services, LLC

(CAPCOA) released a guidance document named "Modeling Compliance of The Federal 1-Hour NO2 NAAQS", October 27, 2011. In an effort to provide data needed for modeling and to address issues noted in EPA's NO<sub>2</sub> guidance memoranda, the San Joaquin Valley APCD has started gathering data from internal and external resources and has compiled a NO<sub>2</sub>/NO<sub>X</sub> ratio for a variety of sources. The document's Appendix C is found in Attachment C. Based on this ISR summary, the ISR range for natural gas boilers is 0.00 to 0.1579 with the CAPCOA recommendation of 0.10. PHS proposes an ISR for the 4 natural gas boilers a conservative ISR of 0.20. Based on this ISR summary, the CAPCOA recommendation of 0.10. PHS proposes an ISR for the 4 natural gas IC engines (Lean Burn, CO Catalyst) is 0.00 to 0.3962 with the CAPCOA recommendation of 0.10. PHS proposes an ISR for the USR range for natural gas IC engines (Lean Burn, CO Catalyst) is 0.00 to 0.3962 with the CAPCOA recommendation of 0.10. PHS proposes an ISR for the CoGen a conservative 0.20. For neighboring sources, since the ISR has a diminishing impact on ambient NO<sub>2</sub>/NO<sub>X</sub> ratios as a plume is transported farther downwind due to mixing and reaction towards background ambient NO<sub>2</sub>/NO<sub>X</sub> ratios, neighboring sources within 1 kilometer of the site will use an ISR of 0.30 or available source specific ISR data. For Lovelace and UNM sources that combust natural gas the ISR used will be 0.20. For neighboring sources extended beyond 1 kilometer a default ISR of 0.20<sup>1</sup> will be used.

#### **Model Ozone Data**

For OLM or PVMRM, modeling of the project-generated 1-hour NO<sub>2</sub> concentrations requires use of ambient monitored ozone concentrations. This ozone data was provided by the AEHD AQP from the Del Norte monitoring station for the years 2014 - 2018. The Del Norte monitor best represents the PHS area consisting of mostly vehicle traffic emissions.

#### 2.8 PM<sub>2.5</sub> SECONDARY EMISSIONS MODELING

Particulate matter includes both "primary" PM, which is directly emitted into the air, and "secondary" PM, which forms in the atmosphere from chemical reactions involving primary gaseous emissions of precursor air contaminants. Primary PM consists of carbon (soot)—emitted from cars, trucks, heavy equipment, forest fires, and burning waste—and crustal material from unpaved roads, stone crushing, construction sites, and metallurgical operations. Secondary PM forms in the atmosphere from gases. Some of these reactions require sunlight and/or water vapor. Secondary PM includes:

- Sulfates formed from SO<sub>2</sub> emissions from power plants and industrial facilities;
- Nitrates formed from NO<sub>X</sub> emissions from cars, trucks, industrial facilities, and power plants; and
- Carbon formed from reactive organic gas (ROG or VOC) emissions from cars, trucks, industrial facilities, forest fires, and biogenic sources such as trees.

AERMOD does not account for secondary formation of  $PM_{2.5}$  for near-field modeling. Any secondary contribution of the PHS Energy Center source emissions is not explicitly accounted for in the model results. While representative background monitoring data for  $PM_{2.5}$  should adequately account for secondary contribution from existing background sources, the PHS

<sup>&</sup>lt;sup>1</sup> Technical support document (TSD) for NO2-related AERMOD modifications, EPA- 454/B-15-004, July 2015

assessment of their potential contribution to cumulative impacts as secondary PM<sub>2.5</sub> was performed based on guidance from the NMED Modeling Section and using prescribed equations. The permit application for PHS Energy Center emissions of precursors include:

- $NO_X 68.4$  tons per year (above SER)
- $SO_2 4.5$  tons per year (below SER)
- Volatile Organic Compounds (VOC) 12.3 tons per year (below SER)
- Particulate Matter with an aerodynamic diameter of 2.5 micron or less (PM<sub>2.5</sub>) 3.2 tons per year (below SER).

The  $PM_{2.5}$  secondary emission concentration analysis will follow EPA and NMED AQB guidelines. Following recent EPA guidelines for conversion of NO<sub>X</sub> and SO<sub>2</sub> emission rates to secondary  $PM_{2.5}$  emissions, PHS Energy Center emissions are compared to appropriate western MERPs values (NO<sub>X</sub> 24-Hr – 1155 tpy; NO<sub>X</sub> Annual – 3184 tpy; SO<sub>2</sub> 24-Hr – 225 tpy; SO<sub>2</sub> Annual – 2289 tpy). The following equation, found in NMED AQB modeling guidance document on MERPs, will be added to determine if secondary emission would cause violation with  $PM_{2.5}$  NAAQS.

 $PM_{2.5}$  annual = ((NO<sub>X</sub> emission rate (tpy)/3184 + (SO<sub>2</sub> emission rate (tpy)/2289)) x 0.2 µg/m<sup>3</sup>

PM<sub>2.5</sub> annual = ((68.4/3184) + (4.5/2289)) x 0.2  $\mu$ g/m<sup>3</sup> = 0.005  $\mu$ g/m<sup>3</sup>

 $PM_{2.5}$  24 hour = ((NO<sub>X</sub> emission rate (tpy)/1155 + (SO<sub>2</sub> emission rate (tpy)/225)) x 1.2 µg/m<sup>3</sup>

PM<sub>2.5</sub> 24 hour = ((68.4/1155) + (4.5/225)) x 1.2  $\mu$ g/m<sup>3</sup> = **0.10 \mug/m<sup>3</sup>** 

#### 2.9 AMBIENT MODELING BACKGROUND

Conservative ambient background concentrations, based on the South Valley Monitoring Station for CO, NO<sub>2</sub>, SO<sub>2</sub>, PM<sub>10</sub>, and PM<sub>2.5</sub> will be added to the dispersion modeling results and compared to the NAAQS and NMAAQS. Background concentrations were obtained from the AEHD AQP Modeling Section.

CO 1-hr:	2366 micrograms per cubic meter
CO 8-hr:	<b>1450</b> micrograms per cubic meter
NO <sub>2</sub> Annual:	30 micrograms per cubic meter
SO <sub>2</sub> 1-hr:	13.1 micrograms per cubic meter
PM <sub>10</sub> 24-hr:	42 micrograms per cubic meter
PM <sub>2.5</sub> 24-hr:	22 micrograms per cubic meter
PM <sub>2.5</sub> annual:	8.4 micrograms per cubic meter

#### NO2 1-hour Background data

 $NO_2$  1-hour background data was developed by the AEHD AQP based on the Tier 2 procedure found in EPA guidance documents<sup>2</sup> for determining background concentrations.

"Based on this guidance, we believe that an appropriate methodology for incorporating background concentrations in the cumulative impact assessment for the 1-hour  $NO_2$ standard would be to use multivear averages of the 98th-percentile of the available background concentrations by season and hour-of-day, excluding periods when the source in question is expected to impact the monitored concentration (which is only relevant for modified sources). For situations involving a significant mobile source component to the background monitored concentrations, inclusion of a day-of-week component to the temporal variability may also be appropriate. The rank associated with the 98thpercentile of daily maximum 1-hour values should be generally consistent with the number of "samples" within that distribution for each combination based on the temporal resolution but also account for the number of samples "ignored" in specifying the 98thpercentile based on the annual distribution. For example, Table 1 in Section 5 of Appendix S specifies the rank associated with the 98th-percentile value based on the annual number of days with valid data. Since the number of days per season will range from 90 to 92, Table 1 would indicate that the 2nd-highest value from the seasonal distribution should be used to represent the 98th-percentile. On the other hand, use of the 2nd-highest value for each season would effectively "ignore" only 4 values for the year rather than the 7 values "ignored" from the annual distribution. Balancing these considerations, we recommend that background values by season and hour-of-day used in this context should be based on the 3rd-highest value for each season and hour-of-day combination, whereas the 8thhighest value should be used if values vary by hour-of-day only. For more detailed temporal pairing, such as season by hour-of- day and day-of-week or month by hour-ofday, the 1st-highest values from the distribution for each temporal combination should be used."

The NO<sub>2</sub> background data was provided by the AEHD AQP Modeling Section and is presented below in Table 4.

<sup>&</sup>lt;sup>2</sup> Memo: "Additional Clarification Regarding Application of Appendix W Modeling Guidance for 1-hour N02 National Ambient Air Quality Standard" Tyler Fox, Leader, Air Quality Modeling Group, C439-01, dated March 1, 2011.

Hour	Winter	Spring	Summer	Fall
1	72.1	47.6	29.3	65.6
2	67.8	48.3	27.7	59.7
3	67.7	46.0	26.4	57.9
4	68.4	48.9	26.6	58.9
5	69.1	51.7	32.7	58.0
6	69.7	63.9	39.3	57.8
7	72.8	70.7	46.4	63.5
8	77.6	71.8	48.5	64.5
9	80.0	61.1	34.2	65.9
10	71.4	48.0	27.3	55.0
11	62.0	28.6	24.3	47.3
12	48.1	18.9	19.9	35.4
13	36.9	17.6	17.0	28.2
14	35.1	15.7	15.9	25.3
15	33.6	14.8	17.4	24.2
16	37.2	15.3	19.4	28.0
17	48.4	17.1	20.4	38.0
18	73.0	19.4	19.3	69.6
19	79.3	38.5	21.7	79.1
20	78.1	53.2	30.9	77.1
21	77.3	48.0	34.1	73.4
22	76.5	56.3	30.8	70.4
23	75.0	58.8	34.9	69.7
24	72.4	57.9	33.6	70.9

TABLE 4: Monitored Seasonal NO<sub>2</sub> Background – 3<sup>rd</sup> Highest Hourly µg/m<sup>3</sup>

#### **3.0 MODEL SUMMARY**

This section summarizes the model results, following the technical approach discussed in Section 2 of this report for Class II federal ambient air quality standards for this facility. Model results show for each criteria pollutant and applicable averaging periods for nitrogen dioxide (NO<sub>2</sub>), carbon monoxide (CO), sulfur dioxide (SO<sub>2</sub>), and particulate matter with aerodynamic diameter less than 10 micrometers (PM<sub>10</sub>) and particulate matter with aerodynamic diameter less than 2.5 micrometers (PM<sub>2.5</sub>), the installation of a new Caterpillar Model G3516H Natural Gas Cogeneration (CoGen) Package to be included as a permitted emission source to Permit #0273-M3-1TR does not contribute to an exceedance of the national/New Mexico ambient air quality standards (AAQS). The modeling followed the guidance and protocols outlined in the protocol found in Section 2 of this report, the modeling procedures outlined in "Permit Modeling Guidelines, Albuquerque Environmental Health Department", revised 10/26/2020, and the most up to date EPA's *Guideline on Air Quality Models*. As discussed in Section 2.1, because of the location of PHS Energy Center with relation to the main hospital and downtown Albuquerque, all modeling was performed using the "Urban" modeling option.

With this permit modification, PHS will install the CoGen plant to produce electricity and steam (heat) for the new hospital wing building under construction. Presently, the permit for the Energy Center included four (4) steam boilers and three (3) emergency generators. In addition to installation of the CoGen, PHS will be installing new and more efficient burners on steam boilers 1 and 2 (Permit Units 3 and 4). For steam boiler 4 (Permit Unit 6), the NO<sub>X</sub> emission rate will be recalculated using the manufacturer's PPM guarantee of 30. The revised emission rates will be included in the permit modification application.

Three of the four boilers are allowed to combust both natural gas or #2 diesel, while the other can only combust natural gas. Per Permit #0273-M3-1TR Condition I.1.d.viii, Units #3, 4, and 6 are allowed to operate 48 hours per year combusting #2 diesel. Over the last 5 years the total hours combusting #2 diesel is 17.5 hours for Unit 4 and 5 hours for Unit 6 (see Attachment A). Because of the limited time the facility combusts #2 diesel, all modeled emission rates from the boiler will be based on combusting natural gas.

For the expected boilers modeled exhaust parameters, the boiler manufacturers were contacted and the manufacturer provided the following information; stack exhaust temperature at maximum and exhaust flowrate at maximum (see Attachment B). Stack height and stack diameter were determined by site inspection.

The three (3) emergency generators included in Permit #0273-M3-1TR will not be included in the dispersion modeling analysis, because these sources are intermittent. Emergency generators, with exception of loss of generating power, are tested monthly. Testing takes less than an hour per engine, so total testing hours is approximately 12 hours per year per emergency generator.

Presently, the boilers are allowed to operate 8760 hours each. For this permit modification, PHS will restrict the use of the boilers to only three boilers operating under maximum conditions at any one time for 8760 hours per year. This requested permit change will add additional permit conditions to the present operation of the boilers, recordkeeping and reporting.

With four existing boilers, there are four combinations of three boilers operating at any one time. The dispersion model analysis will be run for these 4 "Model Group" sources. To present these scenarios, each boiler combination will be modeled with maximum operation of the CoGen, applicable neighboring sources, and representative background.

Neighboring source included in the modeling is the University of New Mexico's Ford Energy Center (1643-M1), Lovelace Medical Center (1509-M2-1AR), Clean Energy (0649-RV1), Ameripride (1518-M1), and US Transport (1523-M1-3AR). The information on these sources was provided by the city air quality dispersion modeling section.

#### 3.1 SIGNIFICANT IMPACT LEVEL (SILs) MODELING ANALYSIS

Significant impact level AERMOD dispersion modeling was completed for  $PM_{10}$ ,  $PM_{2.5}$ ,  $NO_X$ , CO, and  $SO_2$ . All significant impact models were run in terrain mode and building downwash with PHS modeled Energy Center emission sources only. Table 5 lists the results of the modeling for pollutant and averaging period that falls below the applicable SILs.

Parameter Maximum Modeled Concentration (µg/m <sup>3</sup> )		Significant Impact Level (µg/m³)	% of SIL
CO 1 Hr.	306	2000	15.3
CO 8 Hr.	219	500	43.8

**TABLE 5: Summary of Air Dispersion Modeling Results below SILs** 

For CO, the results show impacts below the NAAQS SILs for the 1-hour averaging period of 2000  $\mu$ g/m<sup>3</sup> and for the 8-hour averaging period of 500  $\mu$ g/m<sup>3</sup>, so no further CO modeling was performed.

#### **3.2 CUMULATIVE IMPACT ANALYSIS (CIA) MODEL RESULTS**

The following CIA dispersion models were used to show compliance with all applicable state and national AAQS. The list in Table 6 discussed which standards are the most stringent.

TIDEL OF Standards for Trimen Frodering 18 100 Required				
Standard not Modeled	Surrogate that Demonstrates Compliance			
NO2 annual NAAQS	NO2 annual NMAAQS			
NO <sub>2</sub> 24-hour NMAAQS	NO <sub>2</sub> 1-hour NAAQS			
SO2 annual NMAAQS	SO2 1-hour NAAQS			
SO2 24-hour NMAAQS	SO <sub>2</sub> 1-hour NAAQS			
SO <sub>2</sub> 3-hour NAAQS	SO <sub>2</sub> 1-hour NAAQS			

 TABLE 6: Standards for Which Modeling Is Not Required

The model results using the maximum operation for the maximum of each of the 4 "Model Group" operating scenarios at PHS Energy Center, significant neighboring sources, approved ambient background (see Section 2.9), and PM<sub>2.5</sub> secondary emissions (see Section 2.8) are summarized below in Table 7. Dispersion modeling analysis followed the modeling protocol outline in Section 2 of this report.

Approved Ambient Dackground, and for FW12.5 Secondary Emissions							
Parameter	Maximum PHS Modeled Concentration with Neighbors (µg/m <sup>3</sup> )	Significant Impact Level (µg/m³)	Maximum Modeled Concentration With Neighbor and Background (µg/m <sup>3</sup> )	Lowest Applicable Standard (µg/m <sup>3</sup> )	% of Standard		
NO <sub>2</sub> 1 Hr. 8 <sup>th</sup> highest 1-hour daily maximum	130.5	7.54	187.4	188.1	99.7		
NO <sub>2</sub> Annual	26.8	1.0	45.8	94.0	48.7		
SO <sub>2</sub> 1 Hr. 4 <sup>th</sup> highest 1-hour daily maximum	8.4	7.8	21.5	196.4	10.9		
PM <sub>2.5</sub> 24 Hr. High 8 <sup>th</sup> High	6.0	1.2	28.0	35	80.0		
PM <sub>2.5</sub> Annual	2.13	0.2	10.53	12	87.8		
PM <sub>10</sub> 24 Hr. High 6 <sup>th</sup> High	13.6	5	55.6	150	37.1		

## TABLE 7: Summary of CIA Modeling Results Including all Applicable Neighboring Sources, Approved Ambient Background, and for PM2.5 Secondary Emissions

Note: Background concentrations are found in Section 2.9 of the modeling protocol.  $PM_{2.5}$  secondary emission concentrations are found in Section 2.8 of the modeling protocol. Dispersion modeling inputs and settings are presented in Section 2.

#### 3.2.1 NO<sub>2</sub> Cumulative Impact Analysis Modeling Results

NO<sub>2</sub> modeling was performed with terrain elevations and building downwash for PHS Energy Center and neighboring sources. NO<sub>X</sub> emission rates represented the maximum hourly rate for PHS Energy Center modeled point sources and significant neighboring sources.

Dispersion modeling meteorology for this analysis included 5 years of data, 2014–2018 Albuquerque Meteorological data, was obtained from the AEHD AQP.

For NO<sub>2</sub> 1-hour modeling, the Tier 3 OLM approach found in Section 2.6 of this report was used for the analysis. For OLM, background ambient O<sub>3</sub> concentrations for the project area during the 2014-2018 meteorological data years was obtained from the Albuquerque Del Norte monitoring station.

The seasonal NO<sub>2</sub> background  $-3^{rd}$  highest hourly, 1-hour NO<sub>2</sub> background concentrations found in Section 2.9 of this report was added to the modeled results and compared to the lowest applicable ambient standard.

CIA dispersion modeling showed exceedance of the  $NO_2 8^{th}$  highest 1-hour daily maximum NAAQS. The exceedance was the result of modeled emissions near neighboring sources. For each of the receptors that showed an exceedance of the NAAQS, it was determine that the

contribution from PHS Energy Center sources were below the NO<sub>2</sub> 1-Hour SIL. For the 4 "Model Group" scenarios, where the contribution from PHS Energy Center sources were above the SIL, the 8<sup>th</sup> highest 1-hour daily maximum is near or on the Energy Center modeled fenceline with Boiler Units 3, 4, and 5 in operation.

For NO<sub>2</sub> annual modeling, the highest concentrations result where PHS Energy Center was a significant contributor occurred near the Lovelace Hospital on Martin Luther King with Boiler Units 3, 4, and 5 in operation.

Table 8 shows the NO<sub>2</sub> 1-Hour 8<sup>th</sup> highest 1-hour daily maximum and annual model results and locations where PHS Energy Center is above the SILs.

	PHS Modeled Concentration With Neighbor (µg/m <sup>3</sup> )	Modeled Concentration With Neighbor and Background (µg/m <sup>3</sup> )	Location UTMs E/N	
NO <sub>2</sub> 1 Hr. 8 <sup>th</sup> highest 1-hour daily maximum	130.5	187.4	350887.7	3883150.5
NO <sub>2</sub> Annual	26.8	45.8	350700.0	3883700.0

#### **TABLE 8: NO<sub>2</sub> CIA MODEL RESULTS**

Figures 4 and 5 shows an aerial map of the NO<sub>2</sub> 8<sup>th</sup> highest 1-hour daily maximum and annual average concentrations and the location of the maximum modeled concentrations which includes background where PHS Energy Center sources contribute above the NO<sub>2</sub> SIL.



Figure 4: Aerial Map of NO2 8<sup>th</sup> Highest 1-Hour Daily Maximum Model Results  $(\mu g/m^3)$ 



Figure 5: Aerial Map of NO2 Annual Average Model Results  $(\mu g/m^3)$ 

#### 3.2.2 SO<sub>2</sub> Cumulative Impact Analysis Modeling Results

SO<sub>2</sub> 1-hour modeling was performed with terrain elevations and building downwash for PHS Energy Center and neighboring sources. SO<sub>2</sub> emission rates represented the maximum hourly rate for PHS Energy Center proposed permitted point sources and significant neighboring sources.

Table 9 shows the SO<sub>2</sub> 4<sup>th</sup> highest 1-hour daily maximum model result and location.

#### TABLE 9: SO2 CIA MODEL RESULTS

	PHS Modeled Concentration (µg/m <sup>3</sup> )	Modeled Concentration With Neighbor and Background (µg/m <sup>3</sup> )	Location UTMs E/N	
SO <sub>2</sub> 1 Hr. 4 <sup>th</sup> highest 1-hour daily maximum	8.4	21.5	350824.7	3883189.0

For SO<sub>2</sub> 1-hour modeling, dispersion modeling meteorology for this analysis included 5 years of data, 2014 - 2018 Albuquerque Meteorological data, obtained from the AEHD AQP.

SO<sub>2</sub> 1-hour background concentration, found in Section 2.9 of this report, was added to the 4<sup>th</sup> highest 1 hour daily maximum modeled results and compared to the lowest applicable ambient standard.

CIA dispersion modeling showed the highest concentrations of the SO<sub>2</sub> 4<sup>th</sup> highest 1-hour daily maximum NAAQS on PHS Energy Center boundary with Boiler Units 3, 4, and 5 in operation.

Figure 6 shows an aerial map of the  $4^{th}$  highest 1-hour SO<sub>2</sub> daily maximum concentration and the location of the maximum modeled concentration including background where PHS Energy Center sources contribute above the 1-hour SO<sub>2</sub> SIL.



Figure 6: Aerial Map of SO<sub>2</sub> 1 Hour Model Results  $(\mu g/m^3)$ 

#### 3.2.3 PM<sub>2.5</sub> Direct and Secondary Formation CIA Modeling Results

Particulate matter includes both "primary" PM, which is directly emitted into the air, and "secondary" PM, which forms in the atmosphere from chemical reactions involving primary gaseous emissions of precursor air contaminants. Primary PM consists of carbon (soot)—emitted from cars, trucks, heavy equipment, forest fires, and burning waste—and crustal material from unpaved roads, stone crushing, construction sites, and metallurgical operations. Secondary PM forms in the atmosphere from gases. Some of these reactions require sunlight and/or water vapor. Secondary PM includes:

- Sulfates formed from SO<sub>2</sub> emissions from power plants and industrial facilities;
- Nitrates formed from NO<sub>X</sub> emissions from cars, trucks, industrial facilities, and power plants; and
- Carbon formed from reactive organic gas (ROG or VOC) emissions from cars, trucks, industrial facilities, forest fires, and biogenic sources such as trees.

AERMOD does not account for secondary formation of  $PM_{2.5}$  for near-field modeling. Any secondary contribution of the PHS Energy Center source emissions is not explicitly accounted for in the model results. While representative background monitoring data for  $PM_{2.5}$  should adequately account for secondary contribution from existing background sources, the PHS assessment of their potential contribution to cumulative impacts as secondary  $PM_{2.5}$  was performed based on guidance from the NMED Modeling Section and using prescribed equations. The permit application for PHS Energy Center emissions of precursors include:

- $NO_X 68.4$  tons per year (above SER)
- $SO_2 4.5$  tons per year (below SER)
- Volatile Organic Compounds (VOC) 12.3 tons per year (below SER)
- Particulate Matter with an aerodynamic diameter of 2.5 micron or less (PM<sub>2.5</sub>) 3.2 tons per year (below SER).

The PM<sub>2.5</sub> secondary emission concentration analysis will follow EPA and NMED AQB guidelines. Following recent EPA guidelines for conversion of NO<sub>X</sub> and SO<sub>2</sub> emission rates to secondary PM<sub>2.5</sub> emissions, PHS Energy Center emissions are compared to appropriate western MERPs values (NO<sub>X</sub> 24-Hr – 1155 tpy; NO<sub>X</sub> Annual – 3184 tpy; SO<sub>2</sub> 24-Hr – 225 tpy; SO<sub>2</sub> Annual – 2289 tpy). The following equation, found in NMED AQB modeling guidance document on MERPs, will be added to determine if secondary emission would cause violation with PM<sub>2.5</sub> NAAQS.

$$PM_{2.5}$$
 annual = ((NO<sub>X</sub> emission rate (tpy)/3184 + (SO<sub>2</sub> emission rate (tpy)/2289)) x 0.2 µg/m<sup>3</sup>

PM<sub>2.5</sub> annual = ((68.4/3184) + (4.5/2289)) x 0.2  $\mu$ g/m<sup>3</sup> = 0.005  $\mu$ g/m<sup>3</sup>

 $PM_{2.5}$  24 hour = ((NO<sub>X</sub> emission rate (tpy)/1155 + (SO<sub>2</sub> emission rate (tpy)/225)) x 1.2 µg/m<sup>3</sup>

PM<sub>2.5</sub> 24 hour = ((68.4/1155) + (4.5/225)) x 1.2  $\mu$ g/m<sup>3</sup> = **0.10 \mug/m<sup>3</sup>** 

Results of the secondary formation from the facility were added to the modeled value.

South Valley monitor representative annual and 24-hour  $PM_{2.5}$  background concentrations was added to the modeled results and compared to the lowest applicable ambient standard.

The annual average results show that significant direct "primary" PM<sub>2.5</sub> from PHS Energy Center sources combined with neighboring sources are located on the PHS Energy Center northern facility boundary with Boiler Units 4, 5, and 6 in operation.

The 24-hour average highest  $8^{th}$  high concentrations showed that significant direct "primary" PM<sub>2.5</sub> from PHS Energy Center sources combined with neighboring sources are located on the PHS Energy Center west facility boundary with Boiler Units 4, 5, and 6 in operation.

The result from direct "primary"  $PM_{2.5}$  emissions dispersion modeling, secondary PM emissions, applicable neighboring sources, plus a representative  $PM_{2.5}$  background concentrations from Section 2.9 of this report, which includes monitored secondary  $PM_{2.5}$  concentrations, were used to show compliance with national  $PM_{2.5}$  annual and 24-hour average AAQS.  $PM_{2.5}$  model results are summarized in Table 10.

	Modeled Concentration with Neighboring Sources and Secondary PM (µg/m <sup>3</sup> )	Modeled Concentration With Background (µg/m³)	Location UTMs E/N	
24 Hour Average Highest 8 <sup>th</sup> High	6.0	28.0	350803.8	3883183.9
Annual Average	2.13	10.53	350815.0	3883191.0

#### TABLE 10: PM2.5 CIA Model Results

Figures 7 and 8 summarize the results of the modeling analysis.



Figure 7: Aerial Map of PM<sub>2.5</sub> 8<sup>th</sup> Highest Daily Maximum High 24 Hour Model Result  $(\mu g/m^3)$ 



Figure 8: Aerial Map of PM2.5 Annual Model Result  $(\mu g/m^3)$ 

#### 3.2.4 PM<sub>10</sub> Cumulative Impact Analysis Modeling Results

CIA  $PM_{10}$  24-hour average modeling was performed with terrain elevations and building downwash for PHS Energy Center, neighboring sources and meteorology which included 5 years of data, 2014 – 2018 Albuquerque Meteorological data, obtained from the AEHD AQP.  $PM_{10}$ emissions rates represented the maximum hourly rate for all emission sources, including applicable neighboring sources. South Valley monitor representative 24-hour  $PM_{10}$  background concentrations was added to the modeled results and compared to the lowest applicable ambient standard. The 24-hour background concentrations that were used for  $PM_{10}$  24-hour averaging period is found in Section 2.9 of this report.

Based on the New Mexico Modeling Guideline "...[W]hen n years are modeled, the  $(n+1)^{th}$  highest concentration over the n-year period is the design value, since this represents an average or expected exceedance rate of one per year." For 5 years of modeled met data, the design value is the highest 6<sup>th</sup> high.

The 24-hour average highest  $6^{th}$  high concentrations showed, where significant PM<sub>10</sub> (above SIL) from PHS Energy Center sources, are located on the PHS Energy Center west facility boundary with Boiler Units 4, 5, and 6 in operation.

Table 11 summarizes the 24-hour average highest 6<sup>th</sup> high and receptor location.

#### TABLE 11: PM<sub>10</sub> CIA Model Results

	Modeled Concentration with Neighboring Sources (µg/m <sup>3</sup> )	Modeled Concentration With Background (µg/m <sup>3</sup> )	Location UTMs E/N	
24 Hour Average Highest 6 <sup>th</sup> High	8.6	50.6	350803.8	3883183.9

Figure 9 summarize the results of the modeling analysis.


Figure 9: Aerial Map of  $PM_{10}$  Highest  $6^{th}$  High 24-Hour Model Result  $(\mu g/m^3)$ 

#### **Modeling File List**

Model File Name	Description
PHS ROI	PHS Energy Center Sources Only ROI modeling

Model File Name	Description
PHS CIA NO2 1hrOLMUrban	Cumulative NO <sub>2</sub> Modeling – 1-Hour
PHS CIA NO2 AnnualARMUrban	Cumulative NO <sub>2</sub> Modeling – Annual Average
PHS CIA SO2 1hrUrban	Cumulative SO <sub>2</sub> Modeling – 1-Hour
PHS CIA PM10 24hrUrban	Cumulative PM <sub>10</sub> Modeling – 24-Hour
PHS CIA PM25 24hrUrban	Cumulative PM <sub>2.5</sub> Modeling – 24-Hour
PHS CIA PM25 AnnualUrban	Cumulative PM <sub>2.5</sub> Modeling – Annual Average

# Attachment A

# **Boiler Hours on Oil**

	2016	2017	2018	2019	2020	2021	Total
Unit 3	0	0	0	0	0	0	0
Unit 4	0	0	0	0	0	17.5	17.5
Unit 5	0	0	0	0	0	0	0
Unit 6	0	0	0	0	0	5	5

The table below is a summary of the boiler hours on oil for the years 2016 through April, 2021.

# **Attachment B**

**Boiler Stack Parameters** 

## **ENERGY CENTER BOILERS**

DATA	Boiler # 1	Boiler # 2	Boiler # 3	Boiler # 4
MANUFACTURER	KEWANEE	KEWANEE	SUPERIOR	BURNHAM
ASSET NUMBER	PM # 5517	P.M <b>#</b> 5518	PM# 5519	PM # 5727
TYPE OF BOILER	FIRE TUBE, HIGH PRESSURE	FIRE TUBE, HIGH PRESSURE	FIRE TUBE, HIGH PRESSURE	FIRE TUBE, HIGH PRESSURE
NATIONAL BOARD NUMBER	33550	33529	13398	27718
MAXIUM PSI	150 PSI	150 PSI	150 PSI	150 PSI
TOTAL HEATING SURFACE	2500 sq. ft.	2500 sq. ft.	1022 sq. ft.	2500 sq. ft.
REQUIRED RELIEF CAP.	20,000	20,000	8,176	19,527
NUMBER OF RELIEF VALVES	2	2	2	2
RELIEF VALVE LIFT, PSI	125 psi	125 psi	125 psi	150 psi
CAP. BTU/HR	2 @10,660	2 @10,660	1 @3,500 1@5,592	2 @10,660
NUMBER OF LOW WATER CUTOUTS	2	2	2	2
LOW WATER CUTOUT TYPE	2 float	2 float	2 float	1-float 1-probe
SECONDARY MANUAL RESET	YES	YES	YES	YES
SOFT WATER	YES	YES	YES	YES
D.A. TANK	YES	YES	YES	YES
HIGH PSI / LIMIT W / MAN. RESET	YES	YES	YES	YES
GAS VENTS OUTSIDE	YES	YES	YES	YES
CHEMICAL TREATMENT	YES	YES	YES	YES
TREATMENT POLYMER FOR SCALE	YES	YES	YES	YES
SULFITE FOR OXYGEN PITTING	YES	YES	YES	YES
MAINTENANCE CONTRACT	NO	NO	NO	NO
BREAKDOWNS	NO	NO	NO	NO
NEXT INTERNAL INSPECTION, (ANNUAL P.M.)				
DATA	Boiler # 1	Boiler # 2	Boiler # 3	Boiler # 4
MANUFACTURER	KEWANEE	KEWANEE	SUPERIOR	BURNHAM
ASSET NUMBER	PM # 5517	PM # 5518	PM # 5519	PM # 5727
TYPE OF BOILER	FIRE TUBE, HIGH PRESSURE	FIRE TUBE, HIGH PRESSURE	FIRE TUBE, HIGH PRESSURE	FIRE TUBE, HIGH PRESSURE



#### **Randal Toledo**

From: Sent: To: Subject: Jason Paxson <jason@csinm.com> Tuesday, June 08, 2021 2:43 PM Randal Toledo Re: Emailing: Burner 1 (2)

Hi Randal,

Here's what I got from Powerflame...Still waiting on Webster.

Thanks,

Jason Paxson

Combustion Systems

Below is the requested information.

At the high fire of 20,925 Mbh and 400 deg F stack temp the stack flow will be approximately 7,073 ACFM.

On 6/8/2021 12:47 PM, Randal Toledo wrote:

This Burner is for the two KEWANEE Boilers

Randal Toledo Special Projects Manager / DSR

4538 McLeod Rd. Albuquerque New Mexico 87109 Main: (505) 881-0220 | Office: (505) 962-2823 | Mobile: (505) 991-2918

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the system manager. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Miller Bonded Inc. Finally, The recipient should check this email and any attachments for the presence of viruses or malicious software. Miller Bonded Inc. accepts no liability for any damage caused by receiving, reading or distributing this email or its attachments.



#### **Randal Toledo**

From: Sent: To: Subject: Jason Paxson <jason@csinm.com> Tuesday, June 08, 2021 2:43 PM Randal Toledo Re: Emailing: Burner 1 (2)

Hi Randal,

Here's what I got from Powerflame...Still waiting on Webster.

Thanks,

Jason Paxson

**Combustion Systems** 

Below is the requested information.

At the high fire of 20,925 Mbh and 400 deg F stack temp the stack flow will be approximately 7,073 ACFM.

#### On 6/8/2021 12:47 PM, Randal Toledo wrote:

This Burner is for the two KEWANEE Boilers

Randal Toledo Special Projects Manager / DSR

4538 McLeod Rd. Albuquerque New Mexico 87109 Main: (505) 881-0220 | Office: (505) 962-2823 | Mobile: (505) 991-2918

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the system manager. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Miller Bonded Inc. Finally, The recipient should check this email and any attachments for the presence of viruses or malicious software. Miller Bonded Inc. accepts no liability for any damage caused by receiving, reading or distributing this email or its attachments.



And the second sec

#### **Randal Toledo**

From: Sent: To: Subject: Jason Paxson <jason@csinm.com> Tuesday, June 08, 2021 12:22 PM Randal Toledo Re: Emailing: Burner 3

Hi Randal,

Here's what I got back from the Powerflame rep.

Below is what I received from one of our senior engineers.

The exhaust gas flow rate will be approximately 2,835 ACFM. This is based on the high fire rate of 8400 Mbh and a 400 degree F stack temp.

On 6/7/2021 1:19 PM, Randal Toledo wrote:

> Jason , the last one was the Boiler name plate this is the BURNER name plate.

>
> Randal Toledo
> Special Projects Manager / DSR
>
> 4538 McLeod Rd. Albuquerque New Mexico 87109
> Main: (505) 881-0220 | Office: (505) 962-2823 | Mobile: (505) 991-2918
>

> This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the system manager. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Miller Bonded Inc. Finally, The recipient should check this email and any attachments for the presence of viruses or malicious software. Miller Bonded Inc. accepts no liability for any damage caused by receiving, reading or distributing this email or its attachments.



Office: (505) 962-2823 | Mobile: (505) 991-2918 Begin forwarded message:

> From: Randal Toledo <RToledo@millerbonded.com> Date: June 10, 2021 at 2:51:37 PM MDT To: Nils Madden <nmadden@webstercombustion.com> Subject: Re: 500 HP Burner - Flue Gas Flow Rate

Got it Thx!

Sent from my iPhone

On Jun 10, 2021, at 2:49 PM, Nils Madden <nmadden@webstercombustion.com> wrote:

1

Hello,

Numbers you asked for:

- 21,000 MBH burner (500 HP boiler)
- Natural Gas
- 3% O2 stack (15% Excess Air)
- 400 Fahrenheit stack temperature
- 5,000 FASL

Results:

- Total flue gas flow 18,280 lb/hr
- Flue gas density at conditions 0.03686 lb/ft^3
- Total flue gas flow 8,265 ACFM

Regards,

#### Nils Madden

Director of Engineering Webster Combustion Technology, LLC Attachment C

# ISR Ratio CAPCOA Guidance Document October 27, 2011 Appendix C

Appendix C - In-Stack NO<sub>2</sub>/NOx Ratios

Appendix C Page 56

	Recommend In-stack NO2/NOx Ratios			
Refer #	Fuel	Equipment Category (Controls)	Range of Ratios (%)	Recommended Ratio (%)
		Boilers		
1		Default	10	10
2		6.6 MMBtu/Hr (Force Draft)* <sup>L</sup>	0.0 - 2.90	1.58**
2	NG	7.6 MMBtu/Hr (SCR / FGR)*	3.45 – 15.79	9.65**
2		11.4 MMBtu/Hr (Force Draft)* <sup>L</sup>	1.81 – 3.51	2.68**
		Compressor IC Engines		
1		Default	60	60
2a		225 BHP IGN Timing BTC 17***	11.61 – 11.86	11.76**
2a		350 BHP IGN Timing BTC 18***	4.37 – 4.83	4.66**
2a		550 BHP IGN Timing BTC 20***	0.93 – 2.98	1.96**
2a		625 BHP IGN Timing BTC 10***	10.97 – 11.96	11.6**
2a		773 BHP IGN Timing BTC 9***	58.04 - 58.54	58.3**
2a	NG	773 BHP IGN Timing BTC 20***	72.65 – 73.42	73.12**
2a		880 BHP IGN Timing BTC 8***	9.79 – 14.14	11.93**
2a		880 BHP IGN Timing BTC 15***	0.7 – 8.28	2.52**
2a		1500 BHP IGN Timing BTC 12***	10.32 – 12.03	11.47**
2a		1500 BHP IGN Timing BTC 6.5***	18.42 – 21.33	19.97**
2a		4000 BHP IGN Timing BTC 5***	22.36 – 25.69	23.82**
2a	Waste Gas	880 BHP IGN Timing BTC 20***	1.77 – 6.10	3.86**
2a	(Field Gas)	1000 BHP***	0.40 - 0.81	0.64**
		Dryer		-
	NG	20 MMBTU/Hr (Milk -Tower Dryer)*	3.85 – 11.11	6.88**
Glass Furnace				
2	NG	Glass Furnace	2.45 – 11.59	4.32**
		Heaters		
2	NG / Refinery Gas	14.1 MMBTU/Hr (John Zink PSMR)*	11.54 – 52.63	32.0**

Recommend In-stack NO2/NOx Ratios						
Refer #	Fuel	Equipment Category (Controls)	Equipment Category (Controls) Range of Ratios (%)		os (%)	Recommended Ratio (%)
		IC Engines				
2	Biogas	200 BHP*		0.0 – 1.9	0	0.37**
1	Diagol	Default		20		20
	Diesei	322 BHP (WP)*		0.0 – 50.	0	15.64**
4		Default – Lean Burn		5-10		10
2		120 BHP (3-Way Catalyst)*		0.1 – 2.8	3	0.9**
2		162 BHP (catalytic converter, air/fuel ratio)*		0.0 – 12.	5	1.81**
2		165 BHP (3-Way Catalyst)*		0.0 – 17.5	58	3.16**
2	NC	180 BHP (NSCR)*		1.02 – 3.4	41	1.82**
2	NG	208 BHP (Catalytic converter, air/fuel ratio)*		0.0 – 1.4	4	0.48**
2		1,070 BHP (LB/WP–Turbocharger/Intercooler)*		20.91 – 39	.62	34.41**
2		1,529 BHP (LB - CO Catalyst, SCR)*	2.70 - 4.58		58	3.59**
2		2,775 BHP (SCR)*	14.53 – 26.33		.33	19.46**
2		4,175 BHP (SCR,CO & VOC Catalysts)*	0.0 – 21.28			1.15**
		Transportation Refrigeration Units	(TRUs)			
			Fuel	Eng Speed	Exhaust	NO <sub>2</sub> / NO <sub>x</sub> Ratio
			CARB	High	Muffler	15.37
		CARB= CARB Diesel	GTL	High	Muffler	16.17
5		GTL = Gas To Liquid	CARB	High	pDPF	25.71
			CARB	Low	Muffler	22.66
			GTL	Low	Muffler	25.12
			CARB	Low	pDPF	12.98
		Truck / Cars				
6	Gas/Diesel	Light / Medium Duty		16-25		25
Ø	Diesel	Heavy Duty		6-11		11
		Turbines				
3	NG	GE Turbines	8.33 – 9.1 9.1		9.1	

	Recommend In-stack NO2/NOx Ratios			
Refer #	Fuel	Equipment Category (Controls)	Range of Ratios (%)	Recommended Ratio (%)
2a		Solar Centaur T-4702 (3.4 MW)***	8.43 – 12.42	10.32**

\* Samples taken each minute or several minutes

\*\*Value represents the statistical average of all data points

\*\*\* 30 min / 1 hour Source

Test

L = Load ratings have been included in average

LB = Lean Burn

WP = Water Pump

#### References

- 1. Barrie Lawrence, Environmental Scientist, Government of Newfoundland and Labrador, "Guideline for Plume Dispersion Modeling" 1st Revision: November 20, 2006, Page 14
- 2. District Database "NO2 -NOx Ratio.mdb" Data is based on CEMs, source test, and portable analyzer data collected in the San Joaquin Valley
  - a. District Database "NO2 -NOx Ratio.mdb" Data is based on source test data collected from out of state (Arkansas Department of Environmental Quality Office of Air Quality)
- 3. Roointon Pavri and Gerald D. Moore, GE Energy Services Atlanta, GA, "Gas Turbine Emissions and Control" March 2001 Page 63
- 4. Nigel N. Clark, Center for Alternative Fuels, Engines and Emissions Department of Mechanical and Aerospace Engineering West Virginia University Morgantown, WV 26506, "Selective NOx Recirculation for Stationary Lean-Burn Natural Gas Engines" April 30, 2007 Page 64
- 5. Robb A. Barnitt, National Renewable Energy Laboratory, "Emissions of Transport Refrigeration Units with CARB Diesel, Gas-to-Liquid Diesel, and Emissions Control Devices", May 1, 2010
- 6. P G Boulter, I S McCrae, and J Green, Transportation research Laboratory, "Primary NIO2 Emissions From Road Vehicles in the Hatfield and Bell Commons Tunnels", July 2007

Attachment H Public Notice Documents



Timothy M. Keller, Mayor **Public Participation** 

List of Neighborhood Associations and Neighborhood Coalitions MEMORANDUM

To:	Paul Wade, Principal, Montrose Air Quality Services, LLC
From:	Elizabeth Pomo, Environmental Health Scientist
Subject:	Determination of Neighborhood Associations and Coalitions
	within 0.5 mile of 1002 Silver Ave SE in Bernalillo County, NM
Date:	October 28, 2021

#### **DETERMINATION:**

On October 28, 2021 I used the City of Albuquerque Zoning Advanced Map Viewer (http://coagisweb.cabq.gov/) to verify which City of Albuquerque Neighborhood Associations (NA), Homeowner Associations (HOA) and Neighborhood Coalitions (NC) are located within 0.5 mile of 1002 Silver Ave SE in Bernalillo County, NM.

I then used the City of Albuquerque Office (COA) of Neighborhood Coordination's Monthly Master NA List dated October 2021 and the Bernalillo County (BC) Monthly Neighborhood Association October 2021 Excel file to determine the contact information for each NA and NC located within 0.5 mile of 1002 Silver Ave SE in Bernalillo County, NM.

Health Department's public notice. Duplicates have been deleted.			
COA/BC Association or Coalition	Name	Email or Mailing Address*	
Citizens Information Committee	Frank Martinez	501 Edith Blvd NE, Albuquerque, NM 87102;	
of Martinaztown	Kristi Houde	kris042898@live.com;	
of Martineziowi	Association Email	cicm-na@comcast.net;	
EDo Noighborhood Association	Terry Keene	keenecafe@aol.com;	
ED0 Neighborhood Association	David Tanner	david@edoabq.com;	
Huning Highland Historic	Ann Carson	a.louisa.carson@gmail.com;	
District Association	Bonnie Anderson	andersonbonnie505@gmail.com;	
Silver Hill Neighborhood	Don McIver	dbodinem@gmail.com;	
Association	James Montalbano	ja.montalbano@gmail.com	
Association	Association Email	silverhillabq@gmail.com;	
South Droodway Naighborhood	Tiffany Broadus	tiffany.hb10@gmail.com;	
A see sistion	Frances Armijo	fparmijo@gmail.com;	
Association	Association Email	abqsbna@gmail.com;	
Spruce Park Neighborhood	Bart Cimenti	bartj505@gmail.com;	
Association	John Cochran	jrcochr@gmail.com;	
Sycamore Neighborhood	Richard Vigilano	richard@vigliano.net;	
Association	Mardon Gardella	mg411@q.com:	

The table below contains the contact information, which will be used in the City of Albuquerque Environmental Health Department's public notice. Duplicates have been deleted.

\*If email address is not listed, provide public notice via certified mail and include a copy of each mail receipt with the application submittal.

### NOTICE FROM THE APPLICANT Notice of Intent to Apply for Air Quality Construction Permit

You are receiving this notice because the New Mexico Air Quality Control Act (20.11.41.13B NMAC) requires any owner/operator proposing to construct or modify a facility subject to air quality regulations to provide public notice by certified mail or electronic mail to designated representatives of recognized neighborhood associations and coalitions within 0.5-mile of the property on which the source is or is proposed to be located.

This notice indicates that the <u>owner/operator intends to apply for an Air Quality Construction Permit</u> from the Albuquerque – Bernalillo County Joint Air Quality Program. Currently, <u>no application for this proposed project</u> <u>has been submitted</u> to the Air Quality Program. Applicants are required to include a copy of this form and documentation of mailed notices with their Air Quality Construction Permit Application.

#### **Proposed Project Information**

Applicant's name and address: Nombre y domicilio del solicitante:	
<b>Owner / operator's</b> name and address: Nombre y domicilio del propietario u operador:	
Contact for comments Datos actuales para comer	and inquires: ntarios y preguntas:
Nam	
Phone Number (Número	(Domicillo):
E-mail Address (Correo	Electrónico):
Actual or estimated dat Fecha actual o estimada en Description of the sour Descripción de la fuente:	te the application will be submitted to the department: n que se entregará la solicitud al departamento: .ce:
Exact location of the so or proposed source: Ubicación exacta de la fuer fuente propuesta:	ource nte o
Nature of business: Tipo de negocio:	
Process or change for permit is requested: Proceso o cambio para el o permiso:	which the cuál de solicita el
Maximum operating sc Horario máximo de operaci	hedule: iones:
Normal operating sche Horario normal de operacio	dule: ones:

#### Preliminary estimate of the maximum quantities of each regulated air contaminant the source will emit:

Estimación preliminar de las cantidades máximas de cada contaminante de aire regulado que la fuente va a emitir:

Air Contaminant	Proposed Construction Permit Permiso de Construcción Propuesto		Net Char (for permit modification of Cambio Neto de (para modificación de perm	nges or technical revision) - Emisiones niso o revisión técnica)
Contaminante de aire	pounds per hour libras por hora	tons per year toneladas por año	pounds per hour libras por hora	tons per year toneladas por año
CO				
NOx				
VOC				
SO2				
PM10				
PM2.5				
HAP				

Questions or comments regarding this Notice of Intent should be directed to the Applicant. Contact information is provided with the Proposed Project Information on the first page of this notice. <u>To check the status</u> of an Air Quality Construction Permit application, call 311 and provide the Applicant's information, or visit www.cabq.gov/airquality/air-quality-permits.

The Air Quality Program will issue a Public Notice announcing a 30-day public comment period on the permit application for the proposed project when the application is deemed complete. The Air Quality Program does not process or issue notices on applications that are deemed incomplete. More information about the air quality permitting process is attached to this notice.

#### Air Quality Construction Permitting Overview

This is the typical process to obtain an Air Quality Construction Permit for Synthetic Minor and Minor sources of air pollution from the Albuquerque – Bernalillo County Joint Air Quality Program.

**Step 1: Pre-application Meeting:** The Applicant and their consultant must request a meeting with the Air Quality Program to discuss the proposed action. If air dispersion modeling is required, Air Quality Program staff discuss the modeling protocol with the Applicant to ensure that all proposed emissions are considered.

**Notice of Intent from the Applicant:** Before submitting their application, the Applicant is required to notify all nearby neighborhood associations and interested parties that they intend to apply for an air quality permit or modify an existing permit. The Applicant is also required to post a notice sign at the facility location.

**Step 2: Administrative Completeness Review and Preliminary Technical Review:** The Air Quality Program has 30 days from the day the permit is received to review the permit application to be sure that it is administratively complete. This means that all application forms must be signed and filled out properly, and that all relevant technical information needed to evaluate any proposed impacts is included. If the application is not complete, the permit reviewer will return the application and request more information from the Applicant. Applicants have three opportunities to submit an administratively complete application with all relevant technical information.

**Public Notice from the Department:** When the application is deemed complete, the Department will issue a Public Notice announcing a 30-day public comment period on the permit application. This notice is distributed to the same nearby neighborhood associations and interested parties that the Applicant sent notices to, and published on the Air Quality Program's website.

During this 30-day comment period, individuals have the opportunity to submit written comments expressing their concerns or support for the proposed project, and/or to request a Public Information Hearing. If approved by the Environmental Health Department Director, Public Information Hearings are held after the technical analysis is complete and the permit has been drafted.

**Step 3: Technical Analysis and Draft Permit:** Air Quality Program staff review all elements of the proposed operation related to air quality, and review outputs from advanced air dispersion modeling software that considers existing emission levels in the area surrounding the proposed project, emission levels from the proposed project, and meteorological data. The total calculated level of emissions is compared to state and federal air quality standards and informs the decision on whether to approve or deny the Applicant's permit.

**Draft Permit:** The permit will establish emission limits, standards, monitoring, recordkeeping, and reporting requirements. The draft permit undergoes an internal peer review process to determine if the emissions were properly evaluated, permit limits are appropriate and enforceable, and the permit is clear, concise, and consistent.

**Public Notice from the Department:** When the technical analysis is complete and the permit has been drafted, the Department will issue a second Public Notice announcing a 30-day public comment period on the technical analysis and draft permit. This second Public Notice, along with the technical analysis documentation and draft permit, will be published on the Air Quality Program's website, and the public notice for availability of the technical analysis and draft permit will only be directly sent to those who requested further information during the first comment period.

#### Air Quality Construction Permitting Overview

During this second 30-day comment period, residents have another opportunity to submit written comments expressing their concerns or support for the proposed project, and/or to request a Public Information Hearing.

**Possible Public Information Hearing:** The Environmental Health Department Director may decide to hold a Public Information Hearing for a permit application if there is significant public interest and a significant air quality issue. If a Public Information Hearing is held, it will occur after the technical analysis is complete and the permit has been drafted.

**Step 4: Public Comment Evaluation and Response:** The Air Quality Program evaluates all public comments received during the two 30-day public comment periods and Public Information Hearing, if held, and updates the technical analysis and draft permit as appropriate. The Air Quality Program prepares a response document to address the public comments received, and when a final decision is made on the permit application, the comment response document is published on the Air Quality Program's website and distributed to the individuals who participated in the permit process. If no comments are received, a response document is not prepared.

**Step 5: Final Decision on the Application:** After public comments are addressed and the final technical review is completed, the Environmental Health Department makes a final decision on the application. If the permit application meets all applicable requirements set forth by the New Mexico Air Quality Control Act and the federal Clean Air Act, the permit is approved. If the permit application does not meet all applicable requirements, it is denied.

Notifications of the final decision on the permit application and the availability of the comment response document is published on the Air Quality Program's website and distributed to the individuals who participated in the permit process.

**The Department must approve** a permit application if the proposed action will meet all applicable requirements and if it demonstrates that it will not result in an exceedance of ambient air quality standards. Permit writers are very careful to ensure that estimated emissions have been appropriately identified or quantified and that the emission data used are acceptable.

**The Department must deny** a permit application if it is deemed incomplete three times, if the proposed action will not meet applicable requirements, if estimated emissions have not been appropriately identified or quantified, or if the emission data are not acceptable for technical reasons.

For more information about air quality permitting, visit <u>www.cabq.gov/airquality/air-quality-permits</u>

#### SUBJECT: Public Notice of Proposed Air Quality Construction Permit Application

Dear Neighborhood Association/Coalition Representative(s),

#### Why did I receive this public notice?

You are receiving this notice in accordance with New Mexico Administrative Code (NMAC) 20.11.41.13.B(1) which requires any applicant seeking an Air Quality Construction Permit pursuant to 20.11.41 NMAC to provide public notice by certified mail or electronic mail to the designated representative(s) of the recognized neighborhood associations and recognized coalitions that are within one-half mile of the exterior boundaries of the property on which the source is or is proposed to be located.

#### What is the Air Quality Permit application review process?

The City of Albuquerque, Environmental Health Department, Air Quality Program (Program) is responsible for the review and issuance of Air Quality Permits for any stationary source of air contaminants within Bernalillo County. Once the application is received, the Program reviews each application and rules it either complete or incomplete. Complete applications will then go through a 30-day public comment period. Within 90 days after the Program has ruled the application complete, the Program shall issue the permit, issue the permit subject to conditions, or deny the requested permit or permit modification. The Program shall hold a Public Information Hearing pursuant to 20.11.41.15 NMAC if the Director determines there is significant public interest and a significant air quality issue is involved.

Applicant Name	Presbyterian Healthcare Services
Site or Facility Name	Presbyterian Energy Center
Site or Facility Address	1002 Silver Ave SE, Albuquerque, NM 87106
New or Existing Source	EXISTING
Anticipated Date of Application Submittal	November 31 2021
Summary of Proposed Source to Be Permitted	This 20.11.41.2 permit application is for a significant modification of Presbyterian Healthcare Services (PHS) Permit #0273-M3-1TR to include installation of a new Caterpillar Model G3516H Natural Gas Cogeneration (CoGen) Package. The CoGen will produce electricity and steam (heat) for the new hospital building under construction. Caterpillar rates the engine at 2,746 BHP. Additionally, PHS will be installing new burners on existing boilers 1 and 2 (Permit Units 3 and 4) which will reduce emissions of NOx, VOC, and Particulate. PHS will restrict to only operating 3 of the 4 boilers at any one time.

#### What do I need to know about this proposed application?

#### What emission limits and operating schedule are being requested?

See attached Notice of Intent to Construct form for this information.

How do I get additional information regarding this proposed application?

For inquiries regarding the proposed source, contact:

- Keith Long
- hlong4@phs.org
- 505-563-6221

For inquiries regarding the air quality permitting process, contact:

- City of Albuquerque Environmental Health Department Air Quality Program
- <u>aqd@cabq.gov</u>
- (505) 768-1972



#### Presbyterian Healthcare Permit #0273-M3-1TR Revision

1 message

#### Paul Wade <pwade@montrose-env.com>

Tue, Nov 16, 2021 at 12:13 PM

To: kris042898@live.com, cicm-na@comcast.net, keenecafe@aol.com, a.louisa.carson@gmail.com, andersonbonnie505@gmail.com, dbodinem@gmail.com, ja.montalbano@gmail.com, silverhillabq@gmail.com, tiffany.hb10@gmail.com, fparmijo@gmail.com, abqsbna@gmail.com, bartj505@gmail.com, jrcochr@gmail.com, richard@vigliano.net, mg411@q.com, david@edoabq.com

Cc: Keith Long <hlong4@phs.org>, "Munoz-Dyer, Carina G." <cmunoz-dyer@cabq.gov>, Charles Massegee <charles.massegee@jaynescorp.com>, david@edoabq.com

Dear Neighborhood Association/Coalition Representative(s)

This email is sent to you per the requirements of Bernalillo County/City of Albuquerque Air Quality Regulation 20.11.41.B.1 NMAC "Applicant's Public Notice Requirements". The attached "Notice of Intent" (NOI) addresses a modification to "Authority to Construct" Permit #0273-M3-1TR. Presbyterian Healthcare Systems is proposing installation of a new Caterpillar Model G3516H Natural Gas Cogeneration (CoGen) Package at the Presbyterian Energy Center. The CoGen will produce electricity and steam (heat) for the new hospital building under construction. Attached also is the NOI cover letter.

Thank You

---

MEG Logo\_Signature

#### **Paul Wade**

Principal

Montrose Air Quality Services, LLC

3500 G Comanche Rd. NE, Albuquerque, NM 87107

T: 505.830.9680 x6 | F: 505.830.9678

PWade@montrose-env.com

#### www.montrose-env.com

CONFIDENTIALITY NOTICE: The contents of this email message and any attachments are intended solely for the addressee(s) and may contain confidential, proprietary and/or privileged information and may be legally protected from disclosure. If you are not the intended recipient of this message or their agent, or if this message has been addressed to you in error, please immediately alert the sender by reply email and then delete this message and any attachments and the reply from your system. If you are not the intended recipient, you are hereby notified that any disclosure, use, dissemination, copying, or storage of this message or its attachments is strictly prohibited.

2 attachments

PHS Energy Center Notice of Intent.pdf 146K

PHS Energy Center Public Notice Cover Letter.pdf





2. Actual or Estimated Date the Application will be Submitted to the Department: Fecha Actual o Estimada en que se Entragará la Solicitud al Departamento: Estimated - November 30, 2021 **3. Exact Location of the Source or Proposed Source:** Ubicación Excata de la Fuente o Fuente Propuesta: 1002 Silver Ave SE, Albagacraac, XM **Description of the Source:** Descripción del Fuente: Encray center for Presbyterian Hospital + Medical Center **Nature of Business:** Tipo de Negocio: \_\_\_\_ Prividas heat and electricity to Prestyterian Hospital + Medical Conter **Process or change for which a permit is requested:** Proceso o cambio para el cuál se solicita el permiso: Additail ofa. CAT 63516 H natical que cogeneration Plant. Install new burners for builders 1 +2 Preliminary estimate of the maximum quantities of each regulated air contaminant the source will emit: Estimación preliminar de las cantidades máximas de cada contaminante de aire regulado que la fuente va a emitir:

Air Contaminant

**Proposed Construction Permit** 

**Net Change Emissions** (for permit modification or technical revision)

Contaminante de Aire	Permiso de Construcción Propuesto		Cambio Neto de Emisiones (para modificación de permiso o revisión técnica)		
ue Ane	Pounds per hour libras por hora	Tons per year toneladas por año	Pounds per hour libras por hora	Tons per year toneladas por año	
СО	39.7	66.2.	9.27	39.9	
NOX + NMHC	108.5	68.4	5.2.7	1.83	
SO2	17.2.	4.50	-0.07	-2,79	
PM10	4.03	3,21	0.08	-1-61	
PM2.5	4.03	3.21	E.CE	-1.61	
HAP	1.94	7.02	1.46	6.40	
VOC	6.2.0	12.3	3.04	9.2.7	
5. Maximum Opera Horario Máximo de l	ting Schedule: Operaciones: 24 hr	Iday, Iday/week,	\$760 hr/year		
<b>Normal Operatio</b> Horario Normal de C	n Schedule: Operaciones: <u>2.4 hr</u>	Iday, Iday/weck,	8760 hr/year		

**Current Contact Information for Comments and Inquiries** 6. Datos actuales para Comentarios y Preguntas

> Name (Nombre): Keith Long Address (Domicilio): 1100 Contral Ave. SE, Albhauergue, NIM 87106 Phone Number (Número Telefónico): 505-563-6221 Email Address (Correo Electrónico): hlong 4@ phs. 009

Call 311 for additional information concerning this project, the Air Quality Program, or to file a complaint. Llame al 311 para obtener información adicional sobre este proyecto, del Programa de Calidad del Aire, o para presenter una queja. Goi 311 để biết thêm thông tin hoặc để khiếu nại về dự án này, Chương Trình Chất Lượng Khôna Khí

City of Albuquerque, Environmental Health Department, Air Quality Program – Stationary Source Permitting Ciudad de Albuquerque, Departamento de Salud Ambiental, Programa de Calidad del Aire - Permisos para Fuentes Inmóviles (505) 768-1972, aqd@cabq.gov

THIS SIGN SHALL REMAIN POSTED UNTIL THE DEPARTMENT TAKES FINAL ACTION ON THE PERMIT APPLICATION ESTE AVISO DEBERÁ DE MANTENERSE PUESTO HASTA QUE EL DEPARTAMENTO TOME UNA DECISIÓN SOBRE LA SOLICITUD DE PERMISO

			v	enuor 1100		100100
NOTE	INVOICE NUMBER	PURCHASE ORDER	INVOICE DATE	AMOUNT	DISCOUNT	NET AMOUNT
	RFD121321		12/13/2021	6,516.00	0.00	6,516.0
Air Quality Fee for Co	/ Permit Applicatio Gen project at PH	n Review				
	1 5					
		8				
			TOTALS	\$6,516.00	\$0.00	\$6,516.
E ORIGINAL DOC	CUMENT HAS A WHITE REFL	ECTIVE WATERMARK ON THE B	ACK.	HOLD AT AN ANGLE TO	VIEW. DO NOT CASH IF N	OT PRESENT.
A PRE	SBYTERIAN			WELLS FARGO, I	<b>N.A.</b>	<u>56-3</u>
	26666 ACCOUNTS F FROLIE NM 87125-6	AYABLE		oncon diodra in odgrupoom		
Phone (50	05) 923-8519		DATE		NET	
			12/16/2021	76	10. ILI	
and a second of the second of	State State State		12/10/2021	/3;	0733	6,516.00
13259	housand Five Hunds	ed Sixteen and 00/10	0 Dollars			
PAY Six 7			218-33 (£-3-)			
<sub>PAY</sub> Six 7				7	encoder and the second s	<ul> <li>The second s second second sec</li></ul>
PAY Six 7	CITY OF ALBU	QUERQUE		1	an m/	neo
PAY <i>Six 7</i> D THE RDER	CITY OF ALBU	QUERQUE AZA NW		<u> </u>	an m/n	<u>~</u>
PAY <i>Six</i> 7 D THE RDER OF	CITY OF ALBU ONE CIVIC PL/ STE 3023	QUERQUE AZA NW		1	an n/n	